

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Edison screw lampholders

Douilles à vis edison pour lampes

IECNORM.COM : Click to view the full PDF of IEC 60238:2016+AMD1:2017+AMD2:2020 CSV



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2020 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and definitions clause of IEC publications issued between 2002 and 2015. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et définitions des publications IEC parues entre 2002 et 2015. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.



IEC 60238

Edition 9.2 2020-01
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Edison screw lampholders

Douilles à vis edison pour lampes

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.140.10

ISBN 978-2-8322-7771-3

Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

IECNORM.COM : Click to view the full PDF of IEC 60238:2016+AMD1:2017+AMD2:2020 CSV

REDLINE VERSION

VERSION REDLINE



Edison screw lampholders

Douilles à vis edison pour lampes

IECNORM.COM : Click to view the full PDF of IEC 60238:2016+AMD1:2017+AMD2:2020 CSV

CONTENTS

FOREWORD	4
INTRODUCTION to Amendment 2	6
1 Scope	7
2 Normative references	8
3 Terms and definitions	9
4 General requirement.....	14
5 General conditions for tests	14
6 Standard ratings	15
7 Classification	16
8 Marking	17
9 Dimensions.....	19
10 Protection against electric shock	22
11 Terminals	24
12 Provision for earthing	28
13 Construction	29
14 Switched lampholders.....	34
15 Moisture resistance, insulation resistance and electric strength	35
16 Mechanical strength	37
17 Screws, current-carrying parts and connections.....	41
18 Creepage distances and clearances	43
19 Normal operation	50
20 General resistance to heat.....	51
21 Resistance to heat, fire and tracking.....	54
22 Resistance to excessive residual stresses (season cracking) and to rusting	56
Annex A (normative) Season cracking/corrosion test	77
Annex B (informative) Guidance for requirements in IEC 61058-1 applicable to switches in lampholders (see 14.2)	79
Annex C (informative) Guidance for special requirements in appliance standards – Household and similar electrical appliances	81
Annex D (informative) Schedule of amended subclauses containing more serious/critical requirements which require products to be retested Clauses containing new or more stringent requirements with respect to the previous edition	83
Bibliography.....	84
Figure 1a –Nipple thread for lampholders: metric thread. Basic profile and design profile for the nut and for the screw.....	57
Figure 1b –Nipple thread for lampholders: ISO standard pipe thread. Basic profile and design profile for the nut and for the screw	58
Figure 2a – Gauges for metric thread for nipples	59
Figure 2b – Gauges for ISO standard pipe thread for nipples	60
Figure 3 – Gauge for holes for backplate lampholder screws	61
Figure 4 – Normal operation test apparatus	62
Figure 5 – Test caps for the test of Clause 18.....	63

Figure 6 – Torque apparatus.....	64
Figure 7 – Tumbling barrel.....	65
Figure 8 – Impact-test apparatus	66
Figure 9 – Pressure apparatus.....	67
Figure 10 – Ball-pressure test apparatus.....	67
Figure 11 – Test cap for the tests of 15.4 and 20.3	68
Figure 12 – Bending apparatus	69
Figure 13 – Test cap A and test cap B for lampholders E14 (2 of 2)	71
Figure 14 – Test cap for lampholders E27	72
Figure 15 – Test cap for lampholders E40.....	73
Figure 16 – Standard test finger (according to IEC 60529).....	74
Figure 17 – Clarification of some definitions.....	75
Figure 18 – Preparation of specimens for the needle-flame test of 21.4	76
Table 1 – Thickness of screw shells and contacts	20
Table 2 – Minimum effective screw lengths	21
Table 3 – Dimensions of threaded entries and set screws	22
Table 4 – Minimum dimensions of pillar-type terminals	26
Table 5 – Minimum dimensions of screw-type terminals	26
Table 6 – Pull and torque values.....	32
Table 7 – Insertion torque	34
Table 8 – Minimum and maximum removal torques	34
Table 9 – Test cap dimensions	38
Table 10 – Heights of fall	39
Table 11 – Maximum deformation values	41
Table 12 – Torque values	42
Table 13a – Minimum distances for AC (50/60 Hz) sinusoidal voltages up to 30 kHz – Impulse withstand category II.....	45
Table 13b – Minimum distances for AC (50/60 Hz) sinusoidal voltages up to 30 kHz – Impulse withstand category III.....	47
Table 14 – Minimum distances for non-sinusoidal ignition pulse voltages or equivalent peak voltages Up	50
Table 15 – Heating cabinet temperatures	53
Table A.1 – pH adjustment.....	77

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EDISON SCREW LAMPHOLDERS

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendments has been prepared for user convenience.

IEC 60238 edition 9.2 contains the ninth edition (2016-07) [documents 34B/1852/FDIS and 34B/1860/RVD], and its amendment 1 (2017-01) [documents 34B/1887/FDIS and 34B/1892/RVD] and its corrigendum (2018-01), and its amendment 2 (2020-01) [documents 34B/2029/CDV and 34B/2040A/RVC].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendments 1 and 2. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 60238 has been prepared by subcommittee 34B: Lamp caps and holders, of IEC technical committee 34: Lamps and related equipment.

This ninth edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Addition of a pull test for certain E5 and E10 lampholders.
- b) Annex D listing amended requirements/clauses which require products to be retested.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

In this standard, the following print types are used:

– *compliance statements: in italic type.*

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION to Amendment 2

Some changes and corrections needed for IEC 60238 became obvious during the work relating to the consolidated Edition 9.1 of IEC 60238.

Change 1:

Actual lamp holder safety standards require a ball pressure test in line with IEC 60695-10-2 in sections "Resistance to heat, fire and tracking". Within this test there is an alternative depth indentation method described for the calculation of the indentation diameter.

This alternative calculation option was removed from the latest edition of IEC 60695-10-2 dated 2014 and during its meeting held in Sydney in 2018, SC 34B/WG1 agreed to delete the alternative method as well from IEC 60238.

Change 2:

Based on IEC 60664-1:2007, 4.8.1.5 "Non tracking materials":

"For glass, ceramics or other inorganic insulating materials which do not track, creepage distances need not be greater than their associated clearance for the purpose of insulation coordination. The dimensions of Table F.2 for inhomogeneous field conditions are appropriate."

This is not completely reflected in TC 34 standards as revised recently. For applications with ELV it is of high importance whether the creepage distance shall be 0,6 mm or may be 0,2 mm in the case where inorganic insulating material is used.

Correction

In Amendment 1 to IEC 60238 Edition 9, a complete paragraph was deleted by accident. This was corrected with the publication of a corrigendum to Amendment 1, however an editorial correction needs to be made to the references to previous items, changed to table footnotes "a" and "d", as the referenced text was included in Tables 13a and 13b.

EDISON SCREW LAMPHOLDERS

1 Scope

This International Standard applies to lampholders with Edison thread E14, E27 and E40, designed for connection to the supply of lamps and semi-luminaires¹ only.

It also applies to switched-lampholders for use in AC circuits only, where the working voltage does not exceed 250 V r.m.s.

This standard also applies to lampholders with Edison thread E5 designed for connection to the supply mains of series connected lamps, with a working voltage not exceeding 25 V, to be used indoors, and to lampholders with Edison thread E10 designed for connection to the supply mains of series connected lamps, with a working voltage not exceeding 60 V, to be used indoors or outdoors. It also applies to lampholders E10 for building-in, for the connection of single lamps to the supply. These lampholders are not intended for retail sale.

As far as it reasonably applies, this standard also covers lampholders other than lampholders with Edison thread designed for connection of series-connected lamps to the supply.

NOTE This type of lampholder is for example used in Christmas tree lighting chains.

As far as it reasonably applies, this standard also covers adapters.

This standard also covers lampholders which are, wholly or partly, integral with a luminaire or intended to be built into appliances. It covers the requirements for the lampholder only. For all other requirements, such as protection against electric shock in the area of the terminals or of the lamp cap, the requirements of the relevant appliance standard are observed and tested after building into the appropriate equipment, when that equipment is tested according to its own standard. Such lampholders as well as lampholders provided with a snap-on outer shell, for use by luminaire manufacturers only, are not for retail sale.

This standard applies to lampholders to be used indoors or outdoors in residential as well as in industrial lighting installations. It also applies to candle lampholders. In locations where special conditions prevail, as for street lighting, on board ships, in vehicles and in hazardous locations, for example where explosions are liable to occur, special constructions may be required.

This standard does not apply to three-light lampholders E26d.

This standard is based on the following data relative to lamps for general lighting service:

- caps E14 are used for lamps with a current not exceeding 2 A;
- caps E27 are used for lamps with a current not exceeding 4 A;
- caps E40 are used for lamps with a current not exceeding 16 A, or 32 A if the nominal voltage of the supply does not exceed 130 V (see 5.5 and 6.3).

Where lampholders are used in luminaires, their maximum operating temperatures are specified in IEC 60598.

¹ Requirements for lampholders suitable for semi-luminaires are under consideration.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60061-1, *Lamp caps and holders together with gauges for the control of interchangeability and safety – Part 1: Lamp caps*

IEC 60061-2, *Lamp caps and holders together with gauges for the control of interchangeability and safety – Part 2: Lampholders*

IEC 60061-3, *Lamp caps and holders together with gauges for the control of interchangeability and safety – Part 3: Gauges*

IEC 60068-2-32:1975, *Basic environmental testing procedures – Part 2-32: Tests – Test Ed: Free fall*

IEC 60068-2-75:2014, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60112:2003, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*
Amendment 1:2009

IEC 60227 (all parts), *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V*

IEC 60245 (all parts), *Rubber insulated cables – Rated voltages up to and including 450/750 V*

IEC 60352-1:1997, *Solderless connections – Part 1: Wrapped connections – General requirements, test methods and practical guidance*

IEC 60399, *Barrel thread for lampholders with shade holder ring*

IEC 60417, *Graphical symbols for use on equipment* (available at: <http://www.graphical-symbols.info/equipment>)

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*
Amendment 1:1999
Amendment 2:2013²

IEC 60598-1, *Luminaires – Part 1: General requirements and tests*

IEC 60630, *Maximum lamp outlines for incandescent lamps*

IEC 60695-2-11:2014, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products (GWEPT)*

IEC 60695-11-5, *Fire hazard testing – Part 11-5: Test flames – Needle-flame test method – Apparatus, confirmatory test arrangement and guidance*

² A consolidated edition 2.2 (2013) exists including edition 2.0 (1989) and its Amendment 1 (1999) and Amendment 2 (2013).

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

cord-grip lampholder

lampholder incorporating a method of retaining a flexible cord by which it may then be suspended

3.2

threaded entry lampholder

lampholder incorporating a threaded component at the point of entry of the supply wires permitting the lampholder to be mounted on a mating threaded support

Note 1 to entry: A threaded entry lampholder was formerly called a “nipple lampholder”.

3.3

backplate lampholder

lampholder so designed as to be suitable for mounting by means of an associated or integral backplate, directly onto a supporting surface or appropriate box

3.4

lampholder for building-in

lampholder designed to be built into a luminaire, an additional enclosure or the like

3.4.1

unenclosed lampholder

lampholder for building-in so designed that it requires additional means, for example an enclosure, to meet the requirements of this standard with regard to protection against electric shock

3.4.2

enclosed lampholder

lampholder for building-in so designed that on its own it fulfils the requirements of this standard with regard to protection against electric shock and IP classification, if appropriate

3.5

independent lampholder

lampholder so designed that it can be mounted separately from a luminaire and at the same time providing all the necessary protection according to its classification and marking

3.6

terminal/contact assembly

part or assembly of parts which provides a means of connection between the termination of a supply conductor and the contact making surfaces of the corresponding lamp cap

Note 1 to entry: For clarification of some definitions, see also Figure 17.

3.7

outer shell

cylindrical component protecting the user from contact with the lamp cap.

Note 1 to entry: It may or may not be provided with an external screw thread for fixing a shade ring.

Note 2 to entry: For clarification of some definitions, see also Figure 17.

3.7.1

snap-on outer shell

outer shell for screwless assembly which does not contain the screw shell

Note 1 to entry: The lampholder should not be used when the snap-on outer shell is removed. It is therefore recommended to place an approval mark, if provided, in such a way that it is not visible when this type of outer shell is removed.

3.8

screw shell

cylindrical component having an internal screw thread of Edison form for the retention of the corresponding lamp (cap)

Note 1 to entry: In some constructions, the screw shell is permanently fixed to or integral with the outer shell.

Note 2 to entry: For clarification of some definitions, see also Figure 17.

3.9

insulating ring

cylindrical intermediate piece of insulating material separating a metal screw shell and a metal outer shell

Note 1 to entry: For clarification of some definitions, see also Figure 17.

3.10

shade ring

cylindrical component having an internal thread or other means to engage a corresponding support on the outer shell and intended to carry or retain a shade

Note 1 to entry: For clarification of some definitions, see also Figure 17.

3.11

dome

part of a cord-grip lampholder or threaded entry lampholder which shields the connecting terminals

Note 1 to entry: For clarification of some definitions, see also Figure 17.

3.12

basic insulation

insulation applied to live parts to provide basic protection against electric shock

Note 1 to entry: Basic insulation does not necessarily include insulation used exclusively for functional purposes.

3.13

supplementary insulation

independent insulation applied in addition to basic insulation in order to provide protection against electric shock in the event of a failure of basic insulation

3.14

double insulation

insulation comprising both basic insulation and supplementary insulation

3.15

reinforced insulation

single insulation system applied to live parts, which provides a degree of protection against electric shock equivalent to double insulation under the conditions specified

Note 1 to entry: The term "insulation system" does not imply that the insulation is one homogeneous piece. It may comprise several layers which cannot be tested singly as supplementary or basic insulation.

3.16

live part

conductive part which may cause an electric shock

3.17

type test

test or series of tests made on a type test sample, for the purpose of checking compliance of the design of a given product with the requirements of the relevant standard

3.18

type test sample

sample consisting of one or more similar specimens submitted by the manufacturer or responsible vendor for the purpose of a type test

3.19

semi-luminaire

unit similar to a self-ballasted lamp but designed to utilize a replaceable light source and/or starting device

3.20

rated operating temperature

highest temperature for which the holder is designed

3.21

rated minimum temperature

lowest temperature for which the holder is designed (applicable only to lampholders intended for use in refrigerators and food freezers)

3.22

angled lampholder

lampholder, the rear side of which (threaded entry and/or dome) is at an angled position to the screw shell axis

3.23

lampholder with retention device

lampholder with a device intended to prevent the lamp from becoming loose in the holder

Note 1 to entry: Lamps can, for example, become loose due to changes in temperature or to vibrations.

3.24

impulse withstand category

numeral defining a transient overvoltage condition

Note 1 to entry: Impulse withstand categories I, II, III and IV are used.

a) Purpose of classification of impulse withstand categories

Impulse withstand categories are to distinguish different degrees of availability of equipment with regard to required expectations on continuity of service and on an acceptable risk of failure.

By selection of impulse withstand levels of equipment insulation, co-ordination can be achieved in the whole installation, reducing the risk of failure to an acceptable level providing a basis for overvoltage control.

A higher characteristic numeral of an impulse withstand category indicates a higher specific impulse withstand of the equipment and offers a wider choice of methods for overvoltage control.

The concept of impulse withstand category is used for equipment energized directly from the mains.

b) Description of impulse withstand categories

Equipment of impulse withstand category I is equipment which is intended to be connected to the fixed electrical installations of buildings. Protective means are taken outside the equipment – either in the fixed installation or between the fixed installation and the equipment – to limit transient overvoltages to the specific level.

Equipment of impulse withstand category II is equipment to be connected to the fixed electrical installations of buildings.

Equipment of impulse withstand category III is equipment which is part of the fixed electrical installations and other equipment where a higher degree of availability is expected.

Equipment of impulse withstand category IV is for use at or in the proximity of the origin of the electrical installations of buildings upstream of the main distribution board.

3.25

primary circuit

circuit which is directly connected to the AC mains supply

Note 1 to entry: It includes, for example, the means for connection to the AC mains supply, the primary windings of transformers, motors and other loading devices.

3.26

secondary circuit

circuit which has no direct connection to a primary circuit and derives its power from a transformer, converter or equivalent isolation device, or from a battery

Note 1 to entry: Exception: autotransformers. Although having direct connection to a primary circuit, the tapped part of them is also deemed to be a secondary circuit in the sense of this definition.

Note 2 to entry: Mains transients in such a circuit are attenuated by the corresponding primary windings. Also inductive ballasts reduce the mains transient voltage height. Therefore, components located after a primary circuit or after an inductive ballast can be suited for an impulse withstand category of one step lower, i.e. for impulse withstand category II.

3.27

adapter

component used for the electrical and mechanical connection of a lamp to a lampholder

Note 1 to entry: This definition is specific for this standard. The definition of an adapter in principle could vary very much depending on its use. In most cases such a component is used to bridge differences in the screw thread diameter between the lampholder and the lamp.

3.28

enclosed reinforced insulated lampholder

lampholder for building-in so designed that on its own it fulfils the requirements for double or reinforced insulated parts in class II applications

3.29

partly reinforced insulated lampholder

lampholder for building-in so designed that some parts of the lampholder require additional means to fulfil the requirements with regard to double or reinforced insulation

Note 1 to entry: In some cases, the dimensions might be achieved only after mounting into the luminaire.

3.30

rated voltage

voltage declared by the manufacturer to indicate the highest working voltage for which the lampholder is intended

[SOURCE: IEC 60838-1:2016, 3.1]

3.31

working voltage

highest r.m.s. voltage that may occur across any insulation, transients being disregarded, both when the lamp is operating under normal conditions and when the lamp is removed

[SOURCE: IEC 60838-1:2016, 3.2]

3.32

rated current

current declared by the manufacturer to indicate the highest current for which the lampholder is intended

[SOURCE: IEC 60838-1:2016, 3.3]

3.33

critical frequency

f_{crit}

frequency at which the reduction of the breakdown voltage of a clearance begins (occurs)

Note 1 to entry: $f_{\text{crit}} \approx 0,2/d$ [MHz] where d (in mm) is the clearance according to Table 3 (basic or supplementary insulation and reinforced insulation respectively) disregarding the frequency.

[SOURCE: IEC 61347-1:2015, 3.40, modified – the note has been added]

3.34

ignition voltage

peak voltage applied to ignite a discharge lamp

[SOURCE: IEC 61347-1:2015, 3.46]

3.34.1

ignition pulse voltage

peak ignition voltage with a total duration of $\leq 750 \mu\text{s}$ (summation of all pulses durations) within 10 ms, with the duration time (width) of each pulse being measured at the level of 50 % of the maximum absolute peak value

Note 1 to entry: Ignition pulse waveforms, which are considered as ignition pulse voltage, should not contain any dominant frequency above 30 kHz or should be usually highly damped (after 20 μs the peak voltage level should be less than one half of the maximum peak voltage). For the assessment of the dominant frequency IEC 60664-4:2005, Annex E should be consulted.

[SOURCE: IEC 61347-1:2015, 3.46.1]

3.35

rated ignition voltage

highest peak value of an ignition pulse voltage the holder is able to withstand

3.36

maximum working voltage

U_{out}

maximum occurring working voltage (r.m.s.) between the output terminals of a controlgear or between the output terminals and earth, during normal or abnormal operating condition

Note 1 to entry: Transients and ignition voltages have to be neglected.

[SOURCE: IEC 61347-1:2015, 3.33, modified – "of a controlgear" has been added]

3.37

maximum working peak output voltage

$\hat{U}_{\text{out}}$

maximum repetitive occurring peak working voltage between the output terminals of a controlgear or between its output terminals and earth, during normal or abnormal operating condition and with transients neglected

[SOURCE: IEC 61347-1:2015, 3.45, modified – "of a controlgear" has been added]

3.38 equivalent transformed peak voltage

U_p
transformed output peak voltage, which is converted for the worst case peak voltage with its related frequency into an ignition pulse voltage

Note 1 to entry: The value of the declared equivalent transformed output peak voltage is the essential parameter for selecting the associated components.

Note 2 to entry: See 3.34.1.

Note 3 to entry: To determine the declared equivalent transformed output peak voltage for basic insulation U_p [basic] the worst case combination of the maximum occurring peak voltage and frequency has to be taken into account, which means the maximum clearance according to IEC 61347-1:2015, Table 10 for basic insulation.

Note 4 to entry: To determine the declared equivalent transformed output peak voltage for the reinforced insulation U_p [reinforced] the worst case combination of the maximum occurring peak voltage and frequency has to be taken into account, which means the maximum clearance according to IEC 61347-1:2015, Table 11 for reinforced insulation.

[SOURCE: IEC 61347-1:2015, 3.47]

4 General requirement

Lampholders shall be so designed and constructed that in normal use they function reliably and cause no danger to persons or surroundings.

In general, compliance is checked by carrying out all the tests specified.

In addition, the enclosure of independent lampholders shall comply with the requirements of IEC 60598-1, including the classification and marking requirements of that standard.

5 General conditions for tests

5.1 Tests according to this standard are type tests.

NOTE The requirements and tolerances permitted by this standard are related to testing of a type test sample submitted for that purpose.

Compliance of the type test sample does not ensure compliance of the whole production of a manufacturer with this safety standard.

In addition to type testing, conformity of production is the responsibility of the manufacturer and can include routine tests and quality assurance.

For further information on conformity testing during manufacture see IEC 60061-4.

5.2 Unless otherwise specified, the tests are made at an ambient temperature of $20\text{ °C} \pm 5\text{ °C}$ and with the holder tested as delivered and installed as in normal use.

5.3 The tests and inspections are carried out on a total of

- nine specimens for non-switched lampholders, or
- 12 specimens for switched lampholders

in the following order of clauses:

- three specimens: Clauses 2 to 13 (except for 10.1 and 11.2) and Clauses 15 to 18;
- three specimens: Clause 14 (switched-lampholder tests only);
- three specimens: 10.1 and Clauses 19 and 20;

- two specimens: Clause 21 (of which one specimen for the test of 21.1 and the other for the tests of 21.3 or 21.4);
- one specimen: 21.5 and Clause 22.

For testing lampholders with a retention device, the retention device shall be removed.

For testing lampholders with a retention device according to 13.14, three additional specimens are required with the retention device kept in place.

For testing of screwless terminals according to 11.2, separate specimens are required in addition.

5.4 *In case of doubt, gauges, test caps and mandrels are introduced into the specimens, unless otherwise specified, by applying the following torques:*

- 0,2 Nm for lampholders E5;
- 0,2 Nm for lampholders E10;
- 0,2 Nm for lampholders E14;
- 0,4 Nm for lampholders E27;
- 0,8 Nm for lampholders E40.

5.5 *For lampholders E40 with a rated current of 32 A, the tests shall be based on this rated current.*

5.6 *Lampholders are deemed to comply with this standard if no specimen fails in the complete series of tests specified in 5.3.*

If one specimen fails in one test, that test and the preceding ones which may have influenced the result of that test are repeated on another set of specimens to the number required by 5.3, all of which shall then comply with the repeated tests and with the subsequent tests. Lampholders are deemed not to comply with this standard if there are more failures than one.

6 Standard ratings

6.1 Standard rated voltages are 250 V and 500 V.

For lampholders E14, and for switched lampholders E27, a rated voltage of 250 V only is allowed.

For lampholders E5 and E10 intended for the connection of series-connected lamps to the supply, the rated voltage shall not exceed 25 V for lampholders E5 and not exceed 60 V for lampholders E10.

NOTE 1 These values refer to the voltage between parts of different polarity.

For lampholders E10 intended for the connection of single lamps to the supply, a rated voltage of 250 V only is allowed.

NOTE 2 These lampholders are also used for such special cases as series-connected lamps, where, because of the low number of lamps, 60 V per lampholder is exceeded.

With the exception given for lampholders E5 and E10, the rated voltage shall be not less than 250 V. Additionally a rated voltage of 125 V is allowed for lampholders E40.

Compliance is checked by inspection of the marking.

6.2 Standard rated currents are

- 0,2 A for lampholders E5;
- 0,5 A for lampholders E10;
- 2 A for lampholders E14;
- 2 A for switched-lampholders E27;
- 4 A for other lampholders E27;
- 16 A for lampholders E40.

The rated current shall be not less than the standard value.

Compliance is checked by inspection of the marking.

6.3 Lampholders E40 to be used on 125 V installations may have an additional nominal rating of 32 A.

NOTE This nominal rating covers the voltages up to and including 130 V.

Compliance is checked by inspection of the marking.

6.4 The rated operating temperature for lampholders intended for use in high temperature conditions (T marked holders) shall be not lower than 140 °C for lampholders E14, not lower than 170 °C for lampholders E27 and not lower than 230 °C for lampholders E40.

Compliance is checked by inspection of the marking.

NOTE The rated operating temperatures for Edison screw lampholders without T marking are given in IEC 60598-1, Table 12.1. They are

- 135 °C for lampholders E14;
- 165 °C for lampholders E27;
- 225 °C for lampholders E40.

7 Classification

Lampholders are classified as defined in 7.1 to 7.6.

7.1 According to the material of the external parts:

- lampholders of insulating material;
- metal lampholders.

NOTE Lampholders with external parts consisting partly of metal and lampholders comprising external parts of insulating material with a conductive outer surface, for example a metallized outer shell, are considered as metal lampholders (see 13.3). This does not apply to threaded entries and external parts, for example a metal shade ring mounted onto the outside of a lampholder of insulating material, which cannot become live even in the case of an insulation fault. Metal holders with insulating coverings are considered as metal lampholders (see 10.5).

In order to check whether or not a surface is conductive, two stripe-electrodes 1,5 mm wide, 25 mm long and with a distance of 2 mm from each other are applied to the surface (e.g. with silver conductive paint). In accordance with 15.4, the insulating resistance is measured between the stripes. The surface is considered to be conductive if the resistance is less than 5 MΩ.

7.2 According to degree of protection against ingress of water:

- ordinary lampholders;

- drip-proof lampholders.

7.3 According to method of fixing:

- threaded entry lampholders;
- cord-grip lampholders;
- backplate lampholders;
- other lampholders.

NOTE Examples of other lampholders are lampholders provided with a mechanical suspension device, e.g. a hook.

7.4 According to type:

- switched-lampholders, provided with an integral switch to control the supply to the lamp;
- non-switched lampholders.

7.5 According to protection against electric shock:

- unenclosed lampholders;
- enclosed lampholders;
- independent lampholders;
- partly reinforced insulated lampholders;
- enclosed reinforced insulated lampholders.

NOTE Where a lampholder is used with a working voltage of 50 % or less of its maximum rating, it can be regarded as equivalent to a reinforced insulated lampholder.

7.6 According to resistance to heat:

- lampholders for rated operating temperatures up to the limits given in 6.4;
- lampholders for operating in high temperature conditions (T marked holders).

8 Marking

8.1 Lampholders, other than lampholders E5 and E10, shall be marked with the following:

- rated current, in amperes;
- rated voltage, in volts, ~~and~~
- rated ~~pulse~~ ignition voltage, in kV, if higher than
 - 2,5 kV for lampholders rated 250 V,
 - 4 kV for lampholders rated 500 V;

If applicable, the rated ~~pulse~~ ignition voltage of the lampholder (in kV) ~~should~~ shall be marked either on the lampholder or made available in the manufacturer's catalogue or the like.

NOTE 1 Some lampholders still show rated voltages higher than 500 V. This is an earlier way of expressing the permissible ~~pulse~~ ignition voltage via a rated voltage. For such lampholders, the creepage distances and clearances can be found in IEC 60598-1.

- symbol for nature of current, if required (for switched lampholders only);
- mark of origin (this may take the form of a trade mark, manufacturer's identification mark or the name of the responsible vendor);
- type reference;

Available technical documentation of the manufacturer like printed catalogues or online catalogues should allow a clear identification of a lampholder either by a unique catalogue number or by an identifying reference on the holder, specifying the essential characteristic

features and the basic design of the product supplemented by a clear description. Variations of the basic design like for example different cable length, fixing means, colours etc., which do not affect safety or performance of the lampholder, can be disregarded in the type reference marked on the product. Variations included in the type testing procedure are listed in the corresponding test reports.

- the degree of protection against ingress of water for drip-proof lampholders (see 8.2);
- rated operating temperature "T", indicating the highest operating temperature, if applicable.

The marking of the rated operating temperature is not required for lampholders whose exterior is made wholly of ceramic material. For these lampholders, this information, if applicable, shall either be marked on the lampholder or be made available in the manufacturer's catalogue.

For lampholders according to this standard, the distances for impulse withstand category II are usually applicable. For holders in equipment where a higher degree of availability is expected, distances for impulse withstand category III may be applicable. This information shall be indicated in the manufacturer's catalogue or the like.

Enclosed reinforced insulated lampholders offer an adequate level of protection for use in luminaires where they are accessible in normal use. This information shall be indicated in the manufacturer's catalogue or the like.

For partly reinforced insulated lampholders, sufficient creepage distances and clearances to outer accessible surfaces will require additional protection to some parts of the lampholder by the luminaire design or by use of additional attachment(s) or cover(s). This information shall be indicated in the manufacturer's catalogue or the like.

Lampholders E10 shall be marked with the following:

- rated voltage, in volts;
- mark of origin;
- type reference;

Available technical documentation of the manufacturer like printed catalogues or online catalogues should allow a clear identification of a lampholder either by a unique catalogue number or by an identifying reference on the holder, specifying the essential characteristic features and the basic design of the product supplemented by a clear description. Variations of the basic design like for example different cable length, fixing means, colours etc., which do not affect safety or performance of the lampholder, can be disregarded in the type reference marked on the product. Variations included in the type testing procedure are listed in the corresponding test reports.

- the degree of protection against ingress of water, if applicable.

Lampholders E5 shall be marked with the following:

- mark of origin;
- type reference.

Available technical documentation of the manufacturer like printed catalogues or online catalogues should allow a clear identification of a lampholder either by a unique catalogue number or by an identifying reference on the holder, specifying the essential characteristic features and the basic design of the product supplemented by a clear description. Variations of the basic design like for example different cable length, fixing means, colours etc., which do not affect safety or performance of the lampholder, can be disregarded in the type reference marked on the product. Variations included in the type testing procedure are listed in the corresponding test reports.

Compliance is checked by inspection.

NOTE 2 The type reference for lampholders E10 and E5 can be a catalogue number.

8.2 If symbols are used for current and voltage, A shall denote amperes and V volts.

Alternatively, for volt and ampere ratings, figures may be used alone, the figure for the rated current being marked before or above that for the rated voltage and separated from the latter by an oblique stroke or line.

Therefore the marking of current and voltage may be as follows:

2 A 250 V or 2/250 or $\frac{2}{250}$.

The symbol for direct current shall be — — — (IEC 60417-5031:2002-10).

The symbol for protection against ingress of water for drip-proof lampholders shall be IPX1.

NOTE Where X is used in the IP number it indicates a missing numeral in the example, but both the appropriate numerals in accordance with IEC 60529 are marked.

The letter T shall be followed by the value of the rated operating temperature in degrees Celsius.

Compliance is checked by inspection.

8.3 The marking of the degree of protection against ingress of water shall be on the outside of the holder.

Compliance is checked by inspection.

8.4 An earthing terminal shall be indicated by the symbol — — — (IEC 60417-5019:2002-10).

This symbol shall not be placed on screws, removable washers or other easily removable parts.

Compliance is checked by inspection.

8.5 Marking shall be durable and easily legible.

Compliance is checked by inspection and, after the tests of Clause 19 have been completed, by trying to remove the marking by rubbing lightly for 15 s with a piece of cloth soaked with water and for a further 15 s with a piece of cloth soaked with petroleum spirit.

After the tests the marking shall be still legible.

NOTE The petroleum spirit used typically consists of a solvent hexane with a content of aromatics of maximum 0,1 volume percentage, a kauri-butanol value of 29, an initial boiling-point of approximately 65 °C, a dry-point of approximately 69 °C and a specific density of approximately 0,68 g/cm³.

9 Dimensions

9.1 Lampholders E10, E14, E27 and E40 shall comply with the current edition of the standard sheets of the IEC 60061 series.

Compliance shall be checked by measuring in conformity with IEC 60061-2, Standard Sheet 7005-20.

The minimum dimensions of the screw thread and dimension X shall be checked by means of gauges according to Standard Sheets 7006-25 (E10, E14 and E40) and 7006-25A (E27), and by means of the gauge according to Standard Sheet 7006-26 of IEC 60061-3.

Lampholders designed with a barrel thread for shade holder rings and shade holder rings shall comply with IEC 60399.

Compliance is checked by means of the gauges given in IEC 60399.

9.2 Lampholders shall allow insertion of all corresponding lamps so as to make contact.

Compliance is checked by means of gauges according to the current edition of the following standard sheets of IEC 60061-3 and according to the indications of these sheets:

- *lampholders E14: 7006-30 and 7006-31;*
- *candle lampholders E14: 7006-30A and 7006-31;*
- *lampholders E27: 7006-21 and 7006-22A;*
- *lampholders E40: 7006-23 and 7006-24.*

Pending gauges for lampholders E5 and E10, the contact-making is checked by means of the corresponding lamps. It is presumed that the manufacturer of the lampholder for the purpose of the test delivers the lamps for which the lampholder is intended.

The checking of contact-making is done on lampholders as delivered and after the tests of Clauses 19 and 20.2.

For lampholders for use in appliances other than luminaires only:

If the fixing means of lampholders are integrated parts of the rim and the lampholder is designed for use with a selected standardized lamp only, parts of the lampholder rim could interfere with the relevant contact-making gauge. In this case, compliance with the requirements for maximum lamp outlines according to IEC 60630 for the lamp indicated in the lampholder manufacturer's instructions shall be checked. Following this checking, the contact-making gauge shall be applied after those parts of the lampholder interfering with the gauge have been removed.

For testing such lampholders, two additional specimens specially prepared to accept the relevant contact-making gauge are required.

9.3 The following dimensions shall be not less than the values shown in Table 1.

Table 1 – Thickness of screw shells and contacts

Dimension	Lampholder				
	E5	E10	E14	E27	E40
Thickness of the screw shell, if any (mm):					
– when the shell is unsupported	0,20	0,20	0,30	0,30	0,50
– when the shell is supported by insulating material over a total distance of at least three-quarters of the circumference of the shell	0,15	0,15	0,25	0,25	0,40
Thickness of side or central contacts, if resilient (mm)	0,18	0,18	0,28	0,38	0,48 ^a
^a For the use of side-contacts in lampholders E40, see 13.11.					

Compliance is checked by measurement.

NOTE 1 Thicknesses are measured by means of a micrometer with pointed noses and ratchet screw.

For the screw shell, two sets of three measurements are made, each set carried out on one of two different generating lines of the screw shell. The mean value of the six measurements shall be at least equal to the specified value.

NOTE 2 The deletion of dimensional requirements is under consideration.

9.4 The effective length of screw engagement, if any, of outer shell and dome shall meet one of the following requirements whereby the engagement shall always be over one full turn.

Either the effective length shall be not less than the values shown in Table 2, or the effective length shall be at least two turns provided the test according to 16.3 is withstood with a torque equal to 1,2 times the torque given in 16.2.

Table 2 – Minimum effective screw lengths

Dimension	Lampholder		
	E14	E27	E40
Minimum effective screw length (mm):			
– Metal lampholders for rolled thread	5,0	7,0	10,0
– Metal lampholders for cut thread	5,0	5,0	7,0
– Lampholders of insulating material	5,0	7,0	10,0

These requirements do not apply to lampholders E5 and E10.

Compliance is checked by measurement.

9.5 The threaded entries of lampholders shall be provided with one of the following screw threads:

- lampholders E14: M10×1;
- lampholders E27: M10×1, M13×1 or M16×1;
- lampholders E40: M13×1, M16×1 (or G3/8A).

NOTE 1 The size between brackets is non-preferred; in addition, the threaded entry M10 is mainly intended for internal wiring of luminaires.

NOTE 2 In France, threaded entry lampholders with 11 mm × 19 TPI and 17 mm × 19 TPI (turns per inch) screw threads are permitted for replacement.

The thread of the entry shall comply with Figure 1a or Figure 1b.

These requirements do not apply to lampholders E5 and E10.

Compliance is checked by measurement and by means of gauges according to Figure 2a or Figure 2b.

In case of doubt, the gauge is introduced into the entry by applying a torque of 0,5 Nm.

9.6 The dimensions of threaded entries and set screws, if any, shall be not less than the values shown in Table 3.

Table 3 – Dimensions of threaded entries and set screws

Dimensions in millimetres

Dimension	Nominal thread diameter	
	M10×1 M13×1	M16×1 G3/8A
Length of the thread:		
– metal entry	3	8
– entry of insulating material	5	10
Diameter of set-screw:		
– screw with head	2,5	3,0
– screw without head:		
– in case of one screw	3,0	4,0
– in case of more than one screw	3,0	3,0

A negative deviation of 0,15 mm from the nominal values for thread diameter is allowed.

Compliance is checked by measurement.

These requirements do not apply to lampholders E5 and E10.

NOTE If it is necessary to take the lampholder apart in order to check compliance with the requirements under 9.3 to 9.6, such checking is done after the test of Clause 18.

9.7 Lampholders shall be so designed that they do not interfere with the proper engagement or disengagement of lamps, even if the lamp cap is slightly dented. In no case shall the holder contacts present a cutting edge to the lamp cap.

Compliance is checked by the following test:

For lampholders E27, compliance shall be checked by means of a gauge according to the current edition of Standard Sheet 7006-22B of IEC 60061-3.

For lampholders other than E27, compliance shall be checked by inspection.

10 Protection against electric shock

10.1 Lampholders E5, E10, E14 and E27 shall be so designed that the lamp caps are not accessible when they become live during insertion.

NOTE 1 Details for checking compliance regarding protection against accidental contact with live parts during insertion for lampholders E5 and E10 are under consideration. Because of this, lampholders E10 with a rated voltage exceeding 60 V are for sale to luminaire or other equipment manufacturers only.

For lampholders E10 with a rated voltage exceeding 60 V, the protection against electric shock can be provided by measures taken in the luminaire or equipment where the lampholders are used.

Lampholders E40 shall be so designed that the lamp cap is not accessible when fully inserted.

Candle lampholders are tested without decorative cover, unless this cover cannot be removed without making the lampholders obviously useless.

Compliance is checked as follows:

- for lampholders E10, by means of corresponding lamps and the standard test finger, shown in Figure 16. For the purpose of the test, the lampholder manufacturer shall provide the lamps for which the lampholder is intended;

- for lampholders E14, E27 and E40, by means of gauges according to the current edition of the following standard sheets of IEC 60061-3:
 - 7006-31 for lampholders E14;
 - 7006-22A for lampholders E27;
 - 7006-24 for lampholders E40.

NOTE 2 In order to ensure protection against electric shock during insertion on unused lampholders, the tests according to 10.1 are made on new specimens.

10.2 The external parts of enclosed and independent lampholders shall be so designed that live parts of the lampholder ready for use and with a corresponding normal lamp inserted are not accessible.

Candle lampholders are tested without decorative cover, unless this cover cannot be removed without making the lampholder obviously useless.

Compliance is checked by means of the standard test finger.

For the purpose of the test:

- enclosed lampholders are mounted as in normal use, for example on a threaded support, or the like, if appropriate, and provided with the most unfavourable conductor size fitted for which the lampholders are intended;
- independent lampholders shall be mounted as in normal use on an appropriate plane surface.

The standard test finger shown in Figure 16 is applied in every possible position with a force of 10 N, an electrical indicator being used to show contact with live parts.

It is recommended that a voltage of not less than 40 V be used.

NOTE Unenclosed lampholders are only tested after appropriate installation in a luminaire or other additional enclosure.

For E5 and E10 lampholders with a separate insert part mounted in an outer sleeve, the insert part shall be subjected to a pull force of 60 N for 1 min in the axial direction.

The test shall be performed by hand in order to simulate any axial misalignment as normally occurs in practice. The axial misalignment movement performed during the test should be up to 10° in any direction.

During this test, the insert part shall not become loose to such an extent that live parts become accessible with the standard test finger.

10.3 Parts providing protection against accidental contact with the lamp cap shall be reliably secured so that they will not become detached when a tightly fitting lamp is removed, or when rotating the shade, if applicable.

Compliance is checked by the following test:

The coupling between dome and outer shell is tightened initially with a torque equal to two-thirds of the torque test value specified below. The relevant parts are then subjected to a torque during 1 min in an anticlockwise direction with the following test values:

- 1 Nm for lampholders E14;
- 2 Nm for lampholders E27.

The lampholder is mounted as in normal use and is tested first with and then without the appropriate test cap according to Figure 13 (test cap B) or Figure 14.

After the test, the parts providing protection against accidental contact with the lamp cap shall not have become dismantled.

It shall not be possible to dismantle lampholders E5 and E10 without the aid of a tool.

Requirements for lampholders E40 (see Figure 15) are under consideration.

10.4 Where provision is made for attaching a shade to the lampholder, it is fitted to the lampholder by separate means, such as a shade ring; it is not permitted to fix a shade between parts providing protection against electric shock.

Compliance is checked by inspection.

10.5 The external parts of

- drip-proof lampholders,
- lampholders with a rated voltage of more than 250 V,
- switched-lampholders, and
- lampholders E5 and E10

shall be of insulating material, with the exception of threaded entries and of those parts which cannot become live even in the event of a fault.

Lacquer or enamel is not deemed to provide adequate protection for the purpose of Clause 10.

Compliance is checked by inspection.

NOTE 1 Parts which are separated from live parts by double or reinforced insulation are considered as parts which cannot become live in the event of a fault.

NOTE 2 An example of an external part which cannot become live, even in the event of a fault, is a metal shade ring mounted on the outside of an insulated lampholder.

Switched-lampholders with external metal parts are permitted under the conditions of 13.3.

11 Terminals

11.1 Lampholders, other than those provided with connecting leads (tails), shall be provided with terminals which allow connection of conductors having the following nominal cross-sectional areas:

- 0,5 mm² to 0,75 mm² for lampholders E10;
- 0,5 mm² to 1,0 mm² for lampholders E14 and E27 with M10×1 threaded entry;
- 0,5 mm² to 2,5 mm² for other lampholders E27;
- 1,5 mm² to 4 mm² for lampholders E40 with a rated current of 16 A;
- 2,5 mm² to 6 mm² for lampholders E40 with a rated current of 32 A.

Compliance is checked by inspection and by fitting conductors of the smallest and largest cross-sectional area specified. For cord-grip lampholders, lampholders E10, E14 and lampholders E27 with M10×1 threaded entry, stranded conductors are used; in all other cases the conductors are of the solid type.

Threaded entry lampholders are tested in a screwed conduit.

Lampholders E27 with screwless terminals intended for use by luminaire or equipment manufacturers only need not fulfil the requirements for all the appropriate nominal cross-sectional areas.

11.2 Connections

11.2.1 Lampholders shall be provided with at least one of the following means of connection:

- screw type terminals;
- screwless terminals;
- tabs or pins for push-on connections;
- posts for wire wrapping;
- soldering lugs;
- connecting leads (tails).

Terminal screws and nuts shall have a metric ISO thread or a thread comparable in pitch and mechanical strength.

Conductors may be connected to E5, E10 and similar small lampholders by soldering, welding, crimping or other equally effective means.

Lampholders with screwless terminals, unless intended for sale to luminaire or equipment manufacturers, shall be provided with terminals which are equally satisfactory with both rigid (solid or stranded) conductors and flexible cables or cords.

Compliance is checked by the tests of 11.2.2.

11.2.2 Terminals shall comply with the following requirements, with the restriction that the requirements referring to internal wiring relate to wiring inside independent holders and to wiring inside luminaires for holders for building-in.

All terminal tests shall be made on separate specimens which have not been subjected to any other test:

- *terminals with screw clamping shall comply with the requirements specified in 11.3 to 11.6 inclusive, and 11.8;*
- *screwless terminals shall comply with Clause 15 of IEC 60598-1, provided that the heating test is carried out at the rated operating temperature of the lampholder ± 5 °C;*
- *tabs or pins for push-on connections shall comply with Clause 15 of IEC 60598-1;*
- *posts for wire wrapping shall comply with IEC 60352-1. Wire wrapping applies only to single solid round wire for internal wiring;*
- *soldering lugs shall comply with the requirements for good solderability. Suitable requirements can be found in IEC 60068-2-20;*
- *connecting leads (tails) shall comply with the requirements specified in 11.10.*

11.3 Terminals shall be fixed in such a way that they will not work loose when fastening or loosening the conductors.

For screw terminals, compliance is checked by inspection and by fastening and loosening a conductor of the largest cross-sectional area specified in 11.1 10 times, the applied torque being two-thirds of the torque specified in Clause 14 of IEC 60598-1.

NOTE Terminals can be prevented from working loose by fixing with one screw in a recess without appreciable play, or by other suitable means. Covering with sealing compound without other means of locking is not deemed to be sufficient.

11.4 Screw terminals shall be so designed that they clamp the conductor between metal surfaces with sufficient contact pressure and without damage to the conductor. Terminals shall be so designed that they will prevent a conductor slipping out when the screws or nuts are tightened. They shall allow a conductor to be connected without special preparation (e.g. soldering of the strands of the conductor, use of cable lugs, formation of eyelets, etc.).

Compliance is checked by inspection of the conductors after fitting according to 11.1 and after the test of 20.3.

NOTE The conductors are considered to be damaged if they show deep or sharp indentations.

11.5 Terminals of the pillar type shall have dimensions not less than those shown in Table 4.

Table 4 – Minimum dimensions of pillar-type terminals

Lampholder	Nominal thread diameter mm	Diameter of hole for conductor mm	Length of thread in pillar mm
E10	2,5	2,5	1,8
E14	2,5	2,5	1,8
E27	2,5	2,5	1,8
E40	3,5	3,5	2,5
The diameter of the hole shall be not more than 0,6 mm larger than the diameter of the screw.			

The length of the threaded part of the terminal screw shall be not less than the sum of the diameter of the hole for the conductor and the length of thread in the pillar.

NOTE The length of the thread of the pillar is measured to the point where the thread is broken by the pillar hole.

Compliance is checked by measurement.

11.6 Screw terminals shall have dimensions not less than those shown in Table 5.

Table 5 – Minimum dimensions of screw-type terminals

Lampholder	Nominal thread diameter mm	Length of thread under the head mm	Length of thread in nut mm	Nominal difference between diameter of head and shank of screw mm	Height of head mm
E10	2,5	4,0	1,5	2,5	1,4
E14	3,0	5,0	1,5	3,0	1,8
E27	3,5	5,0	1,5	3,5	2,0
E40	4,0	6,0	2,5	4,0	2,4

If an intermediate part locked against rotation, such as a washer or a pressure plate, is used between the head of the screw and the conductor, the difference in diameter between head and shank of the screw may be reduced by 1 mm.

Compliance is checked by measurement.

A negative deviation of 0,15 mm from the nominal values of the thread diameter and of the difference in diameter of head and shank is allowed.

NOTE If it is necessary to take the lampholder apart in order to check compliance with the requirements under 11.5 and 11.6, such checking is done after the test of Clause 18.

11.7 Terminals shall be so located that, after correct fitting of the wires, there is no risk of accidental contact between live parts and accessible metal parts.

Compliance is checked by inspection and by the following test:

The insulation is removed over a length of 4 mm from the end of a flexible conductor having the minimum nominal cross-sectional area specified in 11.1. One wire of the stranded conductor is left free and the remainder are fully inserted into and clamped in the terminal of the lampholder, mounted and installed as in normal use (locking screws tightened, etc.).

The free wire is bent without tearing the insulation back, in every possible direction, but without making sharp bends around barriers.

The free wire of a conductor connected to a live terminal shall not touch any metal part which is not a live part, and that of a conductor connected to the earthing terminal shall not touch any live part.

If necessary, the test is repeated with the free wire in another position.

NOTE The prohibition against making sharp bends around barriers does not imply that the free wire is kept straight during the test. Sharp bends are, moreover, made if it is considered likely that such bends can occur during the normal assembly of the lampholder. See also 13.3.

11.8 Pillar terminals in which the end of the conductor is not visible shall have a length of hole beyond the terminal screw at least equal to half the value of the diameter of the screw or 2,5 mm, whichever is the higher.

Compliance is checked by measurement.

11.9 Terminals which are floating shall show no appreciable lateral play and shall not move longitudinally more than 3 mm when a lamp is removed or inserted.

Compliance is checked by measurement.

11.10 The requirements of 11.2 to 11.6 inclusive and of 11.8 do not apply to lampholders intended to be factory-mounted in luminaires and which are provided with connecting leads (tails).

Lampholders intended to be factory-mounted in luminaires or built into equipment may be provided with connecting leads (tails), tab-terminals or equally effective means.

Connecting leads (tails) shall be connected to the lampholders by soldering, welding, crimping or by any other at least equivalent method.

Leads shall consist of insulated conductors.

Insulation of the free end of the leads may be stripped.

Fixing of the leads to the lampholders shall withstand the mechanical forces that may occur in normal use.

Compliance is checked by inspection and by the following test, which is made after the test of 20.2 on the same three specimens.

Each connecting lead is subjected to a pull of 20 N, the pull is applied without jerks for 1 min in the most unfavourable direction.

During the test leads shall not move from their fixing.

After the test, the lampholders shall show no damage within the meaning of this standard.

12 Provision for earthing

12.1 Threaded entry lampholders, cord-grip lampholders and backplate lampholders, with provisions for earthing, other than those provided with connecting leads, shall have at least one internal earthing terminal; other lampholders without threaded entry, for example, lampholders for building-in, may be provided with an external earthing terminal.

Compliance is checked by inspection.

NOTE Lampholders intended to be earthed but not provided with an earthing terminal or with connecting leads are not for retail sale.

12.2 Accessible metal parts of lampholders without earthing terminal, which may become live in the event of an insulation fault, shall allow reliable earthing.

There shall be earth continuity between a metal dome and the outer shell, if of metal, when the shell is not separated from live parts by double or reinforced insulation.

NOTE For the purpose of this requirement, small isolated metal screws and the like for fixing bases or covers are not deemed to be accessible parts which can become live in the event of an insulation fault.

Compliance is checked by the following test:

A rigid conductor having the smallest cross-sectional area for which the holder is intended is fitted to the earthing terminal, if provided.

When earth continuity between the dome and the outer shell also has to be checked, the coupling between these parts shall be tightened with the torque specified:

- 1 Nm for lampholders E14;
- 2 Nm for lampholders E27;
- 4 Nm for lampholders E40.

Immediately after the tests of 15.3, the resistance between the means of earthing and the dome (or the outer shell as appropriate) is measured.

For lampholders with an earthing terminal, the means of earthing is the point where the conductor leaves the terminal and for lampholders without an earthing terminal, it is the point where the earthing connection is intended to be made.

A current of at least 10 A, derived from a source with a no-load voltage not exceeding 12 V, shall be passed between the earthing terminal or earthing contact and each of the accessible metal parts in turn.

The voltage drop between the means of earthing and accessible metal part shall be measured. The resistance, calculated from the voltage drop and the current, shall not exceed 0,1 Ω .

12.3 Earthing terminals shall comply with the requirements of Clause 11.

Their clamping means shall be adequately locked against accidental loosening, and it shall not be possible to loosen screw terminals by hand and screwless terminals unintentionally by hand.

Compliance is checked by inspection and by the tests of Clause 11.

NOTE In general, the designs commonly used for current-carrying terminals (complying with the requirements of this standard) provide sufficient resilience to comply with the latter requirement; for other designs special provisions, such as the use of an adequate resilient part which is not likely to be removed inadvertently, may be necessary.

12.4 The metal of earthing terminals shall be such that there is no risk of corrosion resulting from contact with the copper of the earthing conductor.

The screw or the body of the earthing terminal shall be of brass or other metal no less resistant to corrosion, and the contact surfaces shall be bare metal.

Compliance is checked by inspection.

NOTE The risk of corrosion is particularly great when copper is in contact with aluminium.

12.5 Metal parts of the cord anchorage, including clamping screws, shall be insulated from the earthing circuit.

Compliance is checked by inspection.

13 Construction

13.1 Lampholders shall be provided with a screw thread of Edison form for holding the lamp.

For lampholders other than E5 and E10, this thread shall be either of metal and shall be continuous over a length not less than that specified in the current edition of standard sheet 7005-20 of IEC 60061-2, or comply with the following requirements.

NOTE The requirement for a minimum length of screw thread for lampholders E5 and E10 is under consideration.

Deviation from the requirements for a metal thread is allowed provided the design and production tolerances are such that proper engagement with all gauges is ensured throughout the life of the holder delivered. On this subject, further information will be available in the annex: Surveillance tests, under consideration.

In addition, the terminal/contact assembly and the screw shell shall be so constructed and located as to prevent canting or rotation which would impair the use of the lampholder.

Deviation from the requirement for a continuous thread is allowed if this is necessary to provide a special technical advantage, such as the inclusion of a lamp retention device in a cut-away.

Compliance is checked by inspection and by a manual test with the relevant gauges, referred to in Clause 8, applied in all positions which can be achieved with reasonable force, and the holder shall still comply with the gauges, especially the feeler gauge of 0,08 mm × 5,0 mm.

Furthermore, it shall not be possible to score the neck of the bulb of a lamp made to normal standards during engagement and disengagement.

The male screw thread of an adapter shall be of the same size or larger than the female screw thread shell of the adapter.

13.2 There shall be adequate space for the supply wires in the dome of the lampholder. Parts of the lampholder with which insulated conductors may come into contact shall have no sharp edges or a shape likely to damage the insulation.

Threaded entry lampholders shall be provided with means to prevent the conduit entering too far into the entry, unless it is evident from the design that the conduit is unlikely to enter too far into the entry, for example in certain candle lampholders.

Compliance is checked by inspection and by fitting flexible cables or cords of the largest cross-sectional area according to 11.1 for lampholders E14 and lampholders E27 with M10×1 threaded entries, with conductors with a nominal cross-sectional area one size less than specified for other lampholders E27 and lampholders E40.

For cord-grip lampholders, lampholders E14 and lampholders E27 with M10×1 threaded entries, an ordinary sheathed flexible cord is used; in all other cases, two or three PVC insulated single-core cables are used.

For threaded entry lampholders, the dome of the lampholder is screwed onto a conduit having a length of about 10 cm. The cables are then introduced into the conduit and dome. The ends of the cables, after having been prepared in the usual manner, are connected to the terminals of the lampholder. If possible, the connection is made with the part carrying the terminals in a position where the shortest distance between the plane of the upper edge of the dome and the nearest part of the terminals is 10 mm. With the terminals held in this position, the cables are tightened and clamped at the free end of the conduit. After this, the lampholder is assembled.

After dismantling, the cables and cords shall not be damaged.

NOTE 1 For lampholders E27 and E40, a test with conductors with maximum cross-sectional area according to 11.1 is under consideration.

NOTE 2 The requirement concerning sharp edges is not meant for the outer end of the threaded entry, since they are not in contact with the wires when the lampholder is mounted on a conduit.

In case of doubt with regard to the means to prevent the conduit entering too far into the entry of a threaded entry lampholder, the lampholder is screwed onto a steel conduit or mandrel having squared ends (edges left sharp). The conduit or the mandrel is provided with a full thread having the minimum dimensions shown in Figure 1a or Figure 1b.

During this test, the following torque is applied for 1 min:

- 1,0 Nm for threaded entries M10×1;
- 1,3 Nm for threaded entries M13×1;
- 1,6 Nm for threaded entries M16×1 and G3/8A.

After this test, the conduit or the mandrel shall not have entered into the space provided for the supply wires in the dome of the lampholder, and the lampholder shall not show any change impairing its further use.

13.3 Accessible parts of switched lampholders shall be of insulating material unless the design is such that a live wire detached from its terminal cannot touch accessible metal parts or parts of the earthing circuit and that terminal screws or screws in threaded entries which have become loose cannot bridge accessible metal parts, including earthing terminals, and live parts.

Compliance is checked by inspection.

NOTE This requirement does not necessarily imply either complete or partial insulating lining.

13.4 In case of lampholders with metal screw shell and metal outer shell, contact between these parts shall be prevented by an insulating ring which shall not be separable from the live parts or the metal outer shell by hand.

Compliance is checked by inspection.

NOTE The protection by the insulating ring is considered sufficient if its length is approximately equal to that of the screw shell.

13.5 It shall be possible to lock the threaded entry on the conduit. Locking devices can either be part of the lampholder or be provided by the design of a luminaire.

Except for angled lampholders, it shall be possible to operate the locking device from the inside, if provided as part of the lampholder.

If a locking device is provided by the design of a luminaire, its efficiency cannot be checked when testing the lampholder; such a check shall be made during testing of the luminaire.

NOTE Such lampholders are not intended for retail sale.

This requirement does not apply to lampholders E5 and E10.

Compliance is checked by inspection and, for lampholders having an integral locking device, by the test of 16.4.

13.6 Cord-grip lampholders and all lampholders designed for chain connection shall be provided with a device allowing the lampholder to be so fixed to a flexible cord that the conductors are relieved from strain, including twisting, where they are connected to the terminals, and that the outer covering of the cord is gripped in the lampholder and is protected from abrasion. It shall be clear how the relief from strain and the prevention of twisting is intended to be effected.

It shall not be possible to push the cord into the lampholder to such an extent that the cord is subjected to undue mechanical or thermal stress.

Makeshift precautions, such as tying the cord into a knot or tying the end with string, are not permissible.

The device shall be of insulating material or be provided with a fixed insulating lining if otherwise an insulation fault on the cord could make accessible metal parts live.

The design shall be such that the device:

- is at least one part fixed to or integral with the lampholder;
- is suitable for the different types of flexible cord which may be connected to the lampholder;
- does not exert excessive pressure on the cord;
- is unlikely to be damaged when it is tightened or loosened as in normal use.

The device shall be suitable for flexible cords of the following types:

- 60245 IEC 51;
- 60245 IEC 53 or the like;
- 60227 IEC 52.

Compliance is checked by inspection and by the following test:

The lampholder is fitted with a flexible cord, the device for strain and twist relief being appropriately used. The conductors are introduced into the terminals and the terminal screws are slightly tightened, so that the conductors cannot easily change their position. After this preparation, it shall not be possible to push the cord further into the lampholder.

The flexible cord is then subjected 100 times to a pull of the appropriate value shown in the Table 6, each for a duration of 1 s. The pull shall not be applied in jerks.

Immediately afterwards, the flexible cord is subjected for a period of 1 min to a torque as specified in Table 6.

Table 6 – Pull and torque values

Total nominal cross-sectional area of all conductors together mm ²	Pull N	Torque Nm
Up to and including 1,5	60	0,15
Over 1,5 up to and including 3	60	0,25
Over 3 up to and including 5	80	0,35
Over 5 up to and including 8	120	0,35

The lampholders are tested with each of the appropriate types of cord, as specified before, complying with IEC 60245 or IEC 60227.

The test is first made with conductors of the smallest cross-sectional area specified in 11.1 as well as with conductors of either the largest cross-sectional area allowed by the suspending device or the largest cross-sectional area specified in 11.1, whichever is the smaller.

For lampholders designed for chain connection, the test is carried out with the cables for which the lampholder is designed. The cable is subjected 50 times to a pull of 30 N. The torque test is not carried out.

During the test, no damage to the flexible cord shall be caused by the device for strain and twist relief. At the end of the test, the cord shall not have been displaced by more than 2 mm, and the ends of the conductors shall not have been noticeably displaced in the terminals.

In order to enable the displacement to be measured, before starting the test, a mark is made on the cord under strain at a distance approximately 2 cm from the strain-relieving device. At the end of the test, the displacement of this mark in relation to the strain device is measured while the cord is still under strain.

13.7 Suspending devices of enclosed and independent lampholders shall have no accessible metal parts which can become live, even in the event of a fault in the lampholder. Moreover, suspending devices intended to be screwed into threaded entry lampholders shall comply with the requirements of 13.2.

Compliance is checked by inspection and by the test of 13.6.

13.8 Backplate lampholders not specifically intended for building-in shall have a recess for supply wires. This recess shall have the following minimum dimensions in order to allow back entry from a conduit perpendicular to the mounting surface of the lampholder:

- height 7 mm;
- length equal to diameter or width of the base;

- width 16 mm enlarged to a circular space 23 mm in diameter in the centre.

Compliance is checked by measurement.

The dimensional requirement does not apply to lampholders E5 and E10.

13.9 The base of backplate lampholders, other than those specifically intended for building-in, shall be suitable for fixing by means of screws with a diameter of at least 4 mm.

Compliance is checked by means of a gauge according to Figure 3. For this test, the plug is inserted into the hole from the back and the bush is placed on the plug from the front.

The bush shall enter the recess for the screw head.

This requirement does not apply to lampholders E5 and E10.

13.10 Where provision for cable entry/entries is made on the accessible external surface of a backplate lampholder, they shall allow the introduction of cable covering, conduit or trunking etc., as appropriate, so as to afford mechanical protection at least for a distance of 1 mm measured from the accessible external surface of the backplate lampholder.

Compliance is checked by measurement and by the installation test of 11.1.

13.11 The contacts shall be designed and constructed so as to ensure during normal use effective and reliable electrical contact.

The functioning of the contacts shall be independent of the functioning of an optional locking device between the dome and the outer shell.

New E40 lampholder designs shall be of the contact-making shell type.

NOTE Contact-making problems with actual lamp caps have shown that the contact-making shell type is the only practical solution in this respect.

Compliance is checked by inspection and by the test of 20.2.

A single side-contact is allowed.

13.12 Lampholders shall not be fitted with a socket-outlet.

Compliance is checked by inspection.

13.13 Devices for bridging the lamp filament shall not be integral with the lampholder.

Compliance is checked by inspection and, if necessary, by test.

13.14 Lampholders with a retention device shall be able to withstand a certain unscrewing torque.

A commercially available brass lamp cap complying with the relevant standard sheets shall be inserted into the sample lampholder with retention device, with a torque according to the type of lampholder as specified in Table 7.

Table 7 – Insertion torque

Lamp cap	Torque Nm
E27	1,5 ± 0,1
E40	2,0 ± 0,1

The lamp is then unscrewed for about 30°. In this position, the removal torque is measured.

The removal torque shall not be less than the minimum value and shall not exceed the maximum value specified in Table 8.

Table 8 – Minimum and maximum removal torques

Lamp cap	Minimum torque Nm	Maximum torque Nm
E27	0,5	2,0
E40	1,0	4,0

When the lamp cap is damaged or is showing wear, a new cap should be used for the tests.

14 Switched lampholders

14.1 Switches are allowed only in ordinary lampholders E14 and in ordinary lampholders E27 for use up to and including 250 V.

Compliance is checked by inspection.

14.2 Switched lampholders shall comply with the constructional requirements of 13.3 and with the additional requirements of 14.3 to 14.5, or with the relevant requirements given in IEC 61058-1.

NOTE Guidance for the selection of the relevant requirements in IEC 61058-1 is given in Annex B.

14.3 Switches in lampholders shall be capable of making and breaking a load comprising a filament lamp or self-ballasted lamp for general lighting service (GLS).

Compliance is checked by the following tests:

Switches in lampholders E14 shall be tested for an operating temperature of 100 °C, and switches in lampholders E27 shall be tested for an operating temperature of 125 °C.

Switches in lampholders intended for use in refrigerators or food freezers shall be tested at the rated operating temperatures.

Switches in lampholders with temperature marking shall be tested for operating temperatures as follows:

- *lampholders E14: the temperature marking of the lampholder minus 40 °C;*
- *lampholders E27: the temperature marking of the lampholder minus 50 °C.*

The switch is tested with alternating current ($\cos \varphi = 0,6 \pm 0,05$) at 1,1 times rated voltage and 1,25 times rated current.

The switch shall be operated in a normal manner for 200 switch movements at a rate of 30 movements per minute at regular intervals.

The switch is then tested with alternating current ($\cos \varphi = 1$) at rated voltage and rated current.

The switch shall be operated in a normal manner for 20 000 switch movements at a rate of 30 movements per minute at regular intervals.

NOTE Replacement of the above test by the corresponding test of IEC 61058-1 is under consideration.

At the conclusion of the test, the lampholder shall withstand the tests specified in 15.4 for insulation resistance and electric strength and shall be in satisfactory working order.

14.4 Switched lampholders shall be so constructed that accidental contact between moving parts of the switch and the supply wires is prevented.

Compliance is checked by the test of 11.1 and by a manual test.

14.5 The switch-operating member shall be effectively insulated from live parts and, if it is broken or damaged, it shall not expose live parts.

Compliance is checked by inspection and by the tests specified in 14.3.

14.6 Switches in lampholders intended for use in refrigerators or food freezers may be tested with a lamp according to the expected wattage rating for lamps of the appliance.

15 Moisture resistance, insulation resistance and electric strength

15.1 The enclosure of drip-proof lampholders shall provide the necessary degree of protection against ingress of water.

Compliance is checked by the following test.

Lampholders are fitted with the cables or conduits for which they are designed.

Backplate lampholders are mounted on a vertical surface with one drain hole, if any, open and directed downwards. Other lampholders are mounted with their lamp entry pointing vertically downwards.

The test is made by means of equipment, the principle of which is shown in Figure 3 of IEC 60529:1989. The rate of discharge shall be reasonably uniform over the whole area of the apparatus and shall produce a rainfall of between 3 mm and 5 mm of water per minute, falling vertically from a height of 200 mm measured from the lampholder. The test duration is 10 min. The water used for the test shall be at a temperature of $15\text{ }^{\circ}\text{C} \pm 10\text{ }^{\circ}\text{C}$.

Immediately after this treatment, the lampholder shall withstand the same electric strength test as specified in 15.4, and inspection shall show that water has not entered to an appreciable extent.

NOTE It is considered that water has entered to an appreciable extent if it has come into contact with live parts. In this case, a screw shell which is only live when a lamp is inserted is not considered as a live part.

15.2 Inlet openings of drip-proof lampholders shall allow the connection of the supply wires in such a way that drops of water running along the wires cannot reach the inside of the lampholder.

Compliance is checked by inspection.

15.3 Lampholders shall be proof against humid conditions which may occur in normal use.

Compliance is checked by the humidity treatment described in 15.3 followed immediately by the measurement of the insulation resistance and by the electric strength test specified in 15.4.

Cable entries, if any, are left open; if knock-outs are provided, one of them is opened.

The humidity treatment is carried out in a humidity cabinet containing air with a relative humidity maintained between 91 % and 95 %. The temperature of the air, at all places where specimens can be located, is maintained within 1 °C of any convenient value t between 20 °C and 30 °C.

Before being placed in the humidity cabinet, the specimens are brought to a temperature between t and $(t + 4)$ °C.

Lampholders are kept in the cabinet:

- *two days (48 h) for ordinary lampholders;*
- *seven days (168 h) for IPX1 drip-proof lampholders.*

NOTE 1 In most cases, the specimens can be brought to the specified temperature by keeping them at this temperature for at least 4 h before the humidity treatment.

NOTE 2 Relative humidity between 91 % and 95 % can be obtained by placing in the humidity cabinet a saturated solution of sodium sulphate (Na_2SO_4) or potassium nitrate (KNO_3) in water, having a sufficiently large contact surface with the air. In order to achieve the specified conditions within the cabinet using this method, it is important to ensure constant circulation of the air within and, in general, to use a cabinet which is thermally insulated.

After this treatment, the lampholders shall show no damage within the meaning of this standard.

15.4 The insulation resistance and the electric strength shall be adequate:

- a) between live parts of different polarity;
- b) between such live parts and external metal parts, including fixing screws of the base or enclosure of backplate lampholders, and accessible assembling screws;
- c) between the inner and outer surfaces of the lining of metal enclosures, if such accessible lining is required in accordance with 13.3 to give protection or if the distance between any live part and the metal of the enclosure is smaller than that required under footnote b in Tables 13a and 13b.

Compliance is checked by an insulation-resistance measurement and an electric strength test made immediately after the humidity treatment in the humidity cabinet, or in the room in which the specimens were brought to the prescribed temperature.

The insulation resistance is measured with a DC voltage of approximately 500 V, the measurement being made 1 min after application of the voltage.

The insulation resistance is measured consecutively:

- a) *between live parts of different polarity;*
- b) *between such live parts connected together and the body;*
- c) *between accessible metal parts and metal foil in contact with the inner surface of insulating lining, if any.*

The term "body" used in item b) includes external metal parts, fixing screws of the base and of the enclosure, accessible assembling screws and metal foil in contact with the surface of external insulating parts.

Measurements prescribed in items a) and b) are first made on the lampholder in which the test cap shown in Figure 11 is inserted and then on the empty lampholder.

The switch, if any, is placed in the "on" position.

If metal foil is used for the test on the empty lampholder, it shall also be in contact with the metal screw shell if this shell has to be insulated from the contacts.

The insulation resistance shall be not less than:

- 2 M Ω for the measurement according to item a);*
- 4 M Ω in all other cases.*

Immediately after the insulation resistance test, an AC voltage of substantially sine wave form, with a frequency of 50 Hz or 60 Hz and with an r.m.s. value of $(2 U + 1\,000)$ V (where U is the rated voltage) is applied for 1 min between the points prescribed. For enclosed and unenclosed reinforced insulated lampholders, the test voltage shall be determined from Table 10.2 of IEC 60598-1. Additionally, for switched lampholders, this voltage shall be applied between live parts of different polarity and other metal parts with the switch both closed and open.

The electric strength test voltage between live parts of different polarity for lampholders E5 and E10 with a rated voltage not exceeding 60 V is reduced to 500 V.

Initially, not more than half the prescribed voltage is applied, it is then raised rapidly to the full value.

No flashover or breakdown shall occur during the test.

The high-voltage transformer used for the test shall be so designed that, when the output terminals are short-circuited after the output voltage has been adjusted to the appropriate test voltage, the output current is at least 200 mA.

The overcurrent relay shall not trip when the output current is less than 100 mA.

Care is taken that the r.m.s. value of the test voltage applied is measured within ± 3 %.

Glow discharges without drop in voltage are neglected.

16 Mechanical strength

16.1 Lampholders shall have adequate mechanical strength and shall withstand the strain due to the insertion of a lamp as well as that caused by the screwing of the lampholder to a conduit.

Compliance is checked by the tests of 16.2 to 16.7.

With the exception of candle lampholders, brackets or similar devices for the mounting or attachment of lampholders are not covered by the requirements of Clause 16. The mechanical strength of such devices shall comply with the requirements of the standard for the equipment for which the lampholder is intended.

16.2 The mechanical strength of the outer shell, the screw shell and the dome is checked by screwing a test cap (see Figures 13, 14 and 15) into the specimen, the following torque being applied for 1 min:

- 0,3 Nm for lampholders E5;
- 0,3 Nm for lampholders E10;
- 0,5 Nm for candle lampholders E14, when the lampholder is fixed by the threaded entry;
- 1,2 Nm for candle lampholders E14, when the lampholder is clamped by the outer shell;
- 1,2 Nm for other lampholders E14;
- 2 Nm for lampholders E27;
- 4 Nm for lampholders E40.

The test cap dimensions are as specified in Table 9.

Table 9 – Test cap dimensions

Lampholder	Dimension S ^a mm	Diameter of central contact mm
E14	5,5	4,8
E27	9,5	9,5
E40	11,0	14,0
^a For the meaning of dimension S, see Figures 13, 14 or 15.		

The dimensions of the test caps for lampholders E5 and E10 are under consideration. For the time being, the test is carried out with a cap having the same dimensions as the cap of the lamp for which the lampholder is designed.

The test is made twice: first with the specimen clamped at the outer shell and secondly with the specimen fixed by the threaded entry, dome or backplate, according to type of lampholder.

At the end of the test, the specimen shall not show any change impairing its normal use.

16.3 The dome or backplate of the specimen is fixed and a torque as indicated under 16.2 is applied to the outer shell for 1 min so as to tighten the screwed connection between shell and dome.

This test shall cause neither loosening of the connection between shell and dome nor any other damage.

The test does not apply to lampholders E5 and E10.

16.4 *The dome of threaded entry lampholders is fixed to a brass conduit in the normal way, the set-screws being tightened with a torque equal to the values indicated in Table 12. The locking of the screwed entry is tested by the application for 1 min of a torque as indicated under 16.2, but in an anti-clockwise direction.*

The application of this torque shall not loosen the threaded entry from the brass conduit.

If, however, the threaded entry loosens, the set-screw is further tightened with the smallest torque necessary to prevent the entry from loosening during this test, and this minimum value is noted.

NOTE It is practical to increase the torque by increments of about 20 % during this test.

The minimum value of the torque applied is noted for the purpose of the test of 17.1.

For the tests under 16.2 to 16.4, the use of an apparatus according to Figure 6 is recommended.

16.5 The strength of the connection between dome and threaded entry is checked as indicated in Figure 12.

The specimen is fixed by the threaded entry in a horizontal position. A mandrel with a thread having the maximum IEC dimensions acceptable for caps, and with other dimensions according to Figure 12, is screwed into the lampholder and is loaded for 1 min with a mass, as indicated in Figure 12. The end of the mandrel shall not sag more than 5 mm.

The specimen shall not be damaged. If a permanent deformation occurs, the specimen is forced into the original position and the test is repeated five times, after which the specimen shall show no damage impairing its normal use.

This test does not apply to candle lampholders.

16.6 The mechanical strength of the outer shell of insulating material with or without a conductive outer surface and of insulating rings between the screw shell and the exterior of metal lampholders is checked by means of the pendulum hammer test specified in IEC 60068-2-75 (see Figure 8), subject to the following details (see 3.9 of IEC 60068-2-75:2014).

a) Method of mounting:

The specimen shall be held against the plywood sheet of the mounting fixture in such a manner that its axis is horizontal and parallel to the support and its outer edge touches the plywood.

NOTE For lampholders different from the cylindrical shape, the condition of the axis parallel to the plywood sheet can be obtained by adequate pine wood shimmings.

b) Height of fall:

The striking element shall fall from one of the heights given in Table 10.

Table 10 – Heights of fall

Material	Height of fall mm
Ceramic parts	100 ± 1
Parts made of other material	150 ± 1,5

Candle lampholders, if tested without decorative covers, shall, however, be tested with a height of fall of 100 mm.

c) Number of impacts:

Four blows shall be applied to points equally divided over the circumference of the outer edge of the shell and of the ring.

For lampholders of insulating material, the outer shell shall be hit at the outer edge. For metal lampholders, the outer shell shall be hit at the position of the insulating ring between the screw shell and the exterior.

For such candle lampholders as prescribed in b), one blow shall be applied in two places at 90° on the circumference. The blows shall be applied at 5 mm from the outer edge of the lampholder.

d) Pre-conditioning:

Not applicable.

e) Initial measurements:

Not applicable.

f) *Attitudes and impact locations:*

See c) above.

g) *Operating mode and functional monitoring:*

The sample shall not operate during impact.

h) *Acceptance and rejection criteria:*

After the test, the sample shall show no serious damage within the meaning of this standard, in particular

1) *live parts shall not have become accessible.*

Damage to the lampholder which does not reduce creepage distances or clearances below the values specified in Clause 18 and small chips which do not adversely affect the protection against electric shock or ingress of water shall be ignored;

2) *cracks not visible to the naked eye and surface cracks in fibre-reinforced mouldings and the like shall be ignored.*

Cracks or holes in the outer surface of any part of the lampholder shall be ignored if the lampholder complies with this standard even if that part is omitted.

i) *Recovery:*

Not applicable.

j) *Final measurements:*

See h) above.

The mechanical strength of lampholders E5 and E10 shall be checked by means of the free fall test specified in IEC 60068-2-32:1975.

The lampholder E5 or E10 shall withstand, without damage affecting safety, 50 falls of 500 mm onto a 3 mm thick steel plate in the tumbling barrel (see Figure 7) turning at 5 r/min (that is 10 falls per minute).

NOTE The mechanical strength of lampholders used in luminaires or other equipment can be checked by means of the spring hammer specified in IEC 60068-2-75. In IEC 60598-1, the test impact energy used varies from 0,2 Nm to 0,7 Nm depending on component material and luminaire type.

Additionally, for lampholders provided with a snap-on outer shell the following tests are carried out.

A push and a pull force along the lampholder axis is applied for 1 min. to the outer shell by means of a mass of 5 kg.

After this test the outer shell shall have remained in its intended position.

Additionally it shall not be possible to remove the outer shell by use of the standard fingertip, applied in all possible positions, with a force of 30 N.

16.7 For metal lampholders the mechanical strength of external metal parts (outer shell and dome) is tested by means of an apparatus according to Figure 9.

The various parts are tested on the complete lampholder. Each part is subjected twice for 1 min to a pressure as indicated in Table 11; the pressure is applied on two diameters at right angles to each other. The test is not made on outer shells and domes of insulating material with a conductive outer surface.

During and after the test, the deformation of the specimen shall not exceed the values indicated in Table 11.

Table 11 – Maximum deformation values

Lampholder	Pressure N	Maximum deformation	
		During the test mm	After the test mm
E14	75	1	0,3
E27	100	2	0,3
E40	100	4	0,5

This test does not apply to lampholders E5 and E10 and similar small lampholders.

16.8 Entry spouts and glands shall withstand the mechanical stresses occurring during normal fitting and use.

Compliance is checked by the following test.

Screwed glands are fitted with a cylindrical metal rod having a diameter equal to the nearest whole number of millimetres below the internal diameter of the packing. The glands are then tightened by means of a suitable spanner, a force of 30 N for metal glands, or 20 N for glands of moulded material, being applied for 1 min, at a radius of 25 cm.

At the end of the test, the glands, the spouts and the enclosures shall show no damage.

16.9 Backplate lampholders shall be designed to withstand fixing to a support without damage.

Compliance is checked by the following test.

The backplate of the lampholder is fixed by means of 4 mm screws to a rigid flat steel sheet. This sheet has two drilled and tapped holes at a distance equal to the distance between the axes of the fixing holes of the backplate. The screws are gradually tightened, the maximum torque applied being 1,2 Nm.

The backplate of lampholders shall be fixed by means of screws to a rigid flat steel sheet as follows:

- 3 mm screws for lampholders E10;
- 4 mm screws for lampholders other than E10.

The screws shall be gradually tightened, the maximum torque applied being:

- 0,5 Nm for 3 mm screws, and
- 1,2 Nm for 4 mm screws.

These requirements do not apply to lampholders E5.

For backplate lampholders specifically intended for building-in, this test is carried out with the means of attachment specified by the manufacturer.

After this test, the backplate lampholder shall show no damage impairing its further use.

17 Screws, current-carrying parts and connections

17.1 Screws and mechanical connections, the failure of which might cause the holder to become unsafe, shall withstand the mechanical stresses occurring in normal use.

Compliance is checked by inspection and by the following test.

NOTE 1 Screwed connections are already partially checked by the tests of Clause 16.

Screws and nuts which may be operated when connections are made to the lampholders are tightened and loosened

- *five times for screws operating in a female thread in metal;*
- *ten times for screws operating in a female thread in insulating material*

by means of a suitable test screwdriver applying a torque as indicated in Table 12, except for set-screws tightened with an increased torque during the test of 16.4 when the increased torque is applied. Column 1 applies to screws without heads if the screw, when tightened, does not protrude from the hole. Column 2 applies to other screws. Screws operating in a female thread in insulating material are each time completely removed and reinserted.

The test shall cause no damage impairing the further use of the screwed connections.

Table 12 – Torque values

Nominal diameter of screw mm	Torque Nm	
	1	2
Up to and including 2,8	0,2	0,4
Over 2,8 up to and including 3,0	0,25	0,5
Over 3,0 up to and including 3,2	0,3	0,6
Over 3,2 up to and including 3,6	0,4	0,8
Over 3,6 up to and including 4,1	0,7	1,2
Over 4,1 up to and including 4,7	0,8	1,8
Over 4,7 up to and including 5,3	0,8	2,0
Over 5,3 up to and including 6,0	–	2,5
Over 6,0 up to and including 8,0	–	8,0
Over 8,0 up to and including 10,0	–	17,0
Over 10,0 up to and including 12,0	–	29,0
Over 12,0 up to and including 14,0	–	48,0
Over 14,0 up to and including 16,0	–	114,0
NOTE Column 1 applies to screws without heads if the screw, when tightened, does not protrude from the hole. Column 2 applies to other screws.		

NOTE 2 Screws to be operated when connections are made to the holder include, for example, screws for fixing covers when they have to be loosened for making connections, etc. Conduit thread connections and screws to fasten the holders to their supports are excluded.

The shape of the blade of the test screwdriver shall suit the slot of the screw to be tested. The screw shall not be tightened in jerks.

17.2 In the case of screws operating in a thread in insulating material, the length of the thread shall be not less than 3 mm plus one-third of the nominal screw diameter, except that this length need not exceed 8 mm.

Correct introduction of the screw into the thread shall be ensured.

Compliance is checked by inspection, by measurement and by a manual test.

NOTE The requirement with regard to the correct introduction is met if introduction of the screw in a slanting manner is prevented, for example by guiding the screw by the part to be fixed, by a recess in the female thread or by the use of a screw with the leading thread removed.

17.3 Electrical connections shall be so designed that contact pressure is not transmitted through insulating material other than ceramic, unless there is sufficient resiliency in the metal parts to compensate for any possible shrinkage of the insulating material.

Screws shall not be of a metal which is soft or liable to creep, such as zinc or aluminium.

Screws transmitting contact pressure and screws with a nominal diameter of less than 3 mm which may be operated when connections are made to the lampholder, shall screw into a metal nut or metal insert; locking screws are excepted from this requirement.

Compliance is checked by inspection.

17.4 Screws and rivets, which serve as electrical as well as mechanical connections, shall be locked against loosening.

Compliance is checked by inspection and by a manual test.

NOTE 1 Spring washers can provide satisfactory locking. For rivets, a non-circular shank or an appropriate notch can be sufficient for locking.

NOTE 2 Sealing compound which softens on heating provides satisfactory locking only for screw connections not subject to torsion during normal use.

17.5 Current-carrying parts shall be of copper, an alloy containing at least 50 % copper or material having characteristics at least equivalent.

This requirement does not apply to screws which do not essentially contribute to the current conduction such as terminal screws.

Compliance is checked by inspection and, if necessary, by chemical analysis.

The tests of Clauses 19 and 22 will show whether current-carrying parts are equivalent to copper in respect to current-carrying capacity, mechanical strength and corrosion likely to be met in normal service.

Special care should be taken with regard to corrosion and mechanical properties.

18 Creepage distances and clearances

18.1 Creepage distances and clearances shall be not less than the values shown in Tables 13a and 13b, the lampholder being fitted as in normal use and a lamp being inserted into or removed from the lampholder.

The central contact of the lamp cap shall have a diameter of

- 2,4 mm for lampholders E5;
- 3,8 mm for lampholders E10;
- 5,5 mm for lampholders E14;
- 10,5 mm for lampholders E27;
- 16,0 mm for lampholders E40.

The movement of any floating part shall be so limited as to prevent a decrease of creepage distances or clearances below the specified values.

The distances specified in Table 13a apply to impulse withstand category II, the distances specified in Table 13b apply to impulse withstand category III in accordance with IEC 60664-1. Both tables refer to pollution degree 2, where normally only non-conductive pollution occurs but occasionally a temporary conductivity caused by condensation is to be expected.

NOTE 1 IEC 60664-1 gives information on distances for other impulse withstand categories and higher pollution degrees.

Attention is drawn to the fact that the values for creepage distance and clearance given in Clause 18 are the absolute minimum.

NOTE 2 The voltages shown in Tables 13a and 13b are rated voltages, not ignition voltages.

IECNORM.COM : Click to view the full PDF of IEC 60238:2016+AMD1:2017+AMD2:2020 CSV

**Table 13a – Minimum distances for AC (50/60 Hz) sinusoidal voltages up to 30 kHz –
Impulse withstand category II**

Distances mm	Rated voltage V			
	50	150	250	500 ^b
1—Between live parts of different polarity, and 2—Between live parts and external metal parts, if not covered with insulating material: (this includes screws of backplate lampholders) Basic insulation — Creepage distances: insulation — PTI ≥ 600^a — 0,6 — 0,8 — 1,5 — 3 PTI < 600^a — 1,2 — 1,6 — 2,5 — 5 — Clearances^b — 0,2 — 0,8 — 1,5 — 3 Reinforced insulation — Creepage distances: insulation — PTI ≥ 600^a — — — 1,6 — 3 — 6 PTI < 600^a — — — 3,2 — 5 — 6 — Clearances — — — 1,6 — 3 — 6				
3—Clearances for backplate lampholders^c — between live parts of different polarity, and — 0,6 — 0,8 — 1,5 — 3 — between live parts and the boundary of the space for the supply wires in backplate lampholders not specifically intended for building in: — — — —				
^a— PTI means Proof Tracking Index, in accordance with IEC 60112:2003/AMD1:2009. — In the case of creepage distances to parts not energized or not intended to be earthed, where no tracking can occur, the values specified for material with PTI ≥ 600 apply for all materials (independent of the real PTI). — For creepage distances subjected to working voltages of less than 60 s duration, the values specified for materials with PTI ≥ 600 apply for all materials. — For creepage distances not liable to contamination by dust or moisture, the values specified for material with PTI ≥ 600 apply (independent of the real PTI). ^b— Clearances between live parts and a non-live screw shell in an empty lampholder (unscrewed lamp) shall not be less than 2 mm. ^c— These values take account of possible unevenness of the mounting surface.				
NOTE— Values for creepage distances and clearances can be found for intermediate values of rated voltages by linear interpolation between tabulated values. No values are specified for rated voltages below 25 V as the voltage test of 15.4 is considered sufficient.				

Distances mm	Rated voltage V			
	50	150	250	500 ^d
Basic insulation 1 Distances between live parts of different polarity, between live parts and a non-live screw shell, and 2 Distances between live parts and external metal parts, mounting surfaces, loose metal cover, if any, the outer surface of parts of insulating material which are permanently fixed to the holder ^a , including screws or devices for fixing covers or fixing the holder to its support: – Creepage distances insulation PTI ≥ 600 ^b PTI < 600 ^b – Clearances ^{c d}				
	0,6	0,8	1,5	3
	1,2	1,6	2,5	5
	0,2	0,5	1,5	3
Reinforced insulation Distances between live parts and external metal parts, mounting surfaces, loose metal cover, if any, the outer surface of parts of insulating material which are permanently fixed to the holder ^a , including screws or devices for fixing covers or fixing the holder to its support: – Creepage distances insulation PTI ≥ 600 ^b PTI < 600 ^b – Clearances ^c				
		1,6	3	5,5
		3,2	5	10
	0,4	1,6	3	5,5
Values for creepage distances may be found for intermediate values of rated voltages by linear interpolation between tabulated values. No values are specified for rated voltages below 25 V AC and 60 V DC ripple free as the voltage test of 15.4 is considered sufficient. Creepage distances shall not be less than the required minimum clearance. For glass, ceramics or other inorganic insulating materials which do not track, creepage distances need not be greater than their associated clearance for the purpose of insulation coordination. The dimensions of this table are appropriate. In Japan, the values given in the table are not applicable. Japan requires larger values than the values given in the table.				
^a The distances between live contacts and the lampholder face (reference plane) shall, however, be in accordance with the relevant standard sheets of IEC 60061-2. ^b PTI (proof tracking index) in accordance with IEC 60112:2003 and IEC 60112:2003/AMD1:2009. – In the case of creepage distances to parts not energized or not intended to be earthed, where no tracking can occur, the values specified for material with PTI ≥ 600 apply for all materials (in spite of the real PTI). – For creepage distances subjected to working voltages of less than 60 s duration, the values specified for material with PTI ≥ 600 apply for all materials. – For creepage distances not liable to contamination by dust or moisture, the values specified for material with PTI ≥ 600 apply for all materials (independent of the real PTI). – For creepage distances, the equivalent DC voltage is equal to the r.m.s. value of the sinusoidal AC voltage. ^c For clearances, the equivalent DC voltage is equal to the peak of the AC voltage. ^d Clearances between live parts and a non-live metal screw shell in an empty lampholder (unscrewed lamp) can be reduced to 2 mm.				

**Table 13b – Minimum distances for AC (50/60 Hz) sinusoidal voltages up to 30 kHz –
Impulse withstand category III**

Distances mm	Rated voltage V			
	50	150	250	500 ^b
1—Creepage distances and clearances between live parts of different polarity	0,6	0,8	1,5	3
2—Between live parts and external metal parts, if not covered with insulating material: (this includes screws of backplate lampholders)				
— Creepage distances:				
insulation — PTI ≥ 600 ^a	0,6	1,5	3	4
— PTI < 600 ^a	1,2	1,6	3	5
— Clearances ^b	0,2	1,5	3	4
3—Clearances for backplate lampholders ^c				
— between live parts of different polarity, and				
— between live parts and the boundary of the space for the supply wires in backplate lampholders not specifically intended for building in:	0,6	1,5	3	4
^a — PTI means Proof Tracking Index, in accordance with IEC 60112:2003/AMD1:2009. — In the case of creepage distances to parts not energized or not intended to be earthed, where no tracking can occur, the values specified for material with PTI ≥ 600 apply for all materials (in spite of the real PTI). — For creepage distances subjected to working voltages of less than 60 s duration, the values specified for materials with PTI ≥ 600 apply for all materials. — For creepage distances not liable to contamination by dust or moisture, the values specified for material with PTI ≥ 600 apply (independent of the real PTI). ^b — Clearances between live parts and a non-live screw shell in an empty lampholder (unscrewed lamp) shall not be less than 2 mm. ^c — These values take account of possible unevenness of the mounting surface.				
NOTE—Values for creepage distances and clearances can be found for intermediate values of rated voltages by linear interpolation between tabulated values. No values are specified for rated voltages below 25 V as the voltage test of 15.4 is considered sufficient.				

Distances mm	Rated voltage V			
	50	150	250	500 ^d
Basic insulation 1 Distances between live parts of different polarity and between live parts and a non-live screw shell – Creepage distances insulation PTI ≥ 600 ^b PTI < 600 ^b – Clearances ^{c d}				
	0,6	0,8	1,5	3
	1,2	1,6	2,5	5
	0,2	0,5	1,5	3
2 Distances between live parts and external metal parts, mounting surfaces, loose metal cover, if any, the outer surface of parts of insulating material which are permanently fixed to the holder ^a , including screws or devices for fixing covers or fixing the holder to its support: – Creepage distances insulation PTI ≥ 600 ^b PTI < 600 ^b – Clearances ^c				
	0,6	1,5	3	5,5
	1,2	1,6	3	5,5
	0,2	1,5	3	5,5
Reinforced insulation Distances between live parts and external metal parts, mounting surfaces, loose metal cover, if any, the outer surface of parts of insulating material which are permanently fixed to the holder ^a , including screws or devices for fixing covers or fixing the holder to its support: – Creepage distances insulation PTI ≥ 600 ^b PTI < 600 ^b – Clearances ^c				
	-	3	5,5	8
	-	3,2	5,5	10
	-	3	5,5	8
Values for creepage distances may be found for intermediate values of rated voltages by linear interpolation between tabulated values. No values are specified for rated voltages below 25 V AC and 60 V DC ripple free as the voltage test of 15.4 is considered sufficient. Creepage distances shall not be less than the required minimum clearance. For glass, ceramics or other inorganic insulating materials which do not track, creepage distances need not be greater than their associated clearance for the purpose of insulation coordination. The dimensions of this table are appropriate. In Japan, the values given in the table are not applicable. Japan requires larger values than the values given in the table.				

- | |
|--|
| <p>^a The distances between live contacts and the lampholder face (reference plane) shall, however, be in accordance with the relevant standard sheets of IEC 60061-2.</p> <p>^b PTI (proof tracking index) in accordance with IEC 60112:2003 and IEC 60112:2003/AMD1:2009.</p> <ul style="list-style-type: none">– In the case of creepage distances to parts not energized or not intended to be earthed, where no tracking can occur, the values specified for material with $PTI \geq 600$ apply for all materials (in spite of the real PTI).– For creepage distances subjected to working voltages of less than 60 s duration, the values specified for material with $PTI \geq 600$ apply for all materials.– For creepage distances not liable to contamination by dust or moisture, the values specified for material with $PTI \geq 600$ apply for all materials (independent of the real PTI).– For creepage distances, the equivalent DC voltage is equal to the r.m.s. value of the sinusoidal AC voltage. <p>^c For clearances, the equivalent DC voltage is equal to the peak of the AC voltage.</p> <p>^d Clearances between live parts and a non-live metal screw shell in an empty lampholder (unscrewed lamp) can be reduced to 2 mm.</p> |
|--|

NOTE 3 Information on standard ratings for specific holder types is given in Clause 6.

The clearances for the rated ignition voltage of the holder shall not be less than the values given in Table 14.

NOTE 4 Lampholders can be subjected to a working voltage higher than the rated voltage under the following conditions:

- the nominal voltage and the overvoltage category of the supply voltage does not exceed the rated values of the lampholder;
- the working voltage (r.m.s.) and the maximum repetitive peak working voltage ($\hat{U}_{out}$) marked on the controlgear respectively do not specify a higher creepage distance than the rated voltage of the lampholder;
- the working voltage does not specify a higher clearance than the rated voltage and the rated ignition voltage of the lampholder.

NOTE 5 In case of combination of voltage and frequency (> 30 kHz) requiring higher creepage distances than the values required in Tables 13a and 13b, the controlgear is marked with the details of this combination ($\hat{U}_{out}$ and its corresponding frequency fU_{out}), see IEC 61347-1:2015, 7.1, item w). For details and the required values for creepage distances see IEC 61347-1:2015, 16.2.

Metal locking devices (see 10.3) for the coupling between outer shell and dome are considered as follows:

- if the locking device forms part of the centre contact, the clearances ~~in item 1) of Table 13a or Table 13b apply~~ according to footnote "a" of Table 13a and Table 13b, applies;
- if the locking device forms part of the side contact(s), footnote ~~b~~ "d" of Table 13a or Table 13b applies;
- if the locking device is a separate part, it shall only be taken into account in so far as it shortens any other required distance.

**Table 14 – Minimum distances for ~~non-sinusoidal~~ ignition pulse voltages
or equivalent peak voltages U_p**

Rated pulse voltage (peak kV)	2	2,5	3	4	5	6	8
Minimum clearance (mm)	4	1,5	2	3	4	5,5	8

Rated ignition pulse voltage kV	Minimum clearance mm	
	Basic insulation	Reinforced insulation
2	1	2,2
2,5	1,5	3
3	2	3,8
4	3	6
5	4	8
6	5,5	10,4
8	8	15

For distances subjected to both sinusoidal voltages and non-sinusoidal pulse voltages, the minimum required distance shall not be less than the highest value indicated in Tables 13a or 13b or 14.

Creepage distances shall be not less than the required minimum clearance.

Minimum creepage distances and clearances between live parts of different polarity shall be reduced to 1 mm for lampholders E5 and to 2 mm (for PTI < 600) for lampholders E10 intended for series connected lamps (maximum rated voltage 25 V for lampholders E5 and 60 V for lampholders E10).

Compliance is checked by measuring with and without supply wires of the largest cross-sectional area according to 11.1 connected to the terminals.

NOTE 6 Ignition pulse voltages having a total pulse duration of > 750 μ s or having a higher frequency than f_{crit} can require higher clearances although its peak value is lower than the rated ignition voltage of the lampholder. Therefore, the respective controlgear is marked with an equivalent peak voltage (U_p) which is directly comparable to the rated ignition voltage of the lampholder.

18.2 Sealing compound shall not protrude above the edge of the cavity.

Compliance is checked by inspection.

19 Normal operation

Normal use shall cause no excessive wear or other harmful effect.

Insulation and protection against accidental contact shall not be seriously affected. Linings, barriers and the like shall have adequate mechanical strength and shall be reliably fixed.

Temperature rise and vibration to be expected in normal use shall not cause loosening of electrical connections.

Compliance is checked by the following test.

The specimen shall be placed in a test apparatus as shown in Figure 4. A corresponding test cap, according to Figure 5 shall be screwed in and out 100 times at a rate of about 15 times per minute.

The lampholder shall be fixed during half the number of operations by the threaded entry, dome or backplate according to the type of lampholder, and during the other half clamped at the outer shell.

The test cap (see Figures 13, 14 and 15) is screwed in with a torque of

- 0,4 Nm for candle lampholders E14;
- 1 Nm for lampholders E14;
- 1,5 Nm for lampholders E27;
- 3 Nm for lampholders E40.

At the end of the test, the specimen shall show

- *no wear impairing its operation;*
- *no damage impairing protection against electric shock;*
- *no loosening of electrical contacts;*
- *no loosening of the connection between shell and dome;*
- *no loosening of the set screw locking the threaded entry.*

Finally the specimen shall comply with the requirements of 9.2 and shall withstand an electric strength test according to 15.4, the test voltage being 500 V lower in each case.

NOTE The moisture treatment of Clause 15 is not repeated before this voltage test.

These requirements do not apply to lampholders E5 and E10.

20 General resistance to heat

20.1 Lampholders shall be sufficiently resistant to heat.

Compliance is checked by the tests of 20.2 to 20.4.

20.2

- *For E27 lampholders:*

The lampholder is first checked by means of the gauges according to the current edition of standard sheets 7006-22C and 7006-22D of IEC 60061-3.

After these tests, a solid steel (preferably stainless steel) test cap complying with Figure 14 is screwed into the lampholder, mounted according to its intended use, with a torque of 1,5 Nm. The lampholder, with the test cap screwed in, is then placed in a vertical holder-up position (because the weight of the test cap shall not bear on the holder), in a heating cabinet having a temperature of approximately 85 °C.

This temperature is raised to 175 °C within 1 h ± 15 min. For lampholders which form an integral part of the luminaire, this temperature is replaced by that one measured according to the operating conditions given in 12.4.2 of IEC 60598-1, plus 10 K, with a tolerance of ±5 °C.

After reaching and maintaining this temperature, the lampholder is loaded for 48 h with a current equal to the rated current of the lampholder.

After this period, the lampholder is removed from the heating cabinet and allowed to cool down for 24 h without the test cap.

The tests with gauges 7006-22C and 7006-22D of IEC 60061-3 are then repeated.

The lampholder shall still comply with these gauges.

– *For E14 lampholders:*

A solid steel (preferably stainless steel) test cap B complying with Figure 13 is screwed into a candle lampholder E14, mounted according to its intended use, with a torque of 0,4 Nm and into all other lampholders E14 with a torque of 1 Nm. The lampholder, with test cap B screwed in, is then placed in a vertical holder-up position (because the weight of the test cap shall not bear on the holder), in a heating cabinet having a temperature of approximately 70 °C. This temperature is raised to 145 °C within 1 h ± 15 min. For lampholders which form an integral part of the luminaire, this temperature is replaced by that one measured according to the operating conditions given in 12.4.2 of IEC 60598-1, plus 10 K, with a tolerance of ±5 °C.

After reaching and maintaining this temperature, the lampholder is loaded for 48 h with a current equal to the rated current of the lampholder.

After this period, the lampholder is removed from the heating cabinet and allowed to cool down for 24 h without the test cap.

A solid brass cap A complying with Figure 13 is then screwed into the lampholder with the same torque and then unscrewed. This sequence of operations is performed 10 times, after which the contact resistance between the terminals of the lampholder is measured.

This measurement is made at the rated current of the lampholder, in an AC circuit of not more than 6 V; for switched lampholders the contact resistance in the switch is neglected. The measured contact resistance shall not exceed 0,02 Ω.

NOTE 1 Test cap A is carefully cleaned and polished before being screwed into the lampholder for the contact resistance measurement.

– *For E27 and E14 lampholders:*

T-marked lampholders shall be tested at the marked temperature plus 10 °C.

Lampholders intended for use in refrigerators and food freezers shall be tested at the upper value of the rated operating temperature plus 10 °C.

NOTE 2 The value of 10 °C is being studied and is temporarily kept in line with the present requirements for E27 lampholders.

These requirements do not apply to lampholders E5, E10 and E40.

20.3 Contacts and all other current-carrying parts shall be so constructed as to prevent excessive temperature rise.

Compliance is checked by the following test which shall be made immediately after the test of 20.2 on the lampholder in whose terminals conductors of the maximum cross-sectional area according to 11.1 are fitted.

The terminal screws are tightened with a torque equal to two-thirds of the torque specified in 17.1; the lampholder is placed with the open end downwards and loaded for 1 h with 1,25 times its rated current.

The temperature rise of terminals shall not exceed 45 K.

This temperature is determined with the aid of melting particles or by thermocouples, not by means of thermometers.

For this test, a special test cap shown in Figure 11 is used.

After the test, it is verified that, as required in 11.4, the conductors are not damaged.

NOTE Pellets of beeswax (diameter 3 mm, melting temperature 65 °C) can be used as melting particles provided that the ambient temperature equals 20 °C.

These requirements do not apply to lampholders E5 and E10 with a rated voltage not exceeding 60 V.

20.4 The resistance to heat is then tested in a heating cabinet at the temperature indicated in Table 15.

Table 15 – Heating cabinet temperatures

Lampholder	Temperature °C
E10 general	75
E5 and E10 integral part of luminaire ^a	75 or measured temperature + 15 (whichever is the highest)
E14	170
E27	200
E40	260
^a For E5, E10 and similar small lampholders which form an integral part with the luminaire such as Christmas tree lighting chains, the temperature is measured in the luminaire on the lamp cap at a distance of 2 mm from the lamp glass-to-cap junction.	

T-marked lampholders are tested at the marked temperature plus 35 K.

Lampholders intended for use in refrigerators and food freezers are tested:

- a) at the rated minimum temperature, and*
- b) at the rated operating temperature plus 35 K.*

In case of a) the duration of the test shall be reduced to 16 h.

Immediately after this test, the lampholders shall once more be subjected to the test of 16.6.

A solid steel (preferably stainless steel) test cap complying with Figure 13 (test cap B), 14 or 15 is screwed fully home in the lampholder. The lampholder with the test cap screwed in is then placed in a vertical holder-up position (because the weight of the test cap shall not bear on the holder), in a heating cabinet having approximately half the temperature specified in Table 15. This temperature is raised to the required test temperature within 1 h ± 15 min. Following this, the test is continued for 168 h without interruption.

The test temperature is maintained with a tolerance of ±5 K.

During the test, the lampholder shall not undergo any change impairing its further use especially in the following respects:

- reduction of the protection against electric shock;*
- loosening of electrical contacts;*
- cracks, swelling or shrinking;*
- sealing compound flowing out.*

The test cap is removed from the lampholder after cooling down to approximate room temperature.

At the end of the test, it is checked if the Edison threads are not deformed. The test is made by means of the "Go" gauges shown in the current edition of standard sheets 7006-25 or 7006-25A of IEC 60061-3, as appropriate.

In addition, the holder shall withstand the mechanical strength tests made under the conditions specified in 16.2 and 16.6, the torque, however, being reduced to 50 % of the original value and the height of fall being reduced to 5 cm, respectively.

Sealing compound shall not flow to such an extent that live parts are exposed; a mere displacement of the compound is neglected.

This test is not made on integral lampholders.

21 Resistance to heat, fire and tracking

21.1 Parts retaining the contacts and external parts of lampholders of insulating material and of lampholders comprising external parts of insulating material with a conductive outer surface shall be resistant to heat.

For material other than ceramic, compliance is checked with the aid of the ball-pressure test by means of the apparatus shown in Figure 10.

All the tests required by Clause 21 of this standard are not performed on lampholders which are integral with a luminaire, as similar tests are required in Clause 13 of IEC 60598-1. However, the operating conditions of these tests will take into account those specific to lampholders and defined in Clause 21 of this standard.

For lampholders E5 and E10, only the parts retaining the contacts are subjected to the ball-pressure test.

The surface of the part under test is placed in the horizontal position and a steel ball of 5 mm diameter is pressed against this surface with a force of 20 N.

The test is made in a heating cabinet at a temperature shown in 20.4, except for lampholders E5 and E10, where the temperature is 125 °C.

The test load and the supporting means are placed in the heating cabinet for a sufficient time to ensure that they have attained the stabilized testing temperature before the test commences.

The part to be tested is placed in the heating cabinet for a period of 1 h, before the test load is applied.

If the surface under test bends, the part where the ball presses is supported. For this purpose, if the test cannot be made on the complete specimen, a suitable part may be cut from it.

The specimen shall be at least 2,5 mm thick, but if such a thickness is not available on the specimen then two or more pieces are placed together.

After 1 h, the ball is removed from the specimen which is then immersed within 10 s in cold water for cooling down to approximately room temperature. The diameter of the impression caused by the ball is measured and shall not exceed 2 mm.

NOTE In the event of curved surfaces, such as lampholder shells, the shorter axis is measured if the indent is elliptical.

~~In case of doubt, the depth of the impression is measured and the diameter ϕ calculated using the formula: $\phi = 2\sqrt{p(5-p)}$, where p is the depth of impression.~~

21.2 External parts of insulating material (outer shell, screw shell, dome or backplate) providing protection against electric shock, and parts of insulating material (terminal/contact

assembly) retaining live parts or extra-low voltage (ELV) parts in position, shall be resistant to flame and ignition.

For materials other than ceramic, compliance is checked by the test of 21.3 or 21.4.

Screw shells which are only live when a lamp is inserted into the lampholder are not deemed to be live parts for the purpose of this requirement.

Insulating material retaining such shells in place is therefore checked by the test of 21.3.

21.3 External parts of insulating material, including those with a conductive exterior, providing protection against electric shock, and parts of insulating material retaining ELV parts in position, are subjected to the glow-wire test in accordance with IEC 60695-2-11:2014, subject to the following details.

- *The specimen is a complete holder. It may be necessary to take away parts of the holder to perform the test, but care should be taken to ensure that the test conditions are not significantly different from those occurring in normal use.*
- *The specimen is mounted on the carriage and pressed against the glow-wire tip with a force of 1 N, preferably 15 mm or more from the upper edge, into the centre of the surface to be tested. The penetration of the glow-wire into the specimen is mechanically limited to 7 mm.*

If it is not possible to make the test on a specimen as described above because the specimen is too small, the above test is made on a separate specimen of the same material, 30 mm × 30 mm square and with a thickness equal to the smallest thickness of the specimen.

- *The temperature of the tip of the glow-wire is 650 °C.*

After 30 s the specimen is withdrawn from contact with the glow-wire tip. The glow-wire temperature and heating current are constant for 1 min prior to commencing the test. Care should be taken to ensure that heat radiation does not influence the specimen during this period. The glow-wire tip temperature is measured by means of a sheathed fine wire thermocouple constructed and calibrated as described in IEC 60695-2-11:2014.

- *Any flame or glowing of the specimen shall extinguish within 30 s of withdrawing the glow-wire and any flaming drops of the material shall not ignite a piece of tissue paper, as specified in definition 4.187 of ISO 4046-4:2002, spread out horizontally 200 mm ± 5 mm below the specimen.*

21.4 Parts of insulating material retaining live parts or ELV lamp contacts in position are subjected to the needle-flame test in accordance with IEC 60695-11-5, subject to the following details.

- *The specimen is a complete lampholder. It may be necessary to take away parts of the lampholder to perform the test (for example contacts, which would otherwise shield the area to be tested), but care should be taken to ensure that the test conditions are not significantly different from those occurring in normal use.*
- *The test flame is applied to the centre of the surface to be tested.*
- *The duration of application is 10 s.*
- *Any self-sustaining flame shall extinguish within 30 s of removal of the gas flame and any flaming drops of the material shall not ignite a piece of tissue paper, spread out horizontally 200 mm ± 5 mm below the specimen.*

NOTE For additional information see the explanatory sheet, Figure 18.

21.5 For drip-proof lampholders, insulating parts retaining live parts or ELV parts in position shall have adequate resistance to tracking.

For materials other than ceramic, compliance shall be checked by the proof tracking test in accordance with IEC 60112:2003/AMD1:2009, subject to the following details.

- *If the specimen has no flat surface of at least 15 mm × 15 mm, the test may be carried out on a flat surface with reduced dimensions provided drops of liquid do not flow off the specimen during the test.*
No artificial means should, however, be used to retain the liquid on the surface. In case of doubt, the test may be made on a separate strip of the same material, having the required dimensions and manufactured by the same process.
- *If the thickness of the specimen is less than 3 mm, two specimens, or more if necessary, should be stacked to obtain a thickness of at least 3 mm.*
- *The test shall be made at three places of the specimen or on three specimens.*
- *The electrodes shall be of platinum, and test solution A specified in 7.3 of IEC 60112:2003/AMD1:2009 shall be used.*
- *For drip-proof lampholders the specimen shall withstand 50 drops without failure at a test voltage of PTI 175.*
- *A failure has occurred if a current of 0,5 A or more flows for at least 2 s in a conducting path between the electrodes on the surface of the specimen, thus operating the overcurrent relay, or if the specimen burns without releasing the overcurrent relay.*
- *Clause 9 of IEC 60112:2003/AMD1:2009 regarding determination of erosion, does not apply.*

22 Resistance to excessive residual stresses (season cracking) and to rusting

22.1 *Contacts and other parts of rolled sheets of copper or copper alloy whose failure might cause the lampholder to become unsafe shall not be damaged due to excessive residual stresses.*

Compliance is checked by the following test.

The surface of the specimens is carefully cleaned, varnish being removed by acetone, and grease and finger prints by petroleum spirit or the like.

The specimens are placed for 24 h in a test cabinet, the bottom of which is covered by an ammonium chloride solution having a pH value of 10 (for details of the test cabinet, the test solution and the test procedure, see Annex A).

After this treatment, the specimens are washed in running water; 24 h later they shall show no cracks when inspected at an optical magnification of 8×.

Cracks which may occur in very restricted areas of the outer shell of metal lampholders near the fixing areas of the insulating ring shall not be considered.

In order not to influence the results of the test, the specimens should be handled with care.

22.2 *Ferrous parts, the rusting of which may endanger the safety of the lampholder, shall be adequately rust protected.*

Compliance is checked by the following test.


All grease is removed from parts to be tested by immersion in a suitable degreasing agent for 10 min. The parts are then immersed for 10 min in a water solution of 10 % ammonium chloride at a temperature of 20 °C ± 5 °C.

Without drying, but after shaking off drops of water, the parts are placed for 10 min in a box containing air saturated with moisture at a temperature of $20\text{ °C} \pm 5\text{ °C}$.

After the parts have been dried for 10 min in a heating cabinet at a temperature of $100\text{ °C} \pm 5\text{ °C}$, any traces of rust on sharp edges and any yellowish film may be removed by rubbing, after which their surface shall show no signs of rust.

For small helical springs and the like, and for ferrous parts exposed to abrasion, a layer of grease is deemed to provide sufficient rust protection.

Such parts are not subjected to the test.



Basic profile ^a

Design profile for the nut

Design profile for the screw

IEC


Dimensions in millimetres

Designation	s	Screw					Nut				
		d		d2		d1	D	D2		D1	
		Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.
M8×1	1	8,000	7,800	7,350	7,238	6,917	8,000	7,462	7,350	7,117	6,917
M10×1	1	10,000	9,800	9,350	9,238	8,917	10,000	9,462	9,350	9,117	8,917
M13×1	1	13,000	12,800	12,350	12,190	11,917	13,000	12,510	12,350	12,117	11,917
M16×1	1	16,000	15,800	15,350	15,190	14,917	16,000	15,510	15,350	15,117	14,917


^a The basic profile is the profile to which the deviations defining the limits of the external and the internal threads are applied.

**Figure 1a –Nipple thread for lampholders: metric thread.
Basic profile and design profile for the nut and for the screw**

$$\begin{aligned} h &= 0,960\,491\text{ s} \\ h/6 &= 0,160\,082\text{ s} \\ t_0 = 2/3h &= 0,640\,327\text{ s} \\ r &= 0,137\,329\text{ s} \end{aligned}$$

Basic profile ^a

Design profile for the nut



Dimensions in millimetres


Designation	n ^a	Screw					Nut				
		d		d2		d1	D	D2		D1	
		Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.
G3/8A	19	16,662	16,412	15,806	15,681	14,950	16,662	15,931	15,806	15,395	14,50

^a Number of threads per inch.

^a The basic profile is the profile to which the deviations defining the limits of the external and the internal threads are applied.

Figure 1b –Nipple thread for lampholders: ISO standard pipe thread. Basic profile and design profile for the nut and for the screw

Gauges for the screw



--- Basic profile (see Figure 1a)

"Go" gauge

"Not Go" gauge


IEC

Dimensions in millimetres

Designation	s	d		d2		d1		Wear
		Value	Tolerance	Value	Tolerance	Value	Tolerance	
M10×1	1	9,800	+0,004 –0,004	9,350	–0,012 –0,020	8,917	+0,004 –0,004	0,012
M13×1	1	12,800	+0,004 –0,004	12,350	–0,012 –0,020	11,917	+0,004 –0,004	0,012
M16×1	1	15,800	+0,004 –0,004	15,350	–0,012 –0,020	14,917	+0,004 –0,004	0,012

NOTE The tolerances in column d2 are deliberately positioned both on the same side of the dimension to safeguard a no-man's-land.

Gauges for the nut



--- Basic profile (see Figure 1a)

"Go" gauge

"Not Go" gauge

IEC


Dimensions in millimetres

Designation	s	D		D2		D1		Wear
		Value	Tolerance	Value	Tolerance	Value	Tolerance	
M10×1	1	10,000	+0,004 –0,004	9,350	+0,012 +0,020	9,117	+0,004 –0,004	0,012
M13×1	1	13,000	+0,004 –0,004	12,350	+0,012 +0,020	12,117	+0,004 –0,004	0,012
M16×1	1	16,000	+0,004 –0,004	15,350	+0,012 +0,020	15,117	+0,004 –0,004	0,012

NOTE The tolerances in column D2 are deliberately positioned both on the same side of the dimension to safeguard a no-man's-land.

Figure 2a – Gauges for metric thread for nipples

Gauges for the screw



--- Basic profile (see Figure 1b)

▨ "Go" gauge

▨ "Not Go" gauge


IEC

Dimensions in millimetres

Designation	n ^a	d		d2		d1		Wear
		Value	Tolerance	Value	Tolerance	Value	Tolerance	
G3/8A	19	16,412	$+0$ $-0,008$	15,806	$+0$ $-0,020$	14,950	$+0$ $-0,018$	–

^a Number of threads per inch.

Gauges for the nut



--- Basic profile (see Figure 1b)

▨ "Go" gauge

▨ "Not Go" gauge


IEC

Dimensions in millimetres

Designation	n ^a	D		D2		D1		Wear
		Value	Tolerance	Value	Tolerance	Value	Tolerance	
G3/8A	19	16,662	$+0,018$ $-0,005$	15,806	$+0,005$ $+0,028$	15,395	$+0,008$ -0	0,005

^a Number of threads per inch.


Figure 2b – Gauges for ISO standard pipe thread for nipples



Dimensions in millimetres


Reference	Dimension	Tolerance	
		Manufacture	Wear
a	4,1	+0,03 –0,0	+0,0 –0,03
b	8,2	+0,03 –0,0	+0,0 –0,03
c	18	+0,1 –0,1	– –

Figure 3 – Gauge for holes for backplate lampholder screws




IEC

Figure 4 – Normal operation test apparatus



IEC

Figure 5a – Test cap E14/E27



IEC

Figure 5b – Test cap E40


Material: Hardened steel

The dimensions of the thread on the test cap shall be between the maximum and minimum values specified for E14, E27 and E40 caps in standard sheets 7004-23, 7004-21 and 7004-24 of IEC 60061-1, respectively.

Dimensions in millimetres

Lampholder	C	E	G	H	H1	S	T	α	β
E14	–	12	17	4,8	–	4	17	45°	45°
E27	–	23	32	9,5	–	7,7	23	45°	45°
E40	0,5	–	50	14	17	–	35	45°	45°
Tolerance	+0,1 –0,1	–	+0,5 –0,5	+0,1 –0,1	+0,1 –0	+0,1 –0	+0,1 –0,1	+30' –30'	+1° –1°

Figure 5 – Test caps for the test of Clause 18




Test cap

IEC

Figure 6 – Torque apparatus

Dimensions in millimetres (unless otherwise indicated)



IEC

The body of the tumbling barrel shall be made of steel sheet of 1,5 mm thickness.

The compartments where the sample rests between individual falls shall be backed by a rubber part made of chip-resistant rubber with a hardness of 80 IRHD and the sliding surfaces of these parts shall be made of laminated plastic sheet³.

The tumbling barrel shall be provided with an aperture with lid made of transparent acrylic.

The shaft of the tumbling barrel shall not protrude into the barrel itself.


Figure 7 – Tumbling barrel

³ Formica® is an example of a suitable product available commercially. This information is given for the convenience of users of this document and does not constitute an endorsement by IEC of this product.

Dimensions in millimetres

NOTE For information, this drawing has been retained in this standard, although there is a basic standard.


In case of doubt regarding the drawing, refer to IEC 60068-2-75.



IEC

Figure 8a – Impact-test apparatus

Dimensions in millimetres (unless otherwise indicated)




IEC

NOTE For information this drawing has been retained in this standard, although there is a basic standard. In case of doubt regarding the drawing, refer to IEC 60068-2-75.


Figure 8b – Mounting support

Figure 8 – Impact-test apparatus




IEC

Figure 9 – Pressure apparatus



IEC

Figure 10 – Ball-pressure test apparatus



Tolerances for values without any indication:

- up to and including 30 mm: $\pm 0,05$;
- over 30 mm: $\pm 0,1$;
- on angles: $\pm 30'$.

IEC

^a The insulating material shall be such that it is dimensionally stable, easy to shape and having a PTI of 600; PTFE, for example, is a suitable material.

^b Refers to the metal part only; not applicable to test cap E10.
The dimensions of the thread on the test cap shall be between the maximum and minimum values specified for E10, E14, E27 and E40 caps in standard sheets 7004-22, 7004-23, 7004-21 and 7004-24 of IEC 60061-1, respectively. The inner diameter of the brass cap shall be 2 mm less than the dimension d1 indicated on the relevant standard sheet. The cross-sectional area of the conductors shall be 0,75, 1,5, 1,5 and 4,0 mm² for E10, E14, E27 and E40, respectively. The conductors shall be rigid (solid or stranded).

^c For the E14 test cap, a 45° chamfer is required on the cylindrical portion of the gauge.

NOTE Values for E5 lampholders are under consideration.


Dimensions in millimetres

Lampholder	d	h	B	C1	C2	H	S	E	T min.	K min.	A max.
E10	18	60	6	0,5	2,5	4	–	–	9,5	19	13
E14	38	80	9,5	0,5	3,8	6,2	4,5	12	16	27,2	17,1
E27	38	80	13,5	0,5	4,2	11,5	8,5	23	21,5	28,3	26,1
E40	55	100	25	1	8	18	10 ^a	34 ^a	34	47,8	39

^a In case of lampholders E40, dimensions S and E are only needed for the design of the gauges.

Figure 11 – Test cap for the tests of 15.4 and 20.3

Dimensions in millimetres



IEC

Lampholder	a	b	G kg
E14	19	100	1
E27	25	100	2
E40	37	140	3

Figure 12 – Bending apparatus

Dimensions in millimetres (unless otherwise indicated)




Figure 13a – Test cap A




Figure 13b – Test cap B

- ^a The dimensions of the thread on test cap A shall be between the maximum and minimum values specified in standard sheet 7004-23 of IEC 60061-1.
- ^b The dimensions of the thread on test cap B shall be the minimum values, with a tolerance of $\pm 0,05$ mm, specified in standard sheet 7004-23 of IEC 60061-1.


Figure 13 (1 of 2)

Dimensions in millimetres (unless otherwise indicated)

Reference	Dimensions		Tolerances	
	Test cap A	Test cap B	Test cap A	Test cap B
C1	0,5	1,0	+0,0 –0,1	+0,0 –0,1
C2	2,5	3,0	+0,0 –0,1	+0,0 –0,1
D	3,5	–	+0,1 –0,0	–
S	4,5	4,0	+0,06 –0,0	+0,0 –0,06
H1	4,8	4,8	+0,04 –0,04	+0,04 –0,04
H2	6	6	+0,04 –0,04	+0,04 –0,04
B	10	10	+0,04 –0,0	+0,06 –0,0
E	12	12	–	–
β	–	45°	–	+10' –10'

Figure 13 – Test cap A and test cap B for lampholders E14 (2 of 2)

Dimensions in millimetres (unless otherwise indicated)



Reference	Dimension	Tolerance
C1	1,2	+0,0 -0,04
C2	4,2	+0,0 -0,06
D1	5,45	+0,1 -0,0
D2	7,2	+0,1 -0,0
S	7,7	+0,0 -0,04
H1	9,5	+0,04 -0,04
H2	12,5	+0,04 -0,04
B1	18,5	+0,06 -0,0
B2	20	+0,06 -0,0
B3	22	+0,06 -0,0
E	23	–

IEC

^a The dimensions of the thread on the test cap shall be the minimum values, with a tolerance of $\pm 0,05$ mm, specified in standard sheet 7004-21 of IEC 60061-1.

Figure 14 – Test cap for lampholders E27

Technical drawing of a bolt and nut assembly, showing dimensions and material specifications.

Bolt Dimensions:

- Material: Solid steel
- Head diameter: 30
- Head height: 15
- Shank diameter: 24
- Total length: 40

Nut Dimensions:

- Material: Edges left sharp
- Thread pitch: 1.5
- Thread length: 5
- Total height: 35

Assembly Dimensions:


- Outer diameter: 40
- Inner diameter: 30
- Thread pitch: 1.5

Reference	Dimension	Tolerance
C1	1,5	+0,0 -0,1
C2	7	+0,0 -0,1
S	9	+0,0 -0,06
H1	14	+0,04 -0,04
H2	19	+0,04 -0,04
B	30	+0,06 -0,0
E ^a	34	-
β	45°	+10' -10'

IEC

a The dimensions of the thread on the test cap shall be the minimum values, with a tolerance of $\pm 0,05$ mm, specified in standard sheet 7004-24 of IEC 60061-1.

Figure 15 – Test cap for lampholders E40




Material: metal, except where otherwise specified.

Tolerances on dimensions without specific tolerance:

- on angles: 0'–10'
- on linear dimensions:
 - up to 25 mm: 0/–0,05 mm
 - over 25 mm: ±0,2 mm

Both joints shall permit movement in the same plane and the same direction through an angle of 90° with a 0° to +10° tolerance.

Figure 16 – Standard test finger (according to IEC 60529)



IEC


Key

- 1 terminal/contact assembly
- 2 outer shell
- 3 screw shell
- 4 insulating ring
- 5 shade ring
- 6 dome
- 7 threaded entry

The drawings are intended only to show typical parts of a lampholder and should not limit the design.

^a In this example, parts 2, 3 and 4 are permanently connected together. In other constructions parts 1 and 3 may form one assembly.


Figure 17 – Clarification of some definitions



IEC

For E14 and E27 lampholders, a slot having a width of 5 mm is made to allow entry of the needle and for ventilation.

For E40 lampholders no slot is required.



IEC

The left hand drawing shows how to perform the needle-flame test for testing the side-contact area (not applicable to lampholders E40).

The right-hand drawing shows how to perform the needle-flame test for testing the centre-contact area.

The minimum length of the needle is 35 mm.

Figure 18 – Preparation of specimens for the needle-flame test of 21.4

Annex A (normative)

Season cracking/corrosion test

In the interest of environmental protection, the following requirements relating to test solution, volume and volume of vessel can be modified at the discretion of the test laboratory.

In this event, the test vessel should retain a volume in the range 500 to 1 000 times larger than the volume of the sample and the volume of test solution should be such that the ratio of vessel volume to solution volume is in the range of 20:1 to 10:1. In case of doubt, however, the conditions of Clause A.1 apply.

A.1 Test cabinet

Closeable glass vessels shall be used for the test. These may, for example, be desiccator vessels or simple glass troughs with ground rim and lid. The vessel volume shall be at least 10 l.

A certain ratio of test space to volume of test solution shall be maintained (20:1 to 10:1).

A.2 Test solution

Preparation of 1 l of solution:

Dissolve 107 g ammonium chloride (reagent grade NH_4Cl) in about 0,75 l of distilled or fully demineralized water and add as much of 30 % sodium hydroxide solution (prepared from reagent grade NaOH and distilled or fully demineralized water) as is necessary to reach a pH value of 10 at 22 °C. For other temperatures, adjust this solution to the corresponding pH values specified in Table A.1.

Table A.1 – pH adjustment

Temperature °C	Test solution pH
22 ± 1	10,0 ± 0,1
25 ± 1	9,9 ± 0,1
27 ± 1	9,8 ± 0,1
30 ± 1	9,7 ± 0,1

After the pH adjustment, make up to 1 l with distilled or fully demineralized water. This does not change the pH value any further.

Keep the temperature constant in any event to within ±1 °C during the pH adjustment, and carry out the pH measurement using an instrument which permits an adjustment of the pH value to within ±0,02.

The test solutions may be used over a prolonged period, but the pH value, which represents a measure of the ammonia concentration in the vapour atmosphere, shall be checked at least every three weeks and adjusted if necessary.

A.3 Test procedure

Introduce, preferably suspended, the specimens in the test cabinet in such a way that the ammonia vapour can take effect unhindered. The specimens shall not dip into the test solution nor touch each other. Supports or suspension devices shall be made of materials which are not susceptible to attack by ammonia vapour, e.g. glass or porcelain.

Testing shall be carried out at a constant temperature of $(30 \pm 1) ^\circ\text{C}$ to exclude visible condensed water formation caused by temperature fluctuations, which could severely falsify the test result.

Prior to testing, the test cabinet containing the test solution shall be brought to a temperature of $(30 \pm 1) ^\circ\text{C}$. The test cabinet shall subsequently be filled as quickly as possible with the specimens pre-heated to $30 ^\circ\text{C}$ and closed.

This moment is to be considered the beginning of the test.

Annex B (informative)

Guidance for requirements in IEC 61058-1 applicable to switches in lampholders (see 14.2)

The clauses and subclauses mentioned in Annex B refer to IEC 61058-1:2000.

6 Rating

Subclauses 6.1 and 6.3 are applicable with the following limitations:

6.1 The maximum rated voltage is 250 V.

6.3 The maximum rated current is 2 A.

7.1 Classification of switches

7.1.1 According to nature of supply

Only 7.1.1.1 is applicable.

7.1.2 According to type of load to be controlled by each circuit of the switch

Only 7.1.2.4, 7.1.2.7 and 7.1.2.8 are applicable.

7.1.3 According to ambient temperature

Only 7.1.3.2 is applicable.

7.1.4 According to number of operating cycles

Only 7.1.4.4 is applicable.

For switched lampholders intended to be used in refrigerators or food freezers, 7.1.4.2 applies if the switch is actuated by the door of the refrigerator or food freezer.

7.1.9 According to the glow wire temperature

Only 7.1.9.1 is applicable.

8 Marking and documentation

Not applicable; 13.3 of this standard applies.

16 Heating

16.1 General requirements

Switches in lampholders intended to be used in refrigerators or food freezers are tested at the rated operating temperatures.

20 Clearances, creepage distances, solid insulation and coatings of rigid printed board assemblies

20.2 Creepage distances

Material group IIIb is not useable.

For switched lampholders intended to be used in refrigerators or food freezers, Note 5 is applicable.

IECNORM.COM : Click to view the full PDF of IEC 60238:2016+AMD1:2017+AMD2:2020 CSV

Annex C (informative)

Guidance for special requirements in appliance standards – Household and similar electrical appliances

This standard is based on the requirements of the IEC 60598 series for luminaires. For application in other appliances (e.g. household appliances) the requirements of the relevant appliance standard should be observed.

C.1 List of relevant standards

The following list contains references to appliance standards in which experience has shown that lampholders covered by this standard may be built-in. This list shows a selection of the existing standards and does not lay claim to be exhaustive.

Publication	Title
IEC 60335-1	Household and similar electrical appliances – Safety – Part 1: General requirements
IEC 60335-2-6	Household and similar electrical appliances – Safety – Part 2-6: Particular requirements for stationary cooking ranges, hobs, ovens and similar appliances
IEC 60335-2-9	Household and similar electrical appliances – Safety – Part 2-9: Particular requirements for grills, toasters and similar portable cooking appliances
IEC 60335-2-11	Household and similar electrical appliances – Safety – Part 2-11: Particular requirements for tumble dryers
IEC 60335-2-24	Household and similar electrical appliances – Safety – Part 2-24: Particular requirements for refrigerating appliances, ice-cream appliances and ice-makers
IEC 60335-2-25	Household and similar electrical appliances – Safety – Part 2-25: Particular requirements for microwave ovens, including combination microwave ovens
IEC 60335-2-27	Household and similar electrical appliances – Safety – Part 2-27: Particular requirements for appliances for skin exposure to ultraviolet and infrared radiation
IEC 60335-2-31	Household and similar electrical appliances – Safety – Part 2-31: Particular requirements for range hoods and other cooking fume extractors
IEC 60335-2-36	Household and similar electrical appliances – Safety – Part 2-36: Particular requirements for commercial electric cooking ranges, ovens, hobs and hob elements
IEC 60335-2-42	Household and similar electrical appliances – Safety – Part 2-42: Particular requirements for commercial electric forced convection ovens, steam cookers and steam-convection ovens
IEC 60335-2-43	Household and similar electrical appliances – Safety – Part 2-43: Particular requirements for clothes dryers and towel rails
IEC 60335-2-49	Household and similar electrical appliances – Safety – Part 2-49: Particular requirements for commercial electric hot cupboards
IEC 60335-2-59	Household and similar electrical appliances – Safety – Part 2-59: Particular requirements for insect killers
IEC 60335-2-99	Household and similar electrical appliances – Safety – Part 2-99: Particular requirements for commercial electric hoods

C.2 Reference to special requirements

C.2.1 IEC 60335-1:2001

Clause 8 – Protection against access to live parts

Clause 11 – Heating

Table 3 – Maximum normal temperature rises

Clause 24 – Components

Subclauses 24.1, 24.1.3 and 24.1.6 apply.

Clause 29 – Clearances, creepage distances and solid insulation

Requirements regarding resistance to tracking are given in 29.2.

Requirements regarding thickness of solid insulation are given in 29.3.

Clause 30 – Resistance to heat and fire

Annex E (normative) – Needle-flame test

Annex H (normative) – Switches

Annex N (normative) – Proof tracking test

Annex O (informative) – Selection and sequence of the tests of Clause 30

C.2.2 IEC 60335-2-24:2002

Clause 7 – Marking and instructions

There is no special marking requirement for lampholders within Clause 7 of IEC 60335-2-24:2002. Nevertheless the following requirement is considered to be essential:

In case of lampholders intended for use in a refrigerated compartment of refrigerators and food freezers, the rated minimum temperature to which the lampholder can be subjected shall be marked on the lampholder (e.g. –30 °C).

Clause 8 – Protection against access to live parts

Clause 24 – Components

Particular requirements for switches in doors are given in 24.1.3.

Clause 29 – Clearances, creepage distances and solid insulation

Requirements regarding resistance to tracking are given in 29.2:

For lampholders intended for use in a refrigerated compartment of refrigerators and food freezers, the specimen shall withstand 50 drops without failure at a test voltage of PTI 250.

Annex D (informative)

~~Schedule of amended subclauses containing more serious/critical requirements which require products to be retested~~

Clauses containing new or more stringent requirements with respect to the previous edition

The schedule of clauses given in Annex D details the requirements of this ~~ninth edition~~ Amendment 1 of IEC 60238:2016 which may require retesting to show compliance to this updated standard. Retesting may not be required in cases where examination of previous test results confirms conformity.

- a) ~~Subclause 10.2: Additional pull test requirements for E5 and E10 lampholders with a separate insert part mounted in an outer sleeve (candle shaped lampholders).~~
Clause 18: Update on creepage distances and clearances for frequencies above 30 kHz and inclusion of U_{out} from controlgear.

Bibliography

IEC 60061 (all parts), *Lamp caps and holders together with gauges for the control of interchangeability and safety*

IEC 60061-4, *Lamp caps and holders together with gauges for the control of interchangeability and safety – Part 4: Guidelines and general information*

IEC 60068-2-20, *Environmental testing – Part 2-20: Tests – Test T: Test methods for solderability and resistance to soldering heat of devices with leads*

IEC 60335-1:2001, *Household and similar electrical appliances – Safety – Part 1: General requirements*

IEC 60335-2-24:2002, *Household and similar electrical appliances – Safety – Part 2-24: Particular requirements for refrigerating appliances, ice-cream appliances and ice-makers*

IEC 60598 (all parts), *Luminaires*

IEC 60664-1, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60664-4:2005, *Insulation coordination for equipment within low-voltage systems – Part 4: Consideration of high-frequency voltage stress*

IEC 60695-2-10, *Fire hazard testing – Part 2-10: Glowing/hot-wire based test methods – Glow-wire apparatus and common test procedure*

IEC 61347-1:2015, *Lamp controlgear – Part 1: General and safety requirements*

IECNORM.COM : Click to view the full PDF of IEC 60238:2016+AMD1:2017+AMD2:2020 CSV

SOMMAIRE

AVANT-PROPOS	88
INTRODUCTION à l'Amendement 2	90
1 Domaine d'application	91
2 Références normatives	92
3 Termes et définitions	93
4 Exigences générales	98
5 Conditions générales des essais	99
6 Valeurs normalisées	100
7 Classification	101
8 Marquage	102
9 Dimensions	104
10 Protection contre les chocs électriques	107
11 Bornes	109
12 Dispositions en vue de la mise à la terre	113
13 Construction	115
14 Douilles à interrupteur	120
15 Résistance à l'humidité, résistance d'isolement et rigidité diélectrique	121
16 Résistance mécanique	123
17 Vis, parties transportant le courant et connexions	128
18 Lignes de fuite et distances dans l'air	130
19 Fonctionnement normal	136
20 Généralités sur la résistance à la chaleur	137
21 Résistance à la chaleur, au feu et aux courants de cheminement	139
22 Protection contre les contraintes résiduelles excessives (fissurations intercrystallines) et contre la rouille	142
Annexe A (normative) Essai de fissuration intercrystalline et de corrosion	163
Annexe B (informative) Lignes directrices pour le choix des exigences de l'IEC 61058-1 applicables aux interrupteurs de douilles (voir 14.2)	165
Annexe C (informative) Lignes directrices relatives aux exigences spécifiques des normes d'appareillage – Appareils électrodomestiques et analogues	167
Annexe D (informative) Liste des paragraphes amendés incluant des exigences plus strictes/critiques qui nécessitent la réalisation de nouveaux essais sur les produits Articles contenant des exigences nouvelles ou plus contraignantes par rapport à l'édition précédente	169
Bibliographie	170
Figure 1a – Filetage des raccords pour douilles de lampes: filetage métrique. Profil de base et profil d'exécution pour l'écrou et pour la vis	143
Figure 1b – Filetage des raccords pour douilles de lampes: filetage ISO au pas du gaz. Profil de base et profil d'exécution pour l'écrou et pour la vis	144
Figure 2a – Calibres pour filetage métrique pour raccords de douilles	145
Figure 2b – Calibres pour filetage ISO au pas du gaz pour raccords de douilles	146
Figure 3 – Calibre pour les trous de fixation des douilles à embase	147

Figure 4 – Appareil pour les essais de fonctionnement normal	148
Figure 5 – Culots d'essai pour l'essai de l'Article 18.....	149
Figure 6 – Appareil pour la résistance à la torsion	150
Figure 7 – Tambour tournant.....	151
Figure 8 – Appareil pour l'essai de choc.....	152
Figure 9 – Appareil pour la résistance à la compression	153
Figure 10 – Appareil pour l'essai à la bille.....	153
Figure 11 – Culot d'essai pour les essais de 15.4 et 20.3.....	154
Figure 12 – Appareil pour la résistance à la flexion	155
Figure 13 – Culot d'essai A et culot d'essai B pour les douilles E14 (2 de 2)	157
Figure 14 – Culot d'essai pour les douilles E27.....	158
Figure 15 – Culot d'essai pour les douilles E40.....	159
Figure 16 – Doigt d'épreuve normalisé (d'après l'IEC 60529)	160
Figure 17 – Clarification de quelques définitions	161
Figure 18 – Préparation des spécimens pour l'essai au brûleur-aiguille de 21.4	162
Tableau 1 – Epaisseur des chemises filetées et des contacts	105
Tableau 2 – Longueurs effectives minimales du filetage.....	106
Tableau 3 – Dimensions des entrées taraudées et des vis d'arrêt	107
Tableau 4 – Dimensions minimales des bornes à trous	111
Tableau 5 – Dimensions minimales des bornes à serrage	112
Tableau 6 – Valeurs de traction et de torsion.....	118
Tableau 7 – Couple d'insertion.....	119
Tableau 8 – Couples de dévissage minimal et maximal.....	120
Tableau 9 – Dimensions des culots d'essai.....	124
Tableau 10 – Hauteurs de chute	125
Tableau 11 – Valeurs de déformation maximales	127
Tableau 12 – Valeurs de torsion	128
Tableau 13a – Distances minimales pour les tensions sinusoïdales alternatives (50/60 Hz) en courant alternatif jusqu'à 30 kHz – Catégorie de résistance aux chocs II	131
Tableau 13b – Distances minimales pour les tensions sinusoïdales alternatives (50/60 Hz) en courant alternatif jusqu'à 30 kHz – Catégorie de résistance aux chocs III	133
Tableau 14 – Distances minimales pour les tensions d'impulsion non sinusoïdales d'amorçage ou les tensions de crête équivalentes U_p	135
Tableau 15 – Températures dans l'étuve	138
Tableau A.1 – Réglage du pH	163

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

DOUILLES À VIS EDISON POUR LAMPES

AVANT-PROPOS

- 1) La Commission Electrotechnique Internationale (IEC) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de l'IEC). L'IEC a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, l'IEC – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de l'IEC"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec l'IEC, participent également aux travaux. L'IEC collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de l'IEC concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de l'IEC intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de l'IEC se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de l'IEC. Tous les efforts raisonnables sont entrepris afin que l'IEC s'assure de l'exactitude du contenu technique de ses publications; l'IEC ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de l'IEC s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de l'IEC dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de l'IEC et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) L'IEC elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de l'IEC. L'IEC n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à l'IEC, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de l'IEC, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de l'IEC ou de toute autre Publication de l'IEC, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de l'IEC peuvent faire l'objet de droits de brevet. L'IEC ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets et de ne pas avoir signalé leur existence.

Cette version consolidée de la Norme IEC officielle et de ses amendements a été préparée pour la commodité de l'utilisateur.

L'IEC 60238 édition 9.2 contient la neuvième édition (2016-07) [documents 34B/1852/FDIS et 34B/1860/RVD], et son amendement 1 (2017-01) [documents 34B/1887/FDIS et 34B/1892/RVD] et son corrigendum (2018-01), et son amendement 2 (2020-01) [documents 34B/2029/CDV and 34B/2040A/RVC].

Dans cette version Redline, une ligne verticale dans la marge indique où le contenu technique est modifié par les amendements 1 et 2. Les ajouts sont en vert, les suppressions sont en rouge, barrées. Une version Finale avec toutes les modifications acceptées est disponible dans cette publication.

La Norme internationale IEC 60238 a été établie par le sous-comité 34B: Culots et douilles, du comité d'études 34 de l'IEC: Lampes et équipements associés.

Cette neuvième édition constitue une révision technique.

Cette édition inclut les modifications techniques majeures suivantes par rapport à l'édition précédente:

- a) Addition d'un essai de traction pour certaines douilles E5 et E10.
- b) Une Annexe D répertoriant les exigences/articles amendés nécessitant la réalisation de nouveaux essais sur les produits.

Cette publication a été rédigée selon les Directives ISO/IEC, Partie 2.

Dans cette norme, les caractères d'imprimerie suivants sont utilisés:

– *les déclarations de conformité: en italique.*

Le comité a décidé que le contenu de la publication de base et de ses amendements ne sera pas modifié avant la date de stabilité indiquée sur le site web de l'IEC sous "<http://webstore.iec.ch>" dans les données relatives à la publication recherchée. A cette date, la publication sera

- reconduite,
- supprimée,
- remplacée par une édition révisée, ou
- amendée.

IMPORTANT – Le logo "colour inside" qui se trouve sur la page de couverture de cette publication indique qu'elle contient des couleurs qui sont considérées comme utiles à une bonne compréhension de son contenu. Les utilisateurs devraient, par conséquent, imprimer cette publication en utilisant une imprimante couleur.

INTRODUCTION à l'Amendement 2

Certaines modifications et corrections nécessaires pour l'IEC 60238 sont devenues évidentes au cours des travaux portant sur l'Édition consolidée 9.1 de l'IEC 60238.

Modification 1:

Les normes de sécurité des douilles de lampe réelles exigent un essai à la bille aligné sur l'IEC 60695-10-2 dans les sections "Résistance à la chaleur, au feu et au cheminement". Dans le cadre de cet essai, il existe une méthode alternative par mesure de profondeur d'empreinte décrite pour le calcul du diamètre d'empreinte.

Cette option alternative de calcul a été supprimée de la dernière édition de l'IEC 60695-10-2 datant de 2014 et au cours de sa réunion à Sydney en 2018, le SC 34B/GT1 a convenu également de supprimer cette méthode alternative de l'IEC 60238.

Modification 2:

Sur la base de l'IEC 60664-1:2007, 4.8.1.5, "Matériaux non sujets au cheminement":

"Pour le verre, les céramiques et d'autres matériaux isolants inorganiques qui ne sont pas sujets au cheminement, les lignes de fuite ne nécessitent pas d'être supérieures aux distances d'isolement associées dans le cadre de la coordination de l'isolement. Les dimensions du Tableau F.2 sont donc appropriées dans des conditions de champ hétérogène."

Ceci n'est pas complètement répercuté dans les normes du CE 34 telles que récemment révisées. Pour les applications avec TBT, il est primordial de déterminer si la ligne de fuite doit être de 0,6 mm ou si elle peut être de 0,2 mm, dans le cas d'une utilisation de matériau isolant inorganique.

Correction

Avec l'Amendement 1 à l'IEC 60238 Edition 9, un alinéa complet a été supprimé par accident. Ceci a été corrigé par la publication d'un corrigendum à l'Amendement 1, néanmoins, une correction éditoriale doit être apportée pour les références aux points qui doivent être modifiés en notes de bas de tableau "a" et "d", dans la mesure où le texte de référence a été inclus dans les Tableaux 13a et 13b.

DOUILLES À VIS EDISON POUR LAMPES

1 Domaine d'application

La présente Norme internationale s'applique aux douilles à vis Edison E14, E27 et E40 destinées uniquement au raccordement des lampes et des semi-luminaires¹ à l'alimentation.

Elle s'applique aussi aux douilles à interrupteur destinées exclusivement aux circuits de courant alternatif dont la tension de travail ne dépasse pas 250 V (valeur efficace).

La présente norme est également applicable aux douilles à vis Edison E5 destinées à être raccordées au réseau d'alimentation de lampes montées en série et dont la tension de travail ne dépasse pas 25 V, pour utilisation à l'intérieur, ainsi qu'aux douilles à vis Edison E10 destinées au raccordement au réseau d'alimentation de lampes montées en série et dont la tension de travail ne dépasse pas 60 V, pour utilisation à l'intérieur ou à l'extérieur. Elle s'applique également aux douilles E10 à incorporer, pour le raccordement de lampes individuelles à l'alimentation. Ces douilles ne sont pas destinées à la vente au détail.

Pour autant que la présente norme soit raisonnablement applicable, elle couvre également d'autres douilles que celles à vis Edison destinées au raccordement à l'alimentation de lampes branchées en série.

NOTE Ce type de douille est employé par exemple dans les guirlandes lumineuses pour arbres de Noël.

Pour autant que l'on puisse raisonnablement l'appliquer, cette norme couvre également les adaptateurs.

La présente norme couvre aussi les douilles totalement ou partiellement intégrées au luminaire ou prévues pour être montées dans les appareils. Elle ne couvre que les exigences relatives à la douille. Pour toutes les autres exigences telles que la protection contre les chocs électriques dans la zone des bornes ou du culot de la lampe, les exigences de la norme de l'appareil concerné sont respectées et les essais réalisés après incorporation dans l'appareil approprié, lorsque cet appareil est soumis aux essais selon sa propre norme. De telles douilles ainsi que les douilles pourvues d'un écran extérieur enclenchable, destinées aux fabricants de luminaires exclusivement, ne sont pas destinées à la vente au détail.

La présente norme s'applique aux douilles utilisées à l'intérieur ou à l'extérieur de bâtiments et destinées aux installations d'éclairage domestique ou industriel. Elle s'applique également aux douilles-bougies. Des constructions spéciales peuvent être exigées dans des endroits où règnent des conditions particulières, comme dans le cas de l'éclairage public, à bord des navires, dans les véhicules et dans les locaux à atmosphère dangereuse présentant, par exemple, des risques d'explosion.

La présente norme n'est pas applicable aux douilles E26d pour lampes à trois puissances.

La présente norme est fondée sur les données suivantes, relatives aux lampes pour éclairage général:

- les culots E14 sont utilisés pour des lampes absorbant un courant ne dépassant pas 2 A;
- les culots E27 sont utilisés pour des lampes absorbant un courant ne dépassant pas 4 A;
- les culots E40 sont utilisés pour des lampes absorbant un courant ne dépassant pas 16 A, ou 32 A si la tension nominale de l'alimentation ne dépasse pas 130 V (voir 5.5 et 6.3).

¹ Les exigences applicables aux douilles pour semi-luminaires sont à l'étude.

Quand les douilles sont utilisées dans des luminaires, leurs températures maximales de travail sont spécifiées dans l'IEC 60598.

2 Références normatives

Les documents suivants sont cités en référence de manière normative, en intégralité ou en partie, dans le présent document et sont indispensables pour son application. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

IEC 60061-1, *Culots de lampes et douilles ainsi que calibres pour le contrôle de l'interchangeabilité et de la sécurité – Partie 1: Culots de lampes*

IEC 60061-2, *Culots de lampes et douilles ainsi que calibres pour le contrôle de l'interchangeabilité et de la sécurité – Partie 2: Douilles*

IEC 60061-3, *Culots de lampes et douilles ainsi que calibres pour le contrôle de l'interchangeabilité et de la sécurité – Partie 3: Calibres*

IEC 60068-2-32:1975, *Essais fondamentaux climatiques et de robustesse mécanique – Partie 2-32: Essais – Essai Ed: Chute libre*

IEC 60068-2-75:2014, *Essais d'environnement – Partie 2-75: Essais – Essai Eh: Essais aux marteaux*

IEC 60112:2003, *Méthode de détermination des indices de résistance et de tenue au cheminement des matériaux isolants solides*
Amendement 1:2009

IEC 60227 (toutes les parties), *Conducteurs et câbles isolés au polychlorure de vinyle, de tension nominale au plus égale à 450/750 V*

IEC 60245 (toutes les parties), *Conducteurs et câbles isolés au caoutchouc – Tension assignée au plus égale à 450/750 V*

IEC 60352-1:1997, *Connexions sans soudure – Partie 1: Connexions enroulées – Règles générales, méthodes d'essai et guide pratique*

IEC 60399, *Filetage à filets ronds pour douilles avec bague support d'abat-jour*

IEC 60417, *Symboles graphiques utilisables sur le matériel* (disponible sous: <http://www.graphical-symbols.info/equipment>)

IEC 60529:1989, *Degrés de protection procurés par les enveloppes (Code IP)*
Amendement 1:1999
Amendement 2:2013²

IEC 60598-1, *Luminaires – Partie 1: Exigences générales et essais*

IEC 60630, *Encombrement maximal des lampes à incandescence*

² Il existe une édition consolidée 2.2 (2013) comprenant l'édition 2.0 (1989) et ses Amendement 1 (1999) et Amendement 2 (2013).

IEC 60695-2-11:2014, *Essais relatifs aux risques du feu – Partie 2-11: Essais au fil incandescent/chauffant – Méthode d'essai d'inflammabilité pour produits finis*

IEC 60695-11-5, *Essais relatifs aux risques du feu – Partie 11-5: Flammes d'essai – Méthode d'essai au brûleur-aiguille – Appareillage, dispositif d'essai de vérification et lignes directrices*

IEC 61058-1:2000, *Interrupteurs pour appareils – Partie 1: Règles générales*

ISO 4046-4:2002, *Papier, carton, pâtes et termes connexes – Vocabulaire – Partie 4: Catégories et produits transformés de papier et de carton*

3 Termes et définitions

Pour les besoins du présent document, les termes et définitions suivants s'appliquent.

3.1

douille à serre-fil

douille pourvue d'un dispositif retenant un câble souple par lequel elle peut être suspendue

3.2

douille à entrée taraudée

douille pourvue d'une pièce taraudée au point d'entrée des câbles d'alimentation, permettant à la douille d'être montée sur un support fileté

Note 1 à l'article: La douille à entrée taraudée était précédemment nommée "douille à raccord"

3.3

douille à embase

douille conçue pour permettre le montage au moyen d'une embase associée ou incorporée, directement sur une surface d'appui ou une boîte appropriée

3.4

douille à incorporer

douille conçue pour être incorporée dans un luminaire, dans une enveloppe supplémentaire ou dans un dispositif analogue

3.4.1

douille non protégée

douille à incorporer, conçue de manière que des moyens additionnels, par exemple une enveloppe, soient indispensables pour satisfaire aux exigences de la présente norme concernant la protection contre les chocs électriques

3.4.2

douille protégée

douille à incorporer, conçue de manière qu'elle satisfasse par elle-même aux exigences de la présente norme concernant la protection contre les chocs électriques et, le cas échéant, la classification IP

3.5

douille indépendante

douille conçue de manière qu'elle puisse être installée séparément d'un luminaire tout en assurant toute la protection nécessaire conformément à sa classification et à son marquage

3.6

ensemble borne/contact

pièce ou ensemble de pièces assurant la connexion entre l'extrémité d'un conducteur d'alimentation et les faces de contact du culot de lampe correspondant

Note 1 à l'article: Pour plus de précisions sur certaines définitions, voir également la Figure 17.

3.7

chemise extérieure

pièce cylindrique protégeant l'utilisateur contre le contact avec le culot de la lampe

Note 1 à l'article: Elle peut être munie ou non d'un filetage extérieur pour fixation d'une bague d'abat-jour.

Note 2 à l'article: Pour plus de précisions sur certaines définitions, voir également la Figure 17.

3.7.1

écran extérieur enclenchable

écran extérieur pour un assemblage sans vis qui ne contient pas d'écran vissable

Note 1 à l'article: Il convient que la douille ne soit pas utilisée quand l'écran extérieur enclenchable est enlevé. Il est par conséquent recommandé de positionner la marque d'approbation, lorsqu'il y en a une, de telle façon qu'elle ne soit plus visible lorsque ce type d'écran extérieur est enlevé.

3.8

chemise filetée

pièce cylindrique munie d'un filetage intérieur Edison pour retenir la lampe (le culot) insérée

Note 1 à l'article: Dans quelques constructions, la chemise filetée est fixée de façon permanente ou intégrée dans la chemise extérieure.

Note 2 à l'article: Pour plus de précisions sur certaines définitions, voir également la Figure 17.

3.9

bague d'isolement

pièce intermédiaire cylindrique en matière isolante séparant la chemise filetée métallique et la chemise extérieure métallique

Note 1 à l'article: Pour plus de précisions sur certaines définitions, voir également la Figure 17.

3.10

bague d'abat-jour

pièce cylindrique ayant un filetage interne ou d'autres moyens pour se fixer sur la pièce correspondante du corps de la douille et destinée à monter un abat-jour

Note 1 à l'article: Pour plus de précisions sur certaines définitions, voir également la Figure 17.

3.11

fond

partie d'une douille à serre-fil ou d'une douille à entrée taraudée qui protège les bornes de raccordement

Note 1 à l'article: Pour plus de précisions sur certaines définitions, voir également la Figure 17.

3.12

isolation principale

isolation des parties actives destinée à assurer la protection principale contre les chocs électriques

Note 1 à l'article: L'isolation principale ne comprend pas nécessairement l'isolation exclusivement utilisée à des fins fonctionnelles.

3.13

isolation supplémentaire

isolation indépendante prévue en plus de l'isolation principale en vue d'assurer la protection contre les chocs électriques en cas de défaut de l'isolation principale

3.14

double isolation

isolation comprenant à la fois l'isolation principale et l'isolation supplémentaire

3.15

isolation renforcée

système d'isolation unique des parties sous tension assurant un degré de protection contre les chocs électriques équivalent à une double isolation dans les conditions spécifiées

Note 1 à l'article: L'expression «système d'isolation» ne sous-entend pas que l'isolation se compose d'une pièce homogène. Le système peut comporter plusieurs couches qui ne peuvent pas être soumises aux essais séparément comme isolation principale ou supplémentaire.

3.16

partie active

partie conductrice susceptible de produire un choc électrique

3.17

essai de type

essai ou série d'essais effectués sur un échantillon d'essai de type afin de vérifier la conformité de la conception d'un produit donné aux exigences de la norme concernée

3.18

échantillon d'essai de type

échantillon composé d'un ou de plusieurs spécimens semblables, présenté(s) par le fabricant ou par le vendeur responsable afin de le soumettre aux essais de type

3.19

semi-luminaire

ensemble similaire à une lampe autoballastée mais dans lequel le remplacement de la lampe et/ou de l'amorceur est prévu

3.20

température assignée de fonctionnement

température maximale prévue pour la douille

3.21

température minimale assignée

température la plus basse pour laquelle la douille est conçue (applicable uniquement aux douilles de lampes destinées à être utilisées dans des réfrigérateurs ou congélateurs)

3.22

douille à angle

douille dont la partie arrière (entrée filetée et/ou fond) fait un angle avec l'axe de la chemise filetée

3.23

douille avec dispositif de frein

douille avec un dispositif destiné à prévenir tout dévissage de la lampe dans la douille

Note 1 à l'article: Les lampes sont susceptibles, par exemple, de se dévisser sous l'effet des variations de température ou des vibrations.

3.24

catégorie de tenue aux chocs

chiffre définissant une condition de surtension transitoire

Note 1 à l'article: Les catégories de tenue aux chocs I, II, III et IV sont utilisées.

a) But de la classification des catégories de tenue aux chocs

Les catégories de tenue aux chocs servent à différencier les différents degrés de disponibilité des équipements en ce qui concerne les attentes exigées en matière de continuité de service et de tolérance des risques de défauts.

En sélectionnant les niveaux de tenue aux chocs des équipements, il est possible de réaliser la coordination de l'isolement pour l'installation complète en réduisant le risque de défaut à un niveau acceptable qui servira de base dans la maîtrise de la surtension.

Un chiffre plus élevé désignant la catégorie de tenue aux chocs indique une tenue aux chocs de l'équipement plus élevée, et permet un plus grand choix de méthodes pour la maîtrise de la surtension.

Le concept de catégorie de tenue aux chocs est utilisé pour les équipements directement alimentés par le réseau.

b) Description des catégories de tenue aux chocs

Un équipement de catégorie de tenue aux chocs I est un équipement destiné à être connecté aux installations électriques fixes des bâtiments. Des moyens de protection sont pris à l'extérieur de l'équipement – soit dans l'installation fixe soit entre l'installation fixe et l'équipement – pour limiter les surtensions transitoires à un niveau donné.

Un équipement de catégorie de tenue aux chocs II est un équipement destiné à être connecté aux installations électriques fixes des bâtiments.

Un équipement de catégorie de tenue aux chocs III est un équipement qui constitue une partie des installations électriques fixes et des autres équipements dont le degré de disponibilité attendu est plus élevé.

Un équipement de catégorie de tenue aux chocs IV est destiné à être utilisé à proximité ou dans les installations électriques des bâtiments en amont du tableau de distribution.

3.25

circuit primaire

circuit directement connecté au réseau alternatif

Note 1 à l'article: Il comporte, par exemple, les moyens de connexion au réseau alternatif, les enroulements primaires des transformateurs, moteurs et autres dispositifs en charge.

3.26

circuit secondaire

circuit qui n'a pas de connexion directe avec le circuit primaire en tirant sa puissance d'un transformateur, convertisseur ou système d'isolation équivalent, ou d'un accumulateur

Note 1 à l'article: Exception: les autotransformateurs. Bien qu'ayant une connexion directe avec le circuit primaire, leur partie connectée est également considérée comme un circuit secondaire au sens de la présente définition.

Note 2 à l'article: Les régimes transitoires dans de tels circuits sont amortis par l'enroulement primaire correspondant. Les ballasts inductifs réduisent également la valeur de la tension des régimes transitoires. En conséquence, les composants situés après un circuit primaire ou après un ballast inductif peuvent être adaptés à une catégorie de tenue aux chocs un niveau plus bas, c'est-à-dire une catégorie de tenue aux chocs II.

3.27

adaptateur

composant utilisé pour la connexion électrique et mécanique d'une lampe à une douille

Note 1 à l'article: Cette définition est spécifique à la présente norme. La définition d'un adaptateur est susceptible de varier grandement selon son utilisation. Dans la plupart des cas, un tel composant est utilisé pour adapter les différences de diamètre de filetage entre la douille et la lampe.

3.28

douille protégée à isolation renforcée

douille à incorporer conçue de façon qu'elle satisfasse par elle-même aux exigences des parties à isolation double ou renforcée dans les applications de classe II

3.29

douille à isolation partiellement renforcée

douille à incorporer conçue de façon que certaines parties de la douille nécessitent des dispositions supplémentaires pour satisfaire aux exigences concernant l'isolation double ou renforcée

Note 1 à l'article: Dans certains cas, les dimensions sont susceptibles d'être satisfaites uniquement après montage dans le luminaire.

3.30

tension assignée

valeur déclarée par le fabricant comme étant la tension de service la plus élevée pour laquelle la douille a été prévue

[SOURCE: IEC 60838-1:2016, 3.1, modifié – "travail" a été remplacé par "service"]

3.31

tension de service

tension efficace la plus élevée pouvant être mesurée aux extrémités de tout isolant (les transitoires étant négligées) lorsque la lampe fonctionne dans les conditions normales ou lorsqu'elle est retirée

[SOURCE: IEC 60838-1:2016, 3.2, modifié – "travail" a été remplacé par "service"]

3.32

courant assigné

courant déclaré par le fabricant comme étant le courant le plus élevé pour lequel la douille a été prévue

[SOURCE: IEC 60838-1:2016, 3.3]

3.33

fréquence critique

f_{crit}
fréquence à laquelle la réduction de la tension de claquage d'une distance d'isolement apparaît

Note 1 à l'article: $f_{crit} \approx 0,2/d$ [MHZ] où d (en mm) est la distance d'isolement selon le Tableau 3 (respectivement isolation de base ou supplémentaire et isolation renforcée) sans tenir compte de la fréquence.

[SOURCE: IEC 61347-1:2015, 3.40, modifié – la note a été ajoutée]

3.34

tension d'amorçage

tension de crête appliquée pour amorcer une lampe à décharge

[SOURCE: IEC 61347-1:2015, 3.46]

3.34.1

tension d'impulsion d'amorçage

tension d'amorçage de crête d'une durée totale $\leq 750 \mu s$ (somme de toutes les durées d'impulsion) en moins de 10 ms avec la durée (largeur) de chaque impulsion étant mesurée au niveau de 50 % de la valeur de crête absolue maximale

Note 1 à l'article: Il convient que les formes d'onde d'impulsion d'amorçage, considérées comme une tension d'impulsion d'amorçage, ne contiennent pas de fréquence fondamentale supérieure à 30 kHz ou qu'elles soient généralement fortement amorties (après 20 μs , il convient que le niveau de tension de crête soit inférieur à la moitié de la tension de crête maximale). Pour l'évaluation de la fréquence fondamentale, il convient de consulter l'Annexe E de l'IEC 60664-4:2005.

[SOURCE: IEC 61347-1:2015, 3.46.1]

3.35

tension d'amorçage assignée

valeur crête la plus élevée d'une tension d'impulsion d'amorçage pouvant être supportée par la douille

3.36

tension de service maximale

U_{out}

tension (efficace) de service maximale apparaissant entre les bornes de sortie d'un appareillage ou entre les bornes de sortie et la terre, dans des conditions de fonctionnement normales ou anormales

Note 1 à l'article: Les transitoires et les tensions d'allumage doivent être négligés.

[SOURCE: IEC 61347-1:2015, 3.33, modifié – "d'un appareillage" a été ajouté]

3.37

tension de sortie de crête maximale de service

$\hat{U}_{out}$

tension de service de crête répétitive maximale entre les bornes de sortie d'un appareillage ou entre les bornes de sortie et la terre, lors de conditions de fonctionnement normales ou anormales et avec les surtensions transitoires négligées

[SOURCE: IEC 61347-1:2015, 3.45 modifié – "d'un appareillage " a été ajouté]

3.38

tension de crête équivalente transformée

U_p

tension de crête de sortie transformée, qui est convertie pour la tension de crête la plus défavorable avec sa fréquence associée en une tension d'impulsion d'amorçage

Note 1 à l'article: La valeur de la tension de crête de sortie transformée équivalente déclarée est un paramètre essentiel pour la sélection des composants associés.

Note 2 à l'article: Voir 3.34.1.

Note 3 à l'article: Pour déterminer la tension de crête de sortie transformée équivalente déclarée pour l'isolation principale U_p [principale], la combinaison la plus défavorable de la tension de crête maximale et de la fréquence est à prendre en compte, ce qui signifie la distance dans l'air maximale conformément à l'IEC 61347-1:2015, Tableau 10, pour l'isolation principale.

Note 4 à l'article: Pour déterminer la tension de crête de sortie transformée équivalente déclarée pour l'isolation renforcée U_p [renforcée], la combinaison la plus défavorable de la tension de crête maximale et de la fréquence est à prendre en compte, ce qui signifie la distance dans l'air maximale conformément à l'IEC 61347-1:2015, Tableau 11, pour l'isolation renforcée.

[SOURCE: IEC 61347-1:2015, 3.47]

4 Exigences générales

Les douilles de lampes doivent être conçues et construites de façon qu'en usage normal leur fonctionnement soit sûr et que l'utilisateur ou l'entourage ne puisse pas être mis en danger.

En général, la conformité est vérifiée en exécutant la totalité des essais spécifiés.

De plus, l'enceinte des douilles indépendantes doit satisfaire aux exigences de l'IEC 60598-1, y compris celles relatives à la classification et au marquage.

5 Conditions générales des essais

5.1 Les essais mentionnés dans la présente norme sont des essais de type.

NOTE Les exigences et tolérances autorisées par cette norme se rapportent à l'essai d'un échantillon d'essai de type soumis à cette fin.

La conformité de l'échantillon d'essai de type n'implique pas la conformité de la totalité de la production du fabricant à cette norme de sécurité.

En plus de l'essai de type, la conformité de production est sous la responsabilité du fabricant et peut comprendre des essais individuels (de série) et d'assurance de la qualité.

Pour de plus amples informations sur les essais de conformité en cours de fabrication, voir l'IEC 60061-4.

5.2 Sauf spécification contraire, les essais sont effectués à une température ambiante de $20\text{ °C} \pm 5\text{ °C}$, la douille étant soumise aux essais en état de livraison et installée comme en usage normal.

5.3 L'ensemble des essais et des vérifications est effectué sur un total de

- neuf spécimens pour les douilles sans interrupteur, ou
- 12 spécimens pour les douilles à interrupteur

dans l'ordre des articles ci-après:

- trois spécimens: Articles 2 à 13 (à l'exception des paragraphes 10.1 et 11.2) et Articles 15 à 18;
- trois spécimens: Article 14 (essais des douilles à interrupteur seulement);
- trois spécimens: 10.1, Articles 19 et 20;
- deux spécimens: Article 21 (dont l'un pour l'essai de 21.1 et l'autre pour les essais de 21.3 ou 21.4);
- un spécimen: 21.5 et Article 22.

Pour les essais de douilles avec dispositif de frein, le dispositif de frein doit être enlevé.

Pour les essais des douilles avec dispositif de frein, effectués en conformité avec 13.14, trois spécimens supplémentaires sont exigés avec le dispositif de frein en place.

Pour les essais des bornes sans vis, conformément à 11.2, des spécimens séparés sont en outre nécessaires.

5.4 *En cas de doute, les calibres, les culots d'essai et les mandrins sont vissés dans les spécimens, sauf spécification contraire, en appliquant un des couples de torsion suivants:*

- 0,2 Nm pour les douilles E5;
- 0,2 Nm pour les douilles E10;
- 0,2 Nm pour les douilles E14;
- 0,4 Nm pour les douilles E27;
- 0,8 Nm pour les douilles E40.

5.5 *Pour les douilles E40 dont le courant assigné est de 32 A, les essais doivent être effectués sur la base de ce courant assigné.*

5.6 *Les douilles sont considérées comme répondant à la présente norme si aucun des spécimens soumis à la série complète des essais spécifiés en 5.3 ne présente de défaillance.*

Si un spécimen est refusé à un essai, cet essai et ceux qui l'ont précédé, qui peuvent influencer le résultat de cet essai, sont répétés sur un autre lot de spécimens en nombre égal à celui exigé par 5.3, et qui tous doivent alors satisfaire aux essais répétés et aux suivants. Les douilles sont considérées comme ne répondant pas à la présente norme s'il se produit plus d'une défaillance.

6 Valeurs normalisées

6.1 Les tensions assignées normalisées sont 250 V et 500 V.

Pour les douilles E14 et les douilles E27 à interrupteur, la seule tension assignée admissible est 250 V.

Pour les douilles E5 et E10 destinées au raccordement à l'alimentation de lampes connectées en série, la tension assignée ne doit pas dépasser 25 V pour les douilles E5 et 60 V pour les douilles E10.

NOTE 1 Ces valeurs se réfèrent à la tension entre parties de polarité différente.

Pour les douilles E10 destinées au raccordement de lampes individuelles à l'alimentation, seule la tension assignée de 250 V est admise.

NOTE 2 Ces douilles sont également utilisées pour des cas spéciaux tels que les lampes connectées en série où, en raison du faible nombre de lampes, la tension de 60 V par douille est dépassée.

Hormis l'exception indiquée pour les douilles E5 et E10, la tension assignée ne doit pas être inférieure à 250 V. En outre, une tension assignée de 125 V est admise pour les douilles E40.

La conformité est vérifiée par examen du marquage.

6.2 Les valeurs normalisées du courant assigné sont

- 0,2 A pour les douilles E5;
- 0,5 A pour les douilles E10;
- 2 A pour les douilles E14;
- 2 A pour les douilles E27 à interrupteur;
- 4 A pour les autres douilles E27;
- 16 A pour les douilles E40.

Le courant assigné ne doit pas être inférieur à la valeur normalisée.

La conformité est vérifiée par examen du marquage.

6.3 Les douilles E40 à utiliser dans des installations à 125 V peuvent être prévues, en outre, pour un courant assigné de 32 A.

NOTE Cette valeur nominale assignée couvre toutes les tensions jusqu'à 130 V inclus.

La conformité est vérifiée par examen du marquage.

6.4 La température assignée de fonctionnement des douilles prévues pour fonctionner dans des conditions de températures élevées (douilles à marquage T) ne doit pas être inférieure à 140 °C pour les douilles E14, 170 °C pour les douilles E27 et 230 °C pour les douilles E40.

La conformité est vérifiée par examen du marquage.

NOTE Les températures assignées de fonctionnement des douilles à vis Edison sans marquage T sont indiquées dans l'IEC 60598-1, Tableau 12.1. Elles sont

- 135 °C pour les douilles E14;
- 165 °C pour les douilles E27;
- 225 °C pour les douilles E40.

7 Classification

Les douilles sont classées selon 7.1 à 7.6.

7.1 D'après la matière des parties extérieures:

- douilles en matière isolante;
- douilles métalliques.

NOTE Les douilles qui ont des parties extérieures partiellement en métal et les douilles qui comportent des parties extérieures en matière isolante ayant une surface extérieure conductrice, par exemple une chemise extérieure métallisée, sont considérées comme des douilles métalliques (voir 13.3). Cela ne s'applique pas aux entrées taraudées et aux parties extérieures comme une bague d'abat-jour métallique montée à l'extérieur de la douille en matière isolante, qui ne peuvent pas devenir actives même dans le cas d'un défaut d'isolation. Les douilles métalliques à revêtement isolant sont considérées comme des douilles métalliques (voir 10.5).

Pour contrôler si une surface est conductrice ou non, deux lames métalliques d'une largeur de 1,5 mm, d'une longueur de 25 mm et d'un écartement de 2 mm sont appliquées sur cette surface (à revêtement de peinture d'argent conductrice, par exemple). La résistance d'isolement entre les deux lames est alors mesurée conformément à 15.4. La surface est considérée comme étant conductrice si cette résistance est inférieure à 5 MΩ.

7.2 D'après le degré de protection contre la pénétration d'eau:

- douilles ordinaires;
- douilles protégées contre le ruissellement d'eau vertical.

7.3 D'après le dispositif de fixation:

- douilles à entrée taraudée;
- douilles à serre-fil;
- douilles à embase;
- autres douilles.

NOTE D'autres exemples de douilles sont les douilles munies d'un dispositif de suspension mécanique, par exemple un crochet.

7.4 D'après le type:

- douilles à interrupteur, munies d'un interrupteur intégré pour commander la mise sous tension de la lampe;
- douilles sans interrupteur.

7.5 D'après la protection contre les chocs électriques:

- douilles non protégées;
- douilles protégées;
- douilles indépendantes;
- douilles à isolation partiellement renforcée;
- douilles protégées à isolation renforcée.

NOTE Quand une douille est utilisée avec une tension de travail égale à 50 % ou moins de sa tension maximale assignée, elle est susceptible d'être considérée comme une douille à isolation renforcée.

7.6 D'après la résistance à la chaleur:

- douilles pour des températures de fonctionnement assignées allant jusqu'aux limites données en 6.4;
- douilles pour le fonctionnement dans les conditions de haute température (douilles marquées T).

8 Marquage

8.1 Les douilles autres que les douilles E5 et E10 doivent porter les marquages suivants:

- courant assigné, en ampères;
- tension assignée, en volts, ~~et~~
- tension d'~~impulsion~~ ~~amorçage~~ assignée, en kV, si elle est supérieure à
 - 2,5 kV pour les douilles de 250 V,
 - 4 kV pour les douilles de 500 V;

~~Il convient que~~ Si cela est applicable, la tension d'~~impulsion~~ ~~amorçage~~ assignée de la douille (en kV) ~~soit~~ doit être marquée sur la douille ou indiquée dans le catalogue du fabricant ou document similaire.

NOTE 1 Certaines douilles continuent à indiquer des tensions assignées supérieures à 500 V. C'était la façon autrefois utilisée d'exprimer la tension d'~~impulsion admissible~~ ~~amorçage autorisée~~ par l'intermédiaire ~~d'une~~ de la tension assignée. Pour de telles douilles, les lignes de fuite et distances dans l'air ~~figurent~~ peuvent être consultées dans l'IEC 60598-1.

- le symbole de la nature du courant, s'il est exigé (pour les douilles comportant un interrupteur seulement);
- la marque d'origine (qui peut prendre la forme d'une marque déposée, d'une marque d'identification du fabricant ou du nom du vendeur responsable);
- la référence du type;

Il convient que la documentation technique disponible du fabricant telle que des catalogues imprimés ou en ligne permette une identification claire de la douille, soit par un numéro de catalogue unique soit par une référence d'identification sur le culot, spécifiant les caractéristiques essentielles et la conception de base du produit, complétée d'une description claire. Les variantes de la conception de base telles que, par exemple, une longueur de câble différente, des moyens de fixation différents, une couleur différente, etc., qui n'affectent pas la sécurité ou la performance de la douille, peuvent être ignorées dans la référence du type marquée sur le produit. Les variantes incluses dans la procédure d'essai de type sont répertoriées dans les rapports d'essai correspondants.

- le degré de protection contre la pénétration d'eau, pour les douilles protégées contre le ruissellement d'eau vertical (voir 8.2);
- la température assignée de fonctionnement "T", indiquant la plus haute température de fonctionnement, le cas échéant.

Le marquage de la température assignée de fonctionnement n'est pas obligatoire pour les douilles dont la partie extérieure est entièrement en matière céramique. Dans le cas de telles douilles, l'indication doit, le cas échéant, être soit marquée sur la douille soit être mentionnée dans le catalogue du fabricant.

Pour les douilles conformes à cette norme, les distances correspondant à la catégorie de tenue aux chocs II sont normalement applicables. Pour les douilles des équipements dont un degré de disponibilité supérieur est attendu, les distances de la catégorie de tenue aux chocs III peuvent être applicables. Cette information doit figurer dans le catalogue du fabricant ou document similaire.

Les douilles protégées à isolation renforcée offrent un niveau satisfaisant de protection pour une utilisation dans les luminaires où elles sont accessibles en usage normal. Cette information doit être indiquée dans le catalogue du fabricant ou document similaire.

Pour des douilles à isolation partiellement renforcée, des lignes de fuite et distances dans l'air suffisantes par rapport aux surfaces extérieures accessibles nécessiteront des protections additionnelles pour certaines parties de la douille grâce à la conception du luminaire ou en utilisant un ou plusieurs accessoire(s) ou couvercle(s) supplémentaire(s). Cette information doit être indiquée dans le catalogue du fabricant ou document similaire.

Les douilles E10 doivent porter les marquages suivants:

- la tension assignée, en volts;
- la marque d'origine;
- la référence du type;

Il convient que la documentation technique disponible du fabricant telle que des catalogues imprimés ou en ligne permette une identification claire de la douille, soit par un numéro de catalogue unique soit par une référence d'identification sur le culot, spécifiant les caractéristiques essentielles et la conception de base du produit, complétée d'une description claire. Les variantes de la conception de base telles que, par exemple, une longueur de câble différente, des moyens de fixation différents, une couleur différente, etc., qui n'affectent pas la sécurité ou la performance de la douille, peuvent être ignorées dans la référence du type marquée sur le produit. Les variantes incluses dans la procédure d'essai de type sont répertoriées dans les rapports d'essai correspondants.

- le degré de protection contre la pénétration d'eau, le cas échéant.

Les douilles E5 doivent porter les marquages suivants:

- la marque d'origine;
- la référence du type.

Il convient que la documentation technique disponible du fabricant telle que des catalogues imprimés ou en ligne permette une identification claire de la douille, soit par un numéro de catalogue unique soit par une référence d'identification sur le culot, spécifiant les caractéristiques essentielles et la conception de base du produit, complétée d'une description claire. Les variantes de la conception de base telles que, par exemple, une longueur de câble différente, des moyens de fixation différents, une couleur différente, etc., qui n'affectent pas la sécurité ou la performance de la douille, peuvent être ignorées dans la référence du type marquée sur le produit. Les variantes incluses dans la procédure d'essai de type sont répertoriées dans les rapports d'essai correspondants.

La conformité est vérifiée par examen.

NOTE 2 La référence du type pour les douilles E10 et E5 peut être un numéro de catalogue.

8.2 Lorsqu'il est fait usage de symboles pour le courant et pour la tension, A doit désigner les ampères et V les volts.

Il est également permis d'indiquer le courant assigné et la tension assignée en inscrivant seulement leurs valeurs numériques, le nombre indiquant le courant assigné étant placé avant ou au-dessus du nombre indiquant la tension assignée et ces valeurs étant séparées par un trait oblique ou horizontal.

Le marquage du courant et de la tension peut donc avoir les formes suivantes:

2 A 250 V ou $\frac{2}{250}$.

Le symbole du courant continu doit être  (IEC 60417-5031:2002-10).

La protection contre la pénétration d'eau pour les douilles protégées contre le ruissellement d'eau vertical doit être indiquée par IPX1.

NOTE 2 Quand la lettre X figure dans le numéro IP, elle indique un chiffre manquant dans l'exemple, mais les deux chiffres appropriés sont marqués conformément à l'IEC 60529.

La lettre T doit être suivie de la valeur de la température assignée de fonctionnement, en degrés Celsius.

La conformité est vérifiée par examen.

8.3 Le marquage du degré de protection contre la pénétration d'eau doit être apposé sur l'extérieur de la douille.

La conformité est vérifiée par examen.

8.4 Une borne de terre doit être repérée par le symbole  (IEC 60417-5019:2002-10).

Ce symbole ne doit pas figurer sur des vis, sur des rondelles amovibles ou d'autres parties facilement amovibles.

La conformité est vérifiée par examen.

8.5 Le marquage doit être durable et facilement lisible.

La conformité est vérifiée par examen et, après la réalisation des essais de l'Article 19, en essayant d'effacer le marquage en le frottant légèrement pendant 15 s avec un chiffon imbibé d'eau et pendant 15 s avec un chiffon imbibé de white spirit.

Après les essais, le marquage doit être encore lisible.

NOTE Le white spirit utilisé est généralement composé d'hexane, avec une teneur maximale en carbures aromatiques de 0,1 % en volume, une teneur en kauri-butanol de 29, une température d'ébullition initiale d'environ 65 °C, une température d'ébullition finale d'environ 69 °C et une densité spécifique d'environ 0,68 g/cm³.

9 Dimensions

9.1 Les douilles E10, E14, E27 et E40 doivent être conformes aux feuilles de norme en vigueur de la série IEC 60061.

La conformité doit être vérifiée par des mesures conformément à la feuille de norme 7005-20, de l'IEC 60061-2.

Les dimensions minimales du filetage et la dimension X doivent être vérifiées au moyen des calibres conformes aux feuilles de norme 7006-25 (E10, E14 et E40) et 7006-25A (E27) ainsi qu'au moyen du calibre conforme à la feuille de norme 7006-26 de l'IEC 60061-3.

Les douilles conçues avec un filetage à filet rond pour bagues supports d'abat-jour et les bagues supports d'abat-jour doivent satisfaire à l'IEC 60399.

La conformité est vérifiée au moyen des calibres indiqués dans l'IEC 60399.

9.2 Les douilles doivent permettre l'introduction de toutes les lampes correspondantes jusqu'à l'obtention du contact.

La conformité est vérifiée au moyen de calibres conformes à l'édition en cours des feuilles de norme suivantes de l'IEC 60061-3 et d'après les indications données par ces feuilles:

- douilles E14: 7006-30 et 7006-31;
- douilles-bougies E14: 7006-30A et 7006-31;
- douilles E27: 7006-21 et 7006-22A;
- douilles E40: 7006-23 et 7006-24.

En attendant les spécifications des calibres pour les douilles E5 et E10, la vérification de la réalité du contact se fait à l'aide des lampes correspondantes. Il est entendu que le fabricant de la douille fournira à cet effet les lampes pour lesquelles la douille a été prévue.

La vérification de la réalité du contact est effectuée sur les douilles à l'état de livraison, ainsi qu'après les essais des Articles 19 et 20.2.

Uniquement pour les douilles utilisées dans des appareils autres que les luminaires:

Si les dispositifs de fixation des douilles font partie intégrante du bord et que la douille est destinée à être utilisée uniquement avec certaines lampes normalisées, ces parties du bord de la douille sont susceptibles d'interférer avec le calibre de vérification du contact correspondant. Dans ce cas, la conformité avec les exigences des dimensions extérieures des lampes selon l'IEC 60630 pour la lampe concernée doit être vérifiée. A la suite de ce contrôle, le calibre de vérification du contact doit être utilisé après le retrait des parties de la douille interférant avec le calibre.

Pour l'essai de telles douilles, deux spécimens supplémentaires spécialement préparés pour accepter le calibre de vérification de contact sont nécessaires.

9.3 Les dimensions suivantes ne doivent pas être inférieures aux valeurs indiquées dans le Tableau 1.

Tableau 1 – Epaisseur des chemises filetées et des contacts

Dimension	Douille				
	E5	E10	E14	E27	E40
Epaisseur de la chemise filetée éventuelle (mm):					
– si la chemise est libre	0,20	0,20	0,30	0,30	0,50
– si la chemise comporte un isolant appliqué au filetage sur une distance totale d'au moins trois quarts du pourtour de la chemise	0,15	0,15	0,25	0,25	0,40
Epaisseur des contacts latéraux ou centraux, s'ils sont élastiques (mm)	0,18	0,18	0,28	0,38	0,48 ^a
^a Pour l'emploi de contacts latéraux dans les douilles E40, voir 13.11.					

La conformité est vérifiée par des mesures.

NOTE 1 Les épaisseurs sont mesurées à l'aide d'un micromètre à pointes et rochet d'encliquetage.

Pour la chemise filetée, deux séries de trois mesures sont effectuées, chaque série le long de deux génératrices quelconques de la chemise. La valeur moyenne des six mesures doit être au moins égale à la valeur spécifiée.

NOTE 2 La suppression des exigences relatives aux dimensions est à l'étude.

9.4 La longueur effective du filetage éventuel servant à assembler la chemise extérieure et le fond des douilles doit répondre à l'une des exigences suivantes, étant toutefois entendu qu'au moins un tour entier est en prise.

La longueur effective du filetage ne doit pas être inférieure aux valeurs indiquées dans le Tableau 2, ou au moins deux tours entiers doivent être en prise et l'essai de 16.3 doit être satisfait pour un couple égal à 1,2 fois le couple spécifié en 16.2.

Tableau 2 – Longueurs effectives minimales du filetage

Dimension	Douille		
	E14	E27	E40
Longueur effective minimale du filetage (mm):			
– Douilles métalliques pour filetage roulé	5,0	7,0	10,0
– Douilles métalliques pour filetage décolleté	5,0	5,0	7,0
– Douilles en matière isolante	5,0	7,0	10,0

Ces exigences ne sont pas applicables aux douilles E5 et E10.

La conformité est vérifiée par des mesures.

9.5 Les entrées taraudées des douilles doivent être pourvues d'un des filetages suivants:

- douilles E14: M10×1;
- douilles E27: M10×1, M13×1 ou M16×1;
- douilles E40: M13×1, M16×1 (ou G3/8A).

NOTE 1 La valeur entre parenthèses n'est pas préférentielle; par ailleurs, l'entrée taraudée M10 est généralement réservée au câblage interne des luminaires.

NOTE 2 En France, les entrées filetées des douilles avec des filetages de 11 mm × 19 TPI et 17 mm × 19 TPI (filets par pouce) sont autorisées pour le remplacement.

Le filetage de l'entrée doit être conforme aux Figures 1a ou 1b.

Ces exigences ne sont pas applicables aux douilles E5 et E10.

La conformité est vérifiée par des mesures et au moyen de calibres conformes aux Figures 2a ou 2b.

En cas de doute, le calibre est introduit dans l'entrée avec application d'un couple de 0,5 Nm.

9.6 Les cotes des entrées taraudées des douilles et des vis d'arrêt éventuelles ne doivent pas être inférieures aux valeurs indiquées dans le Tableau 3.

Tableau 3 – Dimensions des entrées taraudées et des vis d'arrêt

Dimensions en millimètres

Dimension	Diamètre nominal du filetage	
	M10×1 M13×1	M16×1 G3/8A
Longueur du filetage:		
– entrée métallique	3	8
– entrée en matière isolante	5	10
Diamètre de la vis d'arrêt:		
– vis avec tête	2,5	3,0
– vis sans tête:		
– une seule vis	3,0	4,0
– plus d'une vis	3,0	3,0

Un écart négatif de 0,15 mm par rapport aux valeurs nominales du diamètre du filetage est admis.

La conformité est vérifiée par des mesures.

Ces exigences ne sont pas applicables aux douilles E5 et E10.

NOTE S'il est nécessaire de démonter la douille pour vérifier la conformité aux exigences de 9.3 à 9.6, cette vérification est effectuée après l'essai de l'Article 18.

9.7 Les douilles doivent être conçues de façon à ne pas empêcher le vissage et le dévissage correct des lampes, même si leurs culots sont légèrement entaillés. En aucun cas les contacts de la douille ne doivent présenter d'arêtes coupantes pour le culot de la lampe.

La conformité est vérifiée par l'essai suivant:

Pour les douilles E27, la vérification doit s'effectuer au moyen d'un calibre conforme à l'édition en vigueur de la feuille de norme 7006-22B de l'IEC 60061-3.

Pour les douilles autres que la douille E27, la conformité doit être vérifiée par examen.

10 Protection contre les chocs électriques

10.1 Les douilles E5, E10, E14 et E27 doivent être conçues de façon que le culot de la lampe ne soit pas accessible lorsqu'il devient actif pendant son insertion.

NOTE 1 Les détails pour la vérification de conformité vis-à-vis de la protection contre les contacts accidentels avec des parties actives pendant l'introduction des douilles E5 et E10 sont à l'étude. En conséquence, les douilles E10 pour une tension assignée supérieure à 60 V peuvent être vendues uniquement aux fabricants de luminaires ou d'autres équipements.

Pour les douilles E10 ayant une tension assignée supérieure à 60 V, la protection contre les chocs électriques est susceptible d'être assurée par des mesures prises sur le luminaire ou un autre équipement dans lequel les douilles sont utilisées.

Les douilles E40 doivent être conçues de façon que le culot de la lampe ne soit pas accessible lorsqu'elles sont vissées à fond.

Les douilles-bougies sont soumises aux essais sans leur partie décorative à moins que l'enlèvement de cette partie ne rende la douille manifestement inutilisable.

La conformité est vérifiée de la manière suivante:

- dans le cas des douilles E10, au moyen de lampes correspondantes et du doigt d'épreuve normalisé, représenté à la Figure 16. Pour les besoins de l'essai, le fabricant de douilles doit fournir les lampes pour lesquelles les douilles sont prévues;
- dans le cas des douilles E14, E27 et E40, au moyen de calibres conformes à l'édition en vigueur des feuilles de norme suivantes de l'IEC 60061-3, à savoir:
 - 7006-31 pour les douilles E14;
 - 7006-22A pour les douilles E27;
 - 7006-24 pour les douilles E40.

NOTE 2 De façon à assurer la protection contre les chocs électriques pendant l'insertion sur des douilles neuves, les essais selon le paragraphe 10.1 sont réalisés avec des spécimens neufs.

10.2 Les parties extérieures des douilles protégées et indépendantes doivent être conçues de telle façon que les parties actives de la douille prête à l'emploi et munie de la lampe correspondante soient inaccessibles.

Les douilles-bougies sont soumises aux essais sans leur partie décorative, à moins que l'enlèvement de cette partie ne rende la douille manifestement inutilisable.

La conformité est vérifiée au moyen du doigt d'épreuve normalisé.

Pour la réalisation de l'essai:

- les douilles protégées sont montées comme en usage normal, par exemple sur un support fileté ou sur une pièce similaire, le cas échéant, et équipées de conducteurs de la section la plus défavorable pour laquelle les douilles sont prévues;
- les douilles indépendantes doivent être montées comme en usage normal sur une surface plane appropriée.

Le doigt d'épreuve normalisé représenté à la Figure 16 est appliqué dans toutes les positions possibles avec une force de 10 N, le contact électrique avec les parties actives étant décelé au moyen d'un indicateur électrique.

Il est recommandé d'utiliser une tension d'au moins 40 V.

NOTE Les douilles non protégées ne sont soumises aux essais qu'après avoir été installées de façon appropriée dans un luminaire ou autre enveloppe supplémentaire.

Pour les douilles E5 et E10 possédant une partie insérable séparée montée dans un manchon extérieur, la partie insérable doit être soumise à une force de traction de 60 N pendant 1 min dans le sens axial.

L'essai doit être effectué manuellement afin de simuler tout défaut d'alignement axial apparaissant normalement en pratique. Il convient que le mouvement de désalignement axial réalisé durant l'essai soit égal à 10° maximum dans toute direction.

Au cours de l'essai, la partie insérable ne doit pas se desserrer au point de rendre les parties actives accessibles par le doigt d'épreuve normalisé.

10.3 Les parties assurant une protection contre un contact accidentel avec le culot de la lampe doivent être convenablement fixées de façon qu'elles ne puissent se détacher lorsqu'une lampe qui aurait été fortement serrée est enlevée, ou par la rotation éventuelle de l'abat-jour.

La conformité est vérifiée par l'essai suivant:

L'assemblage entre le fond et la chemise extérieure est serré d'avance en appliquant un moment de torsion égal aux deux tiers du moment de torsion d'essai spécifié ci-dessous. Les parties appropriées sont alors soumises à un couple de torsion pendant 1 min en appliquant les valeurs d'essai suivantes dans le sens contraire des aiguilles d'une montre:

- 1 Nm pour les douilles E14;
- 2 Nm pour les douilles E27.

La douille est montée comme en usage normal et est soumise à l'essai d'abord avec le culot, puis sans le culot d'essai approprié suivant la Figure 13 (culot d'essai B) ou la Figure 14.

Après l'essai, les parties assurant une protection contre un contact accidentel avec le culot de la lampe ne doivent pas être démontées.

Il ne doit pas être possible de démonter les douilles E5 et E10 sans l'aide d'un outil.

Des exigences pour les douilles E40 (voir la Figure 15) sont à l'étude.

10.4 Lorsque la douille est prévue pour assurer la fixation d'un abat-jour, cette fixation est réalisée par des moyens séparés, tels qu'une bague d'abat-jour; la fixation de celui-ci entre les parties de la douille assurant la protection contre les chocs électriques n'est pas permise.

La conformité est vérifiée par examen.

10.5 Les parties extérieures

- des douilles protégées contre le ruissellement d'eau vertical,
- des douilles à tension assignée supérieure à 250 V,
- des douilles à interrupteur, et
- des douilles E5 et E10

doivent être en matière isolante, à l'exception des entrées taraudées et des parties qui ne peuvent être mises sous tension, même dans l'éventualité d'un défaut.

La laque ou l'émail n'est pas considéré comme une protection adéquate au sens de l'Article 10.

La conformité est vérifiée par examen.

NOTE 1 Les parties qui sont séparées des parties actives par une double isolation ou par une isolation renforcée sont considérées comme des parties qui ne sont pas susceptibles de devenir actives dans l'éventualité d'un défaut.

NOTE 2 Une partie extérieure qui ne peut pas devenir active, même dans l'éventualité d'un défaut, est par exemple une bague d'abat-jour métallique montée à l'extérieur d'une douille en matière isolante.

Les douilles à interrupteur comportant des parties métalliques extérieures sont autorisées sous les conditions de 13.3.

11 Bornes

11.1 Les douilles autres que celles pourvues de fils de raccordement (sortie de fils) doivent être munies de bornes permettant le raccordement de conducteurs ayant les sections nominales suivantes:

- 0,5 mm² à 0,75 mm² pour les douilles E10;
- 0,5 mm² à 1,0 mm² pour les douilles E14 et E27 à entrée taraudée M10×1;
- 0,5 mm² à 2,5 mm² pour les autres douilles E27;

- 1,5 mm² à 4 mm² pour les douilles E40 prévues pour un courant assigné de 16 A;
- 2,5 mm² à 6 mm² pour les douilles E40 prévues pour un courant assigné de 32 A.

La conformité est vérifiée par examen et en raccordant les conducteurs des plus petites et des plus grandes sections spécifiées. Pour les douilles à serre-fils, les douilles E10, E14 ainsi que les douilles E27 à entrée taraudée M10×1, un conducteur à âme câblée est utilisé; dans tous les autres cas, les conducteurs sont à âme massive.

Les douilles à entrée taraudée sont soumises à l'essai dans un conduit fileté.

Les douilles E27 à bornes sans vis destinées à être utilisées seulement par des fabricants de luminaires ou d'autres équipements peuvent ne pas satisfaire aux exigences relatives à toutes les sections nominales appropriées.

11.2 Connexions

11.2.1 Les douilles doivent être pourvues d'au moins un des moyens de connexion suivants:

- bornes à vis;
- bornes sans vis;
- pattes ou broches pour connexions à poussoir;
- broches pour fil enroulé;
- languettes de soudage;
- fils de connexion (sorties).

Les bornes à vis et les écrous doivent avoir un pas de vis métrique conforme à la norme ISO ou un filetage ayant un pas et une résistance mécanique comparables.

Les conducteurs peuvent être connectés par soudage, brasage, sertissage, ou par tout autre moyen équivalent, aux douilles E5, E10 et à toute autre petite douille similaire.

Les douilles à bornes sans vis, à moins qu'elles ne soient prévues pour la vente aux fabricants de luminaires ou d'équipements, doivent être pourvues de bornes pouvant recevoir de manière satisfaisante aussi bien les conducteurs rigides (massifs ou toronnés) que les câbles et conducteurs flexibles.

La conformité est vérifiée par les essais de 11.2.2.

11.2.2 Les bornes doivent satisfaire aux exigences suivantes étant entendu que les exigences relatives au câblage interne concernent le câblage interne aux douilles indépendantes et le câblage interne aux luminaires, lorsqu'il s'agit de douilles à incorporer.

Tous les essais de bornes doivent être exécutés sur des spécimens séparés qui n'ont été soumis auparavant à aucun autre essai:

- *les bornes à serrage sous tête de vis doivent être conformes aux spécifications de 11.3 à 11.6 compris et de 11.8;*
- *les bornes sans vis doivent être conformes à l'Article 15 de l'IEC 60598-1, pourvu que l'essai d'échauffement soit effectué à la température assignée de fonctionnement ± 5 °C;*
- *les pattes ou broches pour connexions à poussoir doivent être conformes à l'Article 15 de l'IEC 60598-1;*
- *les bornes à vis pour fil enroulé doivent être conformes à l'IEC 60352-1. L'enroulement du fil ne s'applique qu'au fil rond, massif, unique, utilisé pour le câblage interne;*
- *les languettes à souder doivent être conformes aux exigences de bonne soudabilité. Les exigences appropriées figurent dans l'IEC 60068-2-20;*

- les fils de raccordement (sorties de fils) doivent être conformes aux exigences spécifiées en 11.10.

11.3 Les bornes doivent être fixées de façon qu'elles ne puissent pas prendre de jeu lors du serrage ou du desserrage des conducteurs.

Pour les bornes à vis, la conformité est vérifiée par examen et en serrant et desserrant 10 fois un conducteur de la plus grande section spécifiée en 11.1, le couple de serrage étant égal aux deux tiers du couple de torsion spécifié à l'Article 14 de l'IEC 60598-1.

NOTE Les bornes peuvent être protégées contre le desserrage par une vis de fixation disposée sans jeu appréciable dans un logement, ou par d'autres dispositifs appropriés. Le surmoulage d'une matière de remplissage sans autre moyen de blocage n'est pas considéré comme suffisant.

11.4 Les bornes à vis doivent être conçues de façon que l'âme du conducteur soit serrée entre deux surfaces métalliques avec une pression de contact suffisante, sans endommager l'âme. Les bornes doivent être conçues de façon que l'âme du conducteur ne puisse pas s'échapper lors du serrage des vis ou des écrous. Elles doivent permettre le raccordement des conducteurs sans préparation spéciale (telle que soudage des brins de l'âme, utilisation de cosses, confection d'œilletons, etc.).

La conformité est vérifiée par examen des conducteurs après le raccordement prévu en 11.1 et après l'essai de 20.3.

NOTE Les âmes sont considérées comme étant endommagées si elles présentent des entailles profondes ou du cisaillement.

11.5 Les bornes à trous doivent avoir des dimensions au moins égales à celles qui sont indiquées dans le Tableau 4.

Tableau 4 – Dimensions minimales des bornes à trous

Douille	Diamètre nominal de la partie filetée mm	Diamètre du trou pour le conducteur mm	Longueur de la partie filetée dans la borne mm
E10	2,5	2,5	1,8
E14	2,5	2,5	1,8
E27	2,5	2,5	1,8
E40	3,5	3,5	2,5
Le diamètre du trou ne doit pas dépasser celui de la vis de plus de 0,6 mm.			

La longueur de la partie filetée de la vis de raccordement doit être au moins égale à la somme du diamètre du trou pour le conducteur et de la longueur de la partie filetée dans le corps de la borne.

NOTE La longueur de la partie filetée d'une borne à trou est mesurée à l'endroit où le filetage est coupé par le trou de la borne.

La conformité est vérifiée par des mesures.

11.6 Les bornes à serrage sous tête de vis doivent avoir des dimensions au moins égales à celles qui sont indiquées dans le Tableau 5.

Tableau 5 – Dimensions minimales des bornes à serrage

Douille	Diamètre nominal de la partie filetée mm	Longueur de la tige de la vis mm	Longueur de la partie filetée dans l'écrou mm	Différence nominale entre les diamètres de la tête et du corps de la vis mm	Hauteur de la tête de la vis mm
E10	2,5	4,0	1,5	2,5	1,4
E14	3,0	5,0	1,5	3,0	1,8
E27	3,5	5,0	1,5	3,5	2,0
E40	4,0	6,0	2,5	4,0	2,4

S'il est interposé entre la tête de la vis et le conducteur une pièce intermédiaire, par exemple une rondelle ou une plaquette de serrage protégée contre la rotation, la différence entre les diamètres de la tête et du corps de la vis peut être réduite de 1 mm.

La conformité est vérifiée par des mesures.

Un écart négatif de 0,15 mm par rapport aux valeurs nominales du diamètre de la partie filetée et de la différence entre les diamètres de la tête et du corps de la vis est admis.

NOTE S'il est nécessaire de démonter la douille pour vérifier la conformité aux exigences de 11.5 et 11.6, cette vérification est effectuée après l'essai de l'Article 18.

11.7 Les bornes doivent être disposées de manière qu'après le raccordement correct des conducteurs, il n'y ait aucun risque de contact accidentel entre les parties actives et les parties métalliques accessibles.

La conformité est vérifiée par examen et par l'essai suivant:

L'enveloppe isolante est enlevée sur une longueur de 4 mm à l'extrémité d'un conducteur souple de la plus faible section nominale spécifiée en 11.1. Un brin de conducteur toronné est décâblé et les autres sont complètement introduits et serrés dans la borne de la douille montée et installée comme en usage normal (vis de serrage serrées, etc.).

Le brin décâblé est plié dans toutes les directions possibles sans déchirer l'enveloppe isolante mais sans former d'angles vifs le long des cloisons.

Le brin décâblé d'un conducteur relié à une borne active ne doit toucher aucune partie métallique qui n'est pas une partie active, et celui d'un conducteur relié à une borne de terre ne doit toucher aucune partie active.

Si nécessaire, l'essai est répété en plaçant le brin décâblé dans une autre position.

NOTE L'interdiction de former des angles vifs le long des cloisons n'implique pas que le brin décâblé reste tendu durant l'essai. Des angles vifs, par contre, sont formés si de tels angles sont considérés comme susceptibles d'apparaître au cours du montage normal de la douille. Voir aussi 13.3.

11.8 Dans le cas de bornes à trou dans lesquelles l'extrémité du conducteur, après raccordement, n'est pas visible, le trou de la borne doit se prolonger au-delà de la vis de raccordement sur une longueur au moins égale à la moitié du diamètre de la vis ou sur une longueur de 2,5 mm, selon la valeur la plus élevée.

La conformité est vérifiée par des mesures.

11.9 Les bornes à montage souple dans la douille ne doivent pas présenter de jeu latéral appréciable, et ne doivent pas se déplacer de plus de 3 mm dans le sens longitudinal lors de l'introduction ou du retrait d'une lampe.

La conformité est vérifiée par des mesures.

11.10 Les exigences de 11.2 à 11.6 inclus et de 11.8 ne s'appliquent pas aux douilles destinées à être montées en usine dans des luminaires et qui sont pourvues de fils de raccordement (sortie de fils).

Les douilles destinées à être montées en usine dans des luminaires ou incorporées dans des équipements peuvent être pourvues de fils de raccordement (sortie de fils), de raccords à connexion par clip ou de moyens d'une efficacité égale.

Les fils de raccordement (sortie de fils) doivent être reliés aux douilles par soudage, brasage, sertissage ou par tout autre moyen au moins équivalent.

Les fils de raccordement doivent être des conducteurs isolés.

L'isolation de l'extrémité libre des conducteurs peut être dénudée.

La fixation des conducteurs dans la douille doit résister aux forces mécaniques pouvant survenir en usage normal.

La conformité est vérifiée par examen et par l'essai suivant, qui est effectué après l'essai de 20.2 sur les trois mêmes spécimens.

Chaque fil de raccordement est soumis à une force de traction de 20 N, la force étant appliquée sans secousses pendant 1 min dans la direction la plus défavorable.

Pendant l'essai, les fils de raccordement en essai ne doivent pas bouger de leur point de fixation.

Après l'essai, les douilles ne doivent présenter aucun endommagement au sens de la présente norme.

12 Dispositions en vue de la mise à la terre

12.1 Les douilles à entrée taraudée, les douilles à serre-fils et les douilles à embase, équipées d'un dispositif de mise à la terre, autres que celles pourvues de conducteurs de sortie, doivent avoir au moins une borne de terre intérieure; d'autres douilles, sans entrée taraudée, par exemple les douilles à incorporer, peuvent être équipées d'un dispositif de mise à la terre extérieur.

La conformité est vérifiée par examen.

NOTE Les douilles destinées à être mises à la terre mais qui ne comportent pas de borne de terre ou de fils de mise à la terre ne sont pas destinées à la vente au détail.

12.2 Les parties métalliques accessibles des douilles de lampes sans borne de terre, qui peuvent devenir actives en cas de défaut d'isolement, doivent permettre une mise à la terre fiable.

Il doit y avoir une continuité de terre entre le fond métallique de la douille et la chemise extérieure, si elle est en métal, lorsque la chemise n'est pas séparée des parties actives par une isolation double ou renforcée.

NOTE Dans le cadre de cette exigence, les petites vis métalliques isolées et celles assurant la fixation des culots ou des habillages ne sont pas considérées comme des parties accessibles qui sont susceptibles de devenir actives en cas de défaut d'isolement.

La conformité est vérifiée par l'essai suivant:

Un conducteur rigide ayant la plus petite section transversale pour laquelle la douille est prévue est monté dans la borne de mise à la terre, dans la mesure où il y en a une.

Lorsque la continuité de terre entre le fond et la chemise extérieure de la douille doit être vérifiée, le raccordement entre ces parties doit être serré avec le couple de torsion spécifié de:

- 1 Nm pour les douilles E14;*
- 2 Nm pour les douilles E27;*
- 4 Nm pour les douilles E40.*

Immédiatement après les essais de 15.3, la résistance entre les moyens de mise à la terre et le fond (ou la chemise extérieure si nécessaire) est mesurée.

Pour les douilles de lampes avec une borne de mise à la terre, le moyen de mise à la terre est le point où le conducteur sort de la borne et pour les douilles de lampes sans borne de terre, c'est le point où la connexion de mise à la terre est destinée à être faite.

Un courant d'au moins 10 A, provenant d'une source avec une tension hors charge ne dépassant pas 12 V, doit traverser la borne de mise à la terre et chacune des parties métalliques accessibles successivement.

La chute de tension entre les moyens de mise à la terre et les parties métalliques accessibles doit être mesurée. La résistance calculée à partir de la chute de tension et du courant ne doit pas dépasser 0,1 Ω .

12.3 Les bornes de terre doivent satisfaire aux exigences de l'Article 11.

Leurs organes de serrage doivent être protégés efficacement contre un desserrage accidentel, et il ne doit pas être possible de desserrer à la main les bornes à vis et de desserrer fortuitement à la main les bornes sans vis.

La conformité est vérifiée par examen et par les essais de l'Article 11.

NOTE En général, les constructions usuelles des bornes transportant le courant (conformes aux exigences de la présente norme) ont une élasticité suffisante pour pouvoir satisfaire à cette dernière exigence; pour d'autres constructions, il peut être nécessaire de prévoir des mesures spéciales telles que l'utilisation d'un élément suffisamment élastique qui ne soit pas susceptible d'être enlevé par inadvertance.

12.4 Le métal des bornes de terre doit être tel qu'il n'y ait pas de risque de corrosion résultant du contact avec le cuivre du conducteur de terre.

La vis ou le corps de la borne de terre doit être en laiton ou en un autre métal résistant aussi bien à la corrosion, tandis que les surfaces de contact doivent être en métal nu.

La conformité est vérifiée par examen.

NOTE Le risque de corrosion est particulièrement grand lorsque le cuivre est en contact avec l'aluminium.

12.5 Les parties métalliques du dispositif d'arrêt de traction et de torsion, y compris les vis de serrage, doivent être isolées du circuit de terre.

La conformité est vérifiée par examen.

13 Construction

13.1 Les douilles doivent avoir un filetage du type Edison pour maintenir la lampe.

Pour les douilles autres que E5 et E10, ce filetage doit être soit métallique et continu sur une longueur non inférieure à celle qui est spécifiée dans l'édition en vigueur de la feuille de norme 7005-20 de l'IEC 60061-2, soit satisfaire aux exigences suivantes.

NOTE L'exigence relative à la longueur minimale du filetage des douilles E5 et E10 est à l'étude.

Une dérogation aux exigences pour filetage métallique est admise pourvu que les tolérances de conception et de fabrication soient telles que l'engagement approprié des calibres soit assuré pendant toute la vie de la douille. D'autres informations à ce sujet seront données dans l'annexe: Essais de surveillance, qui est à l'étude.

De plus, l'ensemble borne/contact et la chemise fileté doivent être construits et positionnés de façon à empêcher toute inclinaison et toute rotation susceptibles de nuire à l'utilisation de la douille.

Une dérogation à l'exigence pour filetage ininterrompu est admise si cela est nécessaire pour obtenir un avantage technique particulier tel qu'un dispositif retenant la lampe logé dans un évidement.

La conformité est vérifiée par examen et par un essai manuel avec les calibres mentionnés à l'Article 8, appliqués dans toutes les positions qui peuvent être atteintes avec un effort raisonnable, et la douille doit encore satisfaire aux essais avec les calibres, en particulier le calibre d'épaisseur de 0,08 mm × 5,0 mm.

De plus, il ne doit pas être possible de rayer le col de l'ampoule d'une lampe conforme aux normes au cours de l'introduction ou de l'enlèvement.

Le filetage mâle de l'adaptateur doit être de même dimension, ou plus grand, que la chemise femelle fileté de l'adaptateur.

13.2 Il doit être prévu un espace adapté pour les conducteurs d'alimentation dans le fond de la douille. Les parties de la douille qui peuvent entrer en contact avec des conducteurs isolés ne doivent pas présenter d'arêtes vives ni de forme susceptible d'endommager l'isolation.

Les douilles à entrée taraudée doivent comporter un dispositif limitant la pénétration du tube dans l'entrée, à moins que, par construction, il soit de toute évidence peu probable que le tube puisse pénétrer trop profondément dans l'entrée, comme c'est le cas pour certaines douilles-bougies.

La conformité est vérifiée par examen et par un essai de montage, en équipant la douille de câbles ou fils souples de la plus grande section spécifiée en 11.1 s'il s'agit de douilles E14 ou de douilles E27 à entrées taraudées M10×1, et de conducteurs d'une section nominale inférieure d'un échelon à la plus grande section spécifiée pour les autres douilles E27 et pour les douilles E40.

Pour les douilles à serre-fils, les douilles E14 et les douilles E27 à entrée taraudée M10×1, un câble souple sous gaine ordinaire est utilisé; dans tous les autres cas, deux ou trois conducteurs isolés au PVC à une seule âme sont utilisés.

Dans le cas de douilles à entrée taraudée, le fond de la douille est vissé sur une longueur de tube de 10 cm environ. Ensuite, les câbles sont introduits dans le tube et dans le fond. Les extrémités des câbles, après une préparation normale, sont raccordées aux bornes de la douille. Dans la mesure du possible, la connexion est effectuée à la partie supportant les bornes dans une position telle que la plus petite distance entre le plan du bord supérieur du

fond et la partie la plus proche des bornes soit de 10 mm. Les bornes étant maintenues dans cette position, les câbles sont serrés et entravés à l'extrémité libre du tube. Puis la douille est assemblée.

Après démontage de la douille, les câbles ne doivent pas être endommagés.

NOTE 1 Pour les douilles E27 et E40, un essai avec les conducteurs de la section maximale spécifiée en 11.1 est à l'étude.

NOTE 2 L'exigence relative aux arêtes vives ne vise pas l'extrémité du filetage de l'entrée taraudée étant donné qu'elles ne sont pas en contact avec les conducteurs quand les douilles ont été montées sur un tube.

En cas de doute concernant le dispositif limitant la pénétration du tube dans l'entrée d'une douille à entrée taraudée, la douille est vissée sur un tube ou une broche en acier, terminé par une section droite plane (arêtes non arrondies). Le tube ou la broche comporte un filet complet ayant les dimensions minimales indiquées aux Figures 1a ou 1b.

Pendant cet essai, le couple de torsion suivant est appliqué pendant 1 min:

- 1,0 Nm pour les entrées taraudées M10×1;
- 1,3 Nm pour les entrées taraudées M13×1;
- 1,6 Nm pour les entrées taraudées M16×1 et G3/8A.

Après cet essai, le tube ou la broche ne doit pas avoir pénétré dans l'espace prévu dans le fond de la douille pour les conducteurs d'alimentation, et la douille ne doit présenter aucune détérioration qui nuirait à son emploi ultérieur.

13.3 Les parties accessibles des douilles à interrupteur doivent être en matière isolante, à moins que, par sa construction, un conducteur sous tension sorti de sa borne ne puisse entrer en contact avec des parties métalliques accessibles ou avec le circuit de terre et que les vis des bornes ou de l'entrée taraudée, après desserrage accidentel, ne puissent ponter des parties métalliques accessibles, y compris les bornes de terre, et des parties actives.

La conformité est vérifiée par examen.

NOTE Cette exigence n'implique pas la présence obligatoire d'un revêtement isolant complet ou partiel.

13.4 Dans le cas de douilles à chemise métallique filetée et à chemise métallique extérieure, le contact entre ces parties doit être empêché par une bague d'isolement qui ne doit pouvoir être séparée manuellement ni des parties actives ni de la chemise métallique extérieure.

La conformité est vérifiée par examen.

NOTE La protection assurée par la bague d'isolement est considérée comme suffisante si la longueur est approximativement égale à celle de la chemise filetée.

13.5 Il doit être possible de bloquer l'entrée taraudée des douilles sur le tube. De tels dispositifs peuvent soit faire partie de la douille soit être prévus dans la conception du luminaire.

Sauf pour les douilles à angles, le dispositif de blocage doit pouvoir être manœuvré de l'intérieur, s'il fait partie de la douille.

Si un dispositif de blocage est prévu dans la conception du luminaire, son efficacité ne peut pas être vérifiée lors de l'essai de la douille; cette vérification doit être effectuée lors des essais pratiqués sur le luminaire.

NOTE De telles douilles ne sont pas destinées à la vente au détail.

Cette exigence ne s'applique pas aux douilles E5 et E10.

La conformité est vérifiée par examen et, pour les douilles ayant un dispositif de blocage intégré, par l'essai de 16.4.

13.6 Les douilles à serre-fils et toutes les douilles destinées au branchement en chaîne doivent comporter un dispositif permettant la fixation de la douille à un conducteur souple de façon que les extrémités des conducteurs dans les bornes ne soient soumises à aucun effort de traction ni de torsion et que le revêtement extérieur du conducteur soit serré à l'intérieur de la douille et protégé contre l'abrasion. La façon de réaliser la protection contre la traction et la torsion doit être facile à reconnaître.

Il ne doit pas être possible d'enfoncer le câble souple dans la douille au point que le câble soit soumis à des efforts mécaniques ou thermiques excessifs.

Le recours à des moyens de fortune, par exemple le procédé qui consiste à faire un nœud dans le câble ou à l'attacher avec une ficelle, n'est pas autorisé.

Le dispositif doit être en matière isolante ou muni d'un revêtement fixe isolant dans le cas où un défaut d'isolation du câble pourrait rendre actives les parties métalliques accessibles.

La construction doit être telle que ce dispositif

- soit au moins une partie fixée à la douille, ou faisant corps avec elle;
- soit approprié aux différents types de câbles souples qui peuvent être connectés à la douille;
- n'exerce aucune force excessive sur le câble;
- ne soit pas susceptible d'être endommagé lorsqu'il est serré ou desserré comme en usage normal.

Le dispositif doit convenir aux types de câbles souples suivants:

- 60245 IEC 51;
- 60245 IEC 53 ou équivalent;
- 60227 IEC 52.

La conformité est vérifiée par examen et par l'essai suivant.

La douille est équipée d'un câble souple et le dispositif d'arrêt de traction et de torsion est utilisé normalement. Les âmes du conducteur sont introduites dans les bornes et les vis sont légèrement serrées de façon que les âmes ne puissent pas se déplacer facilement. Ensuite, il ne doit pas être possible de pousser le câble plus loin dans la douille.

Puis le câble souple est soumis 100 fois, chaque fois pendant 1 s, à un effort de traction dont la valeur est indiquée dans le Tableau 6. L'effort de traction ne doit pas être appliqué par secousses.

Aussitôt après, le câble souple est soumis pendant 1 min à l'effort de torsion spécifié dans le Tableau 6.

Tableau 6 – Valeurs de traction et de torsion

Section nominale totale de l'ensemble des conducteurs mm ²	Traction N	Couple Nm
Jusqu'à 1,5 inclus	60	0,15
Au-dessus de 1,5 à 3 inclus	60	0,25
Au-dessus de 3 à 5 inclus	80	0,35
Au-dessus de 5 à 8 inclus	120	0,35

Les douilles sont soumises aux essais avec chacun des types appropriés de câbles souples, spécifiés ci-dessus, conformes à l'IEC 60245 ou à l'IEC 60227.

L'essai est effectué d'abord avec des conducteurs ayant la plus petite section spécifiée en 11.1 et ensuite avec des conducteurs ayant soit la plus grande section que puisse avoir le dispositif de suspension, soit la plus grande section spécifiée en 11.1, suivant la section la plus petite.

Pour les douilles destinées au branchement en chaîne, l'essai est effectué avec la douille munie des câbles pour lesquels elle a été prévue. Le câble est soumis 50 fois à un effort de traction de 30 N. L'essai de torsion n'est pas effectué.

Le dispositif d'arrêt de traction et de torsion ne doit occasionner aucune détérioration du conducteur souple au cours de cet essai. A l'issue de celui-ci, le conducteur ne doit pas s'être déplacé de plus de 2 mm, et les extrémités ne doivent pas s'être déplacées notablement dans les bornes.

Afin de pouvoir mesurer le déplacement éventuel, une marque est faite sur le conducteur à l'état tendu et à une distance d'environ 2 cm du dispositif d'arrêt de traction. A l'issue de l'essai, le déplacement de la marque par rapport au dispositif d'arrêt de traction est mesuré, le conducteur étant encore soumis à la traction.

13.7 Les dispositifs de suspension des douilles protégées et indépendantes ne doivent comporter aucune partie métallique accessible susceptible de devenir active, même en cas de défectuosité de la douille. Les dispositifs de suspension destinés à être vissés dans les entrées taraudées des douilles doivent, de plus, satisfaire aux exigences de 13.2.

La conformité est vérifiée par examen et par l'essai de 13.6.

13.8 Les douilles à embase, non spécifiquement destinées à être incorporées, doivent avoir un logement pour les conducteurs d'alimentation. Ce logement doit avoir les dimensions minimales suivantes pour permettre l'entrée de câbles sortant d'un tube débouchant perpendiculairement à la surface de montage de la douille:

- hauteur 7 mm;
- longueur égale au diamètre ou à la largeur de l'embase;
- largeur 16 mm portée à 23 mm pour le diamètre de la section circulaire dans la partie centrale.

La conformité est vérifiée par des mesures.

Cette exigence dimensionnelle n'est pas applicable aux douilles E5 et E10.

13.9 L'embase des douilles à embase non spécifiquement destinées à être incorporées doit permettre leur fixation au moyen de vis ayant un diamètre d'au moins 4 mm.

La conformité est vérifiée au moyen d'un calibre conformément à la Figure 3. Pour cet essai, la broche est introduite par l'arrière dans le trou de fixation et elle est coiffée de l'autre côté avec le manchon.

Le manchon doit pénétrer dans le logement prévu pour la tête de la vis.

Cette exigence n'est pas applicable aux douilles E5 et E10.

13.10 Lorsque l'entrée ou les entrées de câbles sont disposées à la surface extérieure accessible d'une douille à embase, ces entrées doivent permettre le passage correct de la gaine des câbles, d'un tube ou d'une canalisation etc., de manière à assurer une protection mécanique sur une distance d'au moins 1 mm mesurée à partir de la surface externe accessible de la douille à embase.

La conformité est vérifiée par mesure et par application de l'essai d'installation de 11.1.

13.11 Les contacts doivent être conçus et réalisés de façon à assurer un contact électrique sûr et fiable en usage normal.

Le fonctionnement des contacts doit être indépendant du fonctionnement d'un dispositif de blocage éventuel entre le fond et la chemise extérieure.

Les nouvelles conceptions de douilles E40 doivent être du type à chemise sous tension.

NOTE Les problèmes de contact avec des culots réels ont montré que le type à chemise sous tension constituait à cet égard la seule solution pratique.

La conformité est vérifiée par examen et par l'essai de 20.2.

Un contact latéral unique est admis.

13.12 Les douilles ne doivent pas être équipées d'un socle de prise de courant.

La conformité est vérifiée par examen.

13.13 Les dispositifs assurant le pontage du filament de la lampe ne doivent pas faire partie intégrante de la douille.

La conformité est vérifiée par examen et, le cas échéant, par un essai.

13.14 Les douilles avec dispositif de frein doivent être capables de résister à un certain couple de desserrage.

Un culot de lampe en laiton disponible dans le commerce, satisfaisant à la norme applicable, doit être inséré dans l'échantillon de douille à dispositif de frein, avec le couple approprié au type de douille, conformément aux indications du Tableau 7.

Tableau 7 – Couple d'insertion

Culot de lampe	Couple Nm
E27	$1,5 \pm 0,1$
E40	$2,0 \pm 0,1$

La lampe est alors dévissée d'environ 30°. Le couple de dévissage est mesuré dans cette position.

Le couple de dévissage ne doit pas être inférieur à la valeur minimale ni supérieur à la valeur maximale indiquée dans le Tableau 8.

Tableau 8 – Couples de dévissage minimal et maximal

Culot de lampe	Couple minimal	Couple maximal
	Nm	Nm
E27	0,5	2,0
E40	1,0	4,0

Lorsque le culot de la lampe est endommagé ou montre des signes d'usure, il convient d'utiliser pour les essais un nouveau culot.

14 Douilles à interrupteur

14.1 Les interrupteurs ne sont autorisés que dans les douilles ordinaires E14 et dans les douilles ordinaires E27 prévues pour une tension jusqu'à 250 V inclus.

La conformité est vérifiée par examen.

14.2 Les douilles à interrupteurs doivent satisfaire aux exigences de construction de 13.3 avec les exigences additionnelles des paragraphes 14.3 à 14.5, ou aux exigences correspondantes de l'IEC 61058-1.

NOTE Des lignes directrices pour la sélection des exigences correspondantes de l'IEC 61058-1 sont données à l'Annexe B.

14.3 Les interrupteurs des douilles doivent être capables d'établir et de couper l'alimentation d'une lampe à filament ou d'une lampe autoballastée d'éclairage général (GLS).

La conformité est vérifiée au moyen des essais suivants:

Les interrupteurs de douilles E14 doivent être soumis aux essais pour une température de fonctionnement de 100 °C et les interrupteurs des douilles E27 pour une température de fonctionnement de 125 °C.

Les interrupteurs des douilles destinées à être utilisées dans les réfrigérateurs ou les congélateurs doivent être soumis aux essais à la température de fonctionnement assignée.

Les interrupteurs des douilles portant un marquage de température doivent être soumis aux essais comme suit pour les températures de fonctionnement:

- *douilles E14: température marquée de la douille moins 40 °C;*
- *douilles E27: température marquée de la douille moins 50 °C.*

L'interrupteur est soumis à l'essai avec un courant alternatif ($\cos \varphi = 0,6 \pm 0,05$), une tension égale à 1,1 fois la tension assignée et un courant égal à 1,25 fois le courant assigné.

L'interrupteur doit être actionné d'une façon normale 200 fois (200 mouvements d'interrupteur) à des intervalles réguliers et au rythme de 30 mouvements par minute.

Ensuite, l'interrupteur est soumis à l'essai avec un courant alternatif ($\cos \varphi = 1$) à la tension assignée et au courant assigné.

L'interrupteur doit alors être actionné d'une façon normale 20 000 fois (20 000 mouvements d'interrupteur) à des intervalles réguliers et au rythme de 30 mouvements par minute.

NOTE Le remplacement de l'essai ci-dessus par l'essai correspondant de l'IEC 61058-1 est à l'étude.

A la fin de l'essai, la douille doit supporter sans défaillance les essais de résistance d'isolement et de rigidité diélectrique spécifiés en 15.4 et doit être en bon ordre de marche.

14.4 Les douilles à interrupteur doivent être construites de façon qu'il ne puisse pas se produire de contact accidentel entre les parties mobiles de l'interrupteur et les conducteurs d'alimentation.

La conformité est vérifiée par l'essai de 11.1 et par un essai manuel.

14.5 L'élément permettant d'actionner l'interrupteur doit être efficacement isolé des parties actives et ne doit pas, s'il est cassé ou endommagé, découvrir des parties actives.

La conformité est vérifiée par examen et par application des essais spécifiés en 14.3.

14.6 Il est admis de soumettre aux essais les interrupteurs de douilles destinées à être utilisées dans les réfrigérateurs ou les congélateurs avec une lampe à la puissance assignée qui correspond aux lampes prévues pour l'appareil.

15 Résistance à l'humidité, résistance d'isolement et rigidité diélectrique

15.1 L'enveloppe des douilles protégées contre le ruissellement d'eau vertical doit garantir le degré nécessaire de protection contre la pénétration d'eau.

La conformité est vérifiée par l'essai suivant.

Les douilles sont équipées des câbles ou des conduits pour lesquels elles ont été conçues.

Les douilles à embase sont montées sur une surface verticale, le trou d'écoulement éventuel étant ouvert et dirigé vers le bas. Les autres douilles sont montées avec leurs entrées de lampe dirigées verticalement vers le bas.

L'essai est réalisé au moyen d'un équipement dont le principe est indiqué à la Figure 3 de l'IEC 60529:1989. Le débit d'eau doit être suffisamment uniforme sur toute la surface de l'appareil et doit produire une chute de pluie comprise entre 3 mm et 5 mm d'eau par minute, tombant verticalement d'une hauteur de 200 mm mesurée depuis la douille. La durée de l'essai est de 10 min. L'eau employée pour l'essai doit être à une température de $15\text{ °C} \pm 10\text{ °C}$.

Immédiatement après ce traitement, la douille doit satisfaire à l'essai de rigidité diélectrique de 15.4 et un examen doit montrer que l'eau n'a pas pénétré en quantité appréciable.

NOTE Il est considéré que l'eau a pénétré en quantité appréciable si elle a atteint des parties actives. Dans ce cas, une chemise filetée qui n'est active que lorsqu'une lampe est introduite n'est pas considérée comme une partie active.

15.2 Les entrées dans les douilles protégées contre le ruissellement d'eau vertical doivent permettre le raccordement des conducteurs d'alimentation de façon que les gouttes d'eau coulant le long des conducteurs ne puissent pas pénétrer à l'intérieur de la douille.

La conformité est vérifiée par examen.

15.3 Les douilles doivent résister aux conditions d'humidité qui peuvent se produire en usage normal.

La conformité est vérifiée par le traitement humide décrit en 15.3, suivi immédiatement de la mesure de la résistance d'isolement et de l'essai de rigidité diélectrique de 15.4.

Les entrées de conducteurs, s'il y en a, sont laissées ouvertes; s'il y a des entrées défonçables, l'une d'elles est défoncée.

Le traitement humide est effectué dans une enceinte humide contenant de l'air d'une humidité relative maintenue entre 91 % et 95 %. La température de l'air, en tout endroit où peuvent être placés les spécimens, est maintenue à 1 °C près à une valeur appropriée t comprise entre 20 °C et 30 °C.

Avant d'être placés dans l'enceinte humide, les spécimens sont portés à une température comprise entre t et $(t + 4)$ °C.

Les douilles sont maintenues dans l'enceinte pendant:

- deux jours (48 h) pour les douilles ordinaires;
- sept jours (168 h) pour les douilles protégées contre le ruissellement d'eau vertical, classées IPX1.

NOTE 1 Dans la plupart des cas, les spécimens peuvent être portés à la température spécifiée en les laissant à cette température pendant 4 h au moins avant le traitement humide.

NOTE 2 L'humidité relative de 91 % à 95 % peut être obtenue en plaçant dans l'enceinte humide une solution saturée de sulfate de sodium (Na_2SO_4) ou de nitrate de potassium (KNO_3) dans l'eau, cette solution ayant une surface de contact avec l'air suffisamment étendue. Afin d'obtenir les conditions imposées pour l'enceinte humide, il est important qu'un brassage constant de l'air à l'intérieur et, en général, qu'une isolation thermique de l'enceinte soient assurés.

A l'issue de ce traitement, les douilles ne doivent présenter aucun endommagement au sens de la présente norme.

15.4 La résistance d'isolement et la rigidité diélectrique doivent avoir une valeur appropriée:

- a) entre parties actives de polarité différente;
- b) entre de telles parties actives et les parties métalliques extérieures, y compris les vis de fixation de la base ou de l'enveloppe des douilles à embase, ainsi que les vis d'assemblage accessibles;
- c) entre les surfaces internes et externes du revêtement intérieur des enveloppes métalliques, si un tel revêtement est exigé conformément à 13.3 pour assurer une protection ou si la distance entre une partie active quelconque et le métal de l'enveloppe est inférieure aux valeurs exigées dans la note de bas de page b du Tableau 13 et du Tableau 14.

La conformité est vérifiée par une mesure de la résistance d'isolement et par un essai de rigidité diélectrique, effectués immédiatement après le traitement humide dans l'enceinte humide ou dans la salle où les spécimens ont été portés à la température prescrite.

La résistance d'isolement est mesurée sous une tension continue de 500 V environ 1 min après l'application de cette tension.

La résistance d'isolement est mesurée successivement:

- a) entre parties actives de polarité différente;
- b) entre de telles parties actives reliées entre elles et la masse;

c) *entre les parties métalliques accessibles et une feuille métallique en contact avec la face interne d'un revêtement isolant intérieur éventuel.*

La désignation «masse» utilisée au point b) couvre les parties métalliques extérieures, les vis de fixation de la base et de l'enveloppe, les vis d'assemblage accessibles et la feuille métallique en contact avec les parties extérieures isolantes.

Les mesures prescrites aux points a) et b) sont d'abord effectuées sur la douille dans laquelle le culot d'essai représenté sur la Figure 11 est introduit et ensuite sur la douille vide.

L'interrupteur éventuel est placé dans la position «fermé».

Si une feuille métallique est utilisée pour l'essai de la douille vide, elle doit également être en contact avec la chemise métallique filetée si celle-ci doit être isolée par rapport aux contacts.

La résistance d'isolement ne doit pas être inférieure à:

- 2 M Ω dans le cas de la mesure prescrite au point a);*
- 4 M Ω dans tous les autres cas.*

Immédiatement après l'essai de résistance d'isolement, une tension alternative pratiquement sinusoïdale, de fréquence 50 Hz ou 60 Hz, ayant une valeur efficace de $(2 U + 1\,000)$ V (U étant la tension assignée) est appliquée pendant 1 min entre les points prescrits. Pour les douilles protégées et non protégées à isolation renforcée, la tension d'essai doit être déterminée à partir du Tableau 10.2 de l'IEC 60598-1. Pour les douilles à interrupteur, cette tension doit, en outre, être appliquée entre des parties actives de polarité différente et les autres parties métalliques, l'interrupteur étant alternativement fermé et ouvert.

La tension appliquée à l'essai de rigidité diélectrique entre des parties actives de polarité différente des douilles E5 et E10 pour une tension assignée inférieure ou égale à 60 V est réduite à 500 V.

Au début, la tension appliquée ne dépasse pas la moitié de la valeur prescrite, puis elle est élevée rapidement à la pleine valeur.

Au cours de l'essai, il ne doit se produire ni contournement ni claquage.

Le transformateur à haute tension utilisé pour l'essai doit être conçu de façon que, lorsque les bornes secondaires sont court-circuitées après que la tension secondaire a été réglée à la tension d'essai appropriée, le courant secondaire soit au moins de 200 mA.

Le relais à maximum de courant ne doit pas se déclencher lorsque le courant secondaire est inférieur à 100 mA.

Des précautions sont prises pour que la valeur efficace de la tension d'essai appliquée soit mesurée à ± 3 %.

Des décharges lumineuses ne coïncidant pas avec une chute de tension ne sont pas retenues.

16 Résistance mécanique

16.1 Les douilles doivent avoir une résistance mécanique appropriée et doivent supporter la contrainte résultant de l'introduction d'une lampe et du vissage de la douille sur un tube.

La conformité est vérifiée par les essais de 16.2 à 16.7.

A l'exception des douilles-bougies, les potences de fixation ou dispositifs similaires destinés au montage ou à la fixation des douilles ne sont pas couverts par les exigences de l'Article 16. La résistance mécanique de dispositifs de ce type doit satisfaire aux exigences de la norme relative à l'équipement pour lequel la douille est destinée.

16.2 La résistance mécanique de la chemise extérieure, de la chemise filetée et du fond est vérifiée en appliquant au culot d'essai (voir les Figures 13, 14 et 15) le couple de torsion suivant pendant 1 min:

- 0,3 Nm pour les douilles E5;
- 0,3 Nm pour les douilles E10;
- 0,5 Nm pour les douilles-bougies E14, si la douille est maintenue par l'entrée taraudée;
- 1,2 Nm pour les douilles-bougies E14, si la douille est maintenue par la chemise extérieure;
- 1,2 Nm pour les autres douilles E14;
- 2 Nm pour les douilles E27;
- 4 Nm pour les douilles E40.

Les dimensions du culot d'essai sont indiquées dans le Tableau 9.

Tableau 9 – Dimensions des culots d'essai

Douille	Dimension S ^a mm	Diamètre du contact central mm
E14	5,5	4,8
E27	9,5	9,5
E40	11,0	14,0
^a Pour la signification de la dimension S, voir les Figures 13, 14 ou 15.		

Les dimensions des culots d'essai des douilles E5 et E10 sont à l'étude. Pour le moment, l'essai est effectué avec un culot ayant les mêmes dimensions que le culot de la lampe pour laquelle la douille a été prévue.

L'essai est effectué deux fois: la première fois, le spécimen est maintenu par la chemise extérieure et la deuxième fois par l'entrée taraudée, le fond ou l'embase, suivant le type de douille.

A l'issue de l'essai, le spécimen ne doit présenter aucune modification susceptible de nuire à son emploi normal.

16.3 Le fond ou l'embase du spécimen est maintenu fixe et le couple de torsion indiqué en 16.2 est appliqué pendant 1 min à la chemise extérieure dans le sens du vissage de la chemise sur le fond.

Cet essai ne doit provoquer aucun desserrage de l'assemblage de la chemise extérieure et du fond, ni aucune autre détérioration.

Cet essai n'est pas applicable aux douilles E5 et E10.

16.4 Le fond des douilles à entrée taraudée est vissé sur un tube en laiton comme en usage normal, les vis d'arrêt étant serrées avec un couple égal aux valeurs indiquées dans le Tableau 12. Le blocage de l'entrée filetée est vérifié en appliquant, pendant 1 min, le couple de torsion indiqué en 16.2, mais dans le sens contraire des aiguilles d'une montre.

Sous l'application de ce couple de torsion, il ne doit pas se produire de desserrage de l'entrée taraudée sur le tube de laiton.

Toutefois, si l'entrée taraudée se desserre, la vis d'arrêt est serrée davantage en appliquant le couple de torsion minimal nécessaire pour empêcher le desserrage de l'entrée taraudée pendant cet essai, et cette valeur minimale est enregistrée.

NOTE Pour des raisons pratiques, il est possible d'accroître le couple de torsion au cours de cet essai par étapes de 20 % environ.

La valeur minimale du couple de torsion appliqué est enregistrée pour les besoins de l'essai de 17.1.

Il est recommandé d'utiliser, pour les essais de 16.2 à 16.4, un appareil conforme à la Figure 6.

16.5 La résistance mécanique de l'assemblage entre le fond et l'entrée taraudée est vérifiée comme indiqué à la Figure 12.

Le spécimen est fixé par son entrée taraudée en position horizontale. Un mandrin fileté aux dimensions maximales admissibles de l'IEC pour les culots de lampes, et dont les autres dimensions sont indiquées sur la Figure 12, est vissé dans la douille. Il est ensuite chargé pendant 1 min avec une masse dont la valeur est indiquée à la Figure 12. La flexion de l'extrémité du mandrin ne doit pas être supérieure à 5 mm.

Le spécimen ne doit pas être endommagé. S'il se produit une déformation permanente, le spécimen est remis à l'état initial et l'essai est répété cinq fois, à la suite de quoi le spécimen ne doit présenter aucune détérioration nuisible à son emploi normal.

Cet essai n'est pas destiné aux douilles-bougies.

16.6 La résistance mécanique de la chemise extérieure en matière isolante, avec ou sans surface extérieure conductrice, ainsi que celle des bagues en matière isolante entre la chemise filetée et les parties extérieures des douilles métalliques est contrôlée au moyen de l'essai au marteau pendulaire spécifié dans l'IEC 60068-2-75 (voir la Figure 8), assujetti aux détails suivants (voir 3.9 de l'IEC 60068-2-75:2014).

a) Mode de montage:

Le spécimen doit être maintenu contre la feuille du contreplaqué du dispositif de montage de telle façon que son axe soit horizontal et parallèle au support et que son rebord touche le contreplaqué.

NOTE Pour les douilles n'ayant pas une forme cylindrique, il est possible d'obtenir la condition du parallélisme de l'axe par rapport à la feuille de contreplaqué par l'usage de cales en bois de pin appropriées.

b) Hauteur de chute:

La pièce de frappe doit tomber de l'une des hauteurs indiquées dans le Tableau 10.

Tableau 10 – Hauteurs de chute

Matériau	Hauteur de chute mm
Parties en céramique	100 ± 1
Parties d'un autre matériau	150 ± 1,5

Cependant, si les douilles en forme de bougie sont soumises aux essais sans le recouvrement décoratif, elles doivent être soumises aux essais avec une hauteur de chute de 100 mm.

c) Nombre d'impacts:

Quatre coups doivent être appliqués à des points également répartis sur la circonférence du rebord extérieur de la chemise et de la bague.

Pour les douilles en matériau isolant, la chemise extérieure doit être heurtée sur le rebord extérieur. Pour les douilles métalliques, la chemise extérieure doit être heurtée sur la bague isolante au point se trouvant entre la chemise filetée et l'extérieur.

Pour les douilles en forme de bougie, tel que prescrit en b), un coup doit être appliqué en deux endroits à 90° sur la circonférence. Les coups doivent être appliqués à 5 mm du rebord extérieur de la douille.

d) *Préconditionnement:*

Ne s'applique pas.

e) *Mesures initiales:*

Ne s'applique pas.

f) *Positions du spécimen et points d'impact:*

Voir c) ci-dessus.

g) *Mode opératoire et contrôle fonctionnel:*

L'échantillon ne doit pas être en fonctionnement lors de l'impact.

h) *Critères d'acceptation ou de refus:*

Après l'essai, l'échantillon ne doit présenter aucun dommage important au sens de la présente norme et particulièrement,

1) *les parties actives ne doivent pas être devenues accessibles.*

Les dommages causés à la douille qui ne réduisent pas les lignes de fuite ou les distances dans l'air au-dessous des valeurs spécifiées à l'Article 18 et les petits éclats qui n'affectent pas défavorablement la protection contre les chocs électriques et la pénétration de l'eau ne doivent pas être pris en compte;

2) *les fissures non visibles à l'œil nu et les fissures superficielles des moulages renforcés de fibres ou de matériau similaire ne doivent pas être prises en compte.*

Les fissures ou trous sur la surface extérieure d'une partie quelconque de la douille ne doivent pas être pris en compte si la douille est conforme à la présente norme, même si cette partie est omise.

i) *Reprise:*

Ne s'applique pas.

j) *Mesures finales:*

Voir h) ci-dessus.

La résistance mécanique des douilles E5 et E10 doit être vérifiée au moyen de l'essai de chute libre spécifié dans l'IEC 60068-2-32:1975.

Les douilles E5 ou E10 doivent résister, sans subir aucun dommage qui puisse affecter la sécurité, à 50 chutes de 500 mm sur une plaque en acier de 3 mm d'épaisseur dans le tonneau rotatif (voir la Figure 7) à 5 r/min (ce qui équivaut à 10 chutes par minute).

NOTE Il est possible de vérifier que la résistance mécanique des douilles utilisées dans les luminaires ou autres équipements au moyen du marteau à ressort spécifié dans l'IEC 60068-2-75. Dans l'IEC 60598-1, l'énergie d'impact utilisée varie de 0,2 Nm à 0,7 Nm en fonction du matériau du composant et du type de luminaire.

De plus, pour les douilles équipées avec un écran enclenchable extérieur, les essais suivants sont réalisés.

Une force de traction et de poussée dans le sens de l'axe de la douille est appliquée pendant 1 min à l'écran extérieur au moyen d'une masse de 5 kg.

Après cet essai, l'écran extérieur doit rester dans sa position prévue.

De plus, il ne doit pas être possible d'enlever la chemise extérieure en utilisant le doigt d'épreuve normalisé appliqué dans toutes les positions possibles avec une force de 30 N.

16.7 *Pour les douilles métalliques, la résistance mécanique des parties métalliques extérieures (chemise extérieure et fond) est vérifiée au moyen de l'appareil représenté à la Figure 9.*

Les différentes parties de la douille sont soumises à l'essai, la douille étant assemblée. Chaque partie est soumise deux fois pendant 1 min à un effort de compression dont la valeur est indiquée dans le Tableau 11 et qui est appliqué sur deux diamètres perpendiculaires l'un par rapport à l'autre. L'essai n'est pas effectué sur les chemises extérieures ni sur les fonds en matière isolante ayant une surface extérieure conductrice.

Pendant et après l'essai, les déformations du spécimen ne doivent pas dépasser les valeurs indiquées dans le Tableau 11.

Tableau 11 – Valeurs de déformation maximales

Douille	Effort N	Déformation maximale	
		Pendant l'essai mm	Après l'essai mm
E14	75	1	0,3
E27	100	2	0,3
E40	100	4	0,5

Cet essai n'est pas applicable aux douilles E5 et E10, ni aux petites douilles similaires.

16.8 Les entrées et les presse-étoupe doivent résister aux contraintes mécaniques survenant pendant un montage et un usage normaux.

La conformité est vérifiée par l'essai suivant.

Les presse-étoupe sont munis d'une broche métallique cylindrique d'un diamètre égal au nombre entier, en millimètres, le plus proche au-dessous du diamètre intérieur de la bague d'étanchéité. Ensuite les presse-étoupe sont serrés à l'aide d'une clé appropriée avec application, pendant 1 min, d'une force de 30 N pour les presse-étoupe métalliques et de 20 N pour les presse-étoupe en matière moulée, avec un bras de levier de 25 cm.

A l'issue de l'essai, les presse-étoupe, les entrées et les enveloppes ne doivent pas présenter de détériorations.

16.9 Les douilles à embase doivent être conçues pour pouvoir subir, sans détérioration, leur fixation sur un support.

La conformité est vérifiée par l'essai suivant:

L'embase de la douille est fixée, au moyen de vis de 4 mm, sur une tôle d'acier rigide et plane. Deux trous taraudés, disposés à une distance égale à celle qui sépare les axes des deux trous de fixation de l'embase, sont pratiqués dans ce morceau de tôle. Les vis sont serrées progressivement, le couple maximal appliqué étant de 1,2 Nm.

L'embase de la douille doit être fixée sur une tôle d'acier rigide et plane au moyen de vis ayant les dimensions suivantes:

- vis de 3 mm pour les douilles E10;
- vis de 4 mm pour les douilles autres que E10.

Les vis doivent être serrées progressivement, le couple maximal appliqué étant de

- 0,5 Nm pour les vis de 3 mm, et*
- 1,2 Nm pour les vis de 4 mm.*

Ces exigences ne sont pas applicables aux douilles E5.

Dans le cas de douilles à embase spécifiquement prévues pour être incorporées, l'essai est effectué avec les moyens de fixation indiqués par le fabricant.

Après cet essai, la douille à embase ne doit présenter aucune détérioration susceptible de nuire à son emploi ultérieur.

17 Vis, parties transportant le courant et connexions

17.1 Les connexions à vis ou mécaniques dont la défaillance peut mettre en cause la sécurité de la douille doivent résister aux contraintes mécaniques survenant en usage normal.

La conformité est vérifiée par examen et par l'essai suivant.

NOTE 1 Les connexions à vis ont été déjà vérifiées partiellement par les essais de l'Article 16.

Les vis et les écrous susceptibles d'être manœuvrés lors du raccordement des conducteurs aux douilles sont serrés et desserrés

- cinq fois quand les vis s'engagent dans un écrou métallique;*
- dix fois quand les vis s'engagent dans un écrou en matière isolante*

à l'aide d'un tournevis d'essai approprié en appliquant un couple de torsion suivant le Tableau 12, sauf pour les vis d'arrêt serrées avec un couple de torsion accru au cours de l'essai de 16.4 quand ce couple de torsion accru est appliqué. La colonne 1 s'applique aux vis sans tête qui, à l'état serré, ne font pas saillie par rapport au trou. La colonne 2 s'applique aux autres vis. Les vis s'engageant dans un écrou en matière isolante sont à chaque fois complètement retirées et engagées de nouveau.

L'essai ne doit occasionner aucune détérioration qui nuirait à l'emploi ultérieur des connexions à vis.

Tableau 12 – Valeurs de torsion

Diamètre nominal de la vis mm	Couple de torsion Nm	
	1	2
Jusqu'à 2,8 inclus	0,2	0,4
Au-dessus de 2,8 à 3,0 inclus	0,25	0,5
Au-dessus de 3,0 à 3,2 inclus	0,3	0,6
Au-dessus de 3,2 à 3,6 inclus	0,4	0,8
Au-dessus de 3,6 à 4,1 inclus	0,7	1,2
Au-dessus de 4,1 à 4,7 inclus	0,8	1,8
Au-dessus de 4,7 à 5,3 inclus	0,8	2,0
Au-dessus de 5,3 à 6,0 inclus	–	2,5
Au-dessus de 6,0 à 8,0 inclus	–	8,0
Au-dessus de 8,0 à 10,0 inclus	–	17,0
Au-dessus de 10,0 à 12,0 inclus	–	29,0
Au-dessus de 12,0 à 14,0 inclus	–	48,0
Au-dessus de 14,0 à 16,0 inclus	–	114,0

NOTE La colonne 1 s'applique aux vis sans tête qui, à l'état serré, ne font pas saillie par rapport au trou. La colonne 2 s'applique aux autres vis.

NOTE 2 Les vis susceptibles d'être manœuvrées lors du raccordement des conducteurs aux douilles comprennent, par exemple, les vis de fixation des enveloppes lorsqu'elles doivent être desserrées pour permettre les connexions, etc. Ne sont pas compris les assemblages réalisés au moyen de filetages à tubes et les vis de fixation de douilles sur leurs supports.

La forme de la lame du tournevis d'essai doit être adaptée à la dimension de la fente de la vis en essai. La vis ne doit pas être vissée par secousses.

17.2 Dans le cas de vis s'engageant dans un écrou en matière isolante, la longueur minimale de la partie filetée doit être au moins égale à 3 mm plus le tiers du diamètre nominal de la vis, mais il n'est pas nécessaire que cette longueur soit supérieure à 8 mm.

Une introduction correcte de la vis dans l'écrou doit être assurée.

La conformité est vérifiée par examen, par des mesures et par un essai manuel.

NOTE L'exigence concernant l'introduction correcte de la vis est remplie si l'introduction en biais est évitée, par exemple au moyen d'un guidage prévu sur la partie à fixer, par un évasement de l'écrou ou par l'emploi d'une vis dont le début du filet a été enlevé.

17.3 Les connexions électriques doivent être conçues de façon que la pression de contact ne se transmette pas par l'intermédiaire de matières isolantes autres que la céramique, sauf si un retrait éventuel de la matière isolante est compensé par une élasticité suffisante des parties métalliques.

Les vis ne doivent pas être en métal mou ou susceptible de se désagréger, comme le zinc ou l'aluminium.

Les vis transmettant la pression de contact et les vis ayant un diamètre nominal inférieur à 3 mm pouvant être manœuvrées lors du raccordement des conducteurs aux douilles doivent se visser dans des écrous métalliques ou dans un taraudage métallique; les vis de blocage font exception à cette règle.

La conformité est vérifiée par examen.

17.4 Les vis et les rivets utilisés à la fois pour des connexions électriques et mécaniques doivent être protégés contre le desserrage.

La conformité est vérifiée par examen et par un essai manuel.

NOTE 1 Des rondelles élastiques peuvent constituer une protection suffisante. Dans le cas de rivets, une tige non circulaire ou une entaille appropriée peut constituer une protection suffisante.

NOTE 2 L'utilisation de matière de remplissage qui se ramollit sous l'influence de la chaleur ne garantit un blocage satisfaisant que pour les connexions à vis qui ne sont pas soumises à des efforts de torsion en usage normal.

17.5 Les parties transportant le courant doivent être constituées de cuivre, d'un alliage contenant au moins 50 % de cuivre ou d'une matière ayant des propriétés au moins égales.

Cette exigence ne s'applique pas aux vis qui ne contribuent pas essentiellement au transport du courant, telles que les vis des bornes.

La conformité est vérifiée par examen et, si nécessaire, par analyse chimique.

Les essais des Articles 19 et 22 montreront si les parties transportant le courant sont équivalentes au cuivre que l'on peut trouver en service normal en ce qui concerne l'aptitude au transport du courant, la résistance mécanique et la résistance à la corrosion.

Il convient de prendre les mesures nécessaires pour éviter la corrosion et maintenir les propriétés mécaniques.

18 Lignes de fuite et distances dans l'air

18.1 Les lignes de fuite et les distances dans l'air ne doivent pas être inférieures aux valeurs indiquées dans les Tableaux 13a et 13b, la douille étant montée comme en usage normal et une lampe y étant introduite ou retirée.

Le contact central du culot de la lampe doit avoir un diamètre de

- 2,4 mm pour les douilles E5;
- 3,8 mm pour les douilles E10;
- 5,5 mm pour les douilles E14;
- 10,5 mm pour les douilles E27;
- 16,0 mm pour les douilles E40.

Les mouvements d'une partie quelconque à montage souple doivent être limités de façon que les lignes de fuite et les distances dans l'air ne puissent prendre des valeurs inférieures à celles qui sont spécifiées.

Les distances indiquées dans le Tableau 13a concernent la catégorie de résistance aux chocs II, les distances indiquées dans le Tableau 13b concernent la catégorie de résistance aux chocs III selon l'IEC 60664-1. Les deux tableaux se réfèrent au degré de pollution 2, pour lequel normalement seule une pollution non conductrice se manifeste, qui est occasionnellement conductrice en cas de condensation.

NOTE 1 L'IEC 60664-1 donne des informations sur les distances des autres catégories de résistance aux chocs et des degrés de pollution plus élevés.

L'attention est attirée sur le fait que les valeurs de lignes de fuite et distances dans l'air qui sont données dans l'Article 18 correspondent aux valeurs strictement minimales.

NOTE 2 Les tensions indiquées dans les Tableaux 13a et 13b sont des tensions assignées et non des tensions d'amorçage.

**Tableau 13a – Distances minimales pour les tensions sinusoïdales ~~alternatives~~
(50/60 Hz) en courant alternatif jusqu'à 30 kHz – Catégorie de résistance aux chocs II**

Distances mm	Tension assignée V			
	50	150	250	500 ^b
1—Entre parties actives de polarité différente, et 2—Entre parties actives et parties métalliques externes, si elles ne sont pas couvertes de matériau isolant: (cela inclut les vis des douilles à embase) Isolation principale — Lignes de fuite: isolation — IRC ≥ 600^a — 0,6 — 0,8 — 1,5 — 3 — IRC < 600^a — 1,2 — 1,6 — 2,5 — 5 — Distances dans l'air^b — 0,2 — 0,8 — 1,5 — 3 Isolation renforcée — Lignes de fuite: isolation — IRC ≥ 600^a — — 1,6 — 3 — 6 — IRC < 600^a — — 3,2 — 5 — 6 — Distances dans l'air — — 1,6 — 3 — 6				
3—Distances dans l'air pour les douilles à embase^c — entre parties actives de polarité différente, et — entre parties actives et les limites de l'espace prévu pour les fils d'alimentation dans les douilles à embase qui ne sont pas spécifiquement destinées à être encastrées:	0,6	0,8	1,5	3
^a—IRC signifie Indice de Résistance au Cheminement, selon l'IEC 60112:2003/AMD1:2009. — Dans le cas de lignes de fuite vers des parties non alimentées ou non prévues pour être mises à la terre, où aucun cheminement ne peut se produire, les valeurs spécifiées pour les matériaux à IRC ≥ 600 s'appliquent à tous les matériaux (quel que soit l'IRC réel). — Pour les lignes de fuite soumises à des tensions de travail de durée inférieure à 60 s, les valeurs spécifiées pour les matériaux à IRC ≥ 600 s'appliquent à tous les matériaux. — Pour les lignes de fuite non sujettes à contamination par la poussière ou l'humidité, les valeurs spécifiées pour les matériaux d'IRC ≥ 600 s'appliquent (quel que soit l'IRC réel). ^b— La distance dans l'air entre les parties actives et la chemise filetée non active dans une douille vide (lampe dévissée) ne doit pas être inférieure à 2 mm. ^c— Ces valeurs tiennent compte des irrégularités éventuelles de la surface de montage. NOTE Les valeurs des lignes de fuite et distances dans l'air sont susceptibles d'être déterminées par interpolation linéaire des valeurs du tableau pour les valeurs intermédiaires des tensions assignées. Aucune valeur n'est spécifiée pour les tensions assignées inférieures à 25 V car l'essai de tension de 15,4 est considéré comme suffisant.				

Distances mm	Tension assignée V			
	50	150	250	500 ^d
Isolation de base 1 Distances entre parties actives de polarité différente, entre les parties actives et la chemise fileté non active, et 2 Distances entre les parties actives et les parties métalliques externes, les surfaces de montage, les enveloppes métalliques non fixées, le cas échéant, la surface extérieure des parties en matériau isolant fixées en permanence à la douille ^a , y compris les vis ou les dispositifs de fixation des enveloppes ou de fixation de la douille à son support: – Lignes de fuite isolation IRC ≥ 600 ^b IRC < 600 ^b – Distances dans l'air ^{c d}				
	0,6	0,8	1,5	3
	1,2	1,6	2,5	5
	0,2	0,5	1,5	3
Isolation renforcée Distances entre les parties actives et les parties métalliques externes, les surfaces de montage, les enveloppes métalliques non fixées, le cas échéant, la surface extérieure des parties en matériau isolant fixées en permanence à la douille ^a , y compris les vis ou les dispositifs de fixation de la douille à son support: – Lignes de fuite isolation IRC ≥ 600 ^b IRC < 600 ^b – Distances dans l'air ^c				
	–	1,6	3	5,5
	–	3,2	5	10
	0,4	1,6	3	5,5
Il est admis que les valeurs des lignes de fuite soient déterminées par interpolation linéaire des valeurs du tableau pour les valeurs intermédiaires des tensions assignées. Aucune valeur n'est spécifiée pour les tensions assignées inférieures à 25 V en courant alternatif et 60 V en courant continu lisse car l'essai de tension de 15.4 est considéré comme suffisant. Les lignes de fuite ne doivent pas être inférieures à la distance dans l'air minimale exigée. Pour le verre, les céramiques et d'autres matériaux isolants inorganiques qui ne sont pas sujets au cheminement, les lignes de fuite ne nécessitent pas d'être supérieures aux distances d'isolement associées dans le cadre de la coordination de l'isolement. Les dimensions de ce tableau sont appropriées. Au Japon, les valeurs indiquées dans le tableau ne sont pas applicables. Le Japon exige des valeurs supérieures aux valeurs données dans le tableau.				
^a Les distances entre les contacts sous tension et la face de la douille (plan de référence) doivent cependant être conformes aux feuilles de norme correspondantes de l'IEC 60061-2. ^b IRC (Indice de Résistance au Cheminement) selon l'IEC 60112:2003 et l'IEC 60112:2003/AMD1:2009. – Dans le cas de lignes de fuite vers des parties non alimentées ou non prévues pour être mises à la terre, ou aucun cheminement ne peut se produire, les valeurs spécifiées pour les matériaux à IRC ≥ 600 s'appliquent à tous les matériaux (quel que soit l'IRC réel). – Pour les lignes de fuite soumises à des tensions de service de durée inférieure à 60 s, les valeurs spécifiées pour les matériaux à IRC ≥ 600 s'appliquent à tous les matériaux. – Pour les lignes de fuite non sujettes à contamination par la poussière ou l'humidité, les valeurs spécifiées pour les matériaux d'IRC ≥ 600 s'appliquent (quel que soit l'IRC réel). – Pour les lignes de fuite, la tension continue équivalente est égale à la valeur efficace de la tension alternative sinusoïdale. ^c Pour les distances dans l'air, la tension continue équivalente est égale à la valeur crête de la tension alternative. ^d Les distances dans l'air entre les parties actives et une chemise fileté métallique non active dans une douille vide (lampe dévissée) peuvent être réduites à 2 mm.				

**Tableau 13b – Distances minimales pour les tensions sinusoïdales ~~alternatives~~
(50/60 Hz) en courant alternatif jusqu'à 30 kHz – Catégorie de résistance aux chocs III**

Distances mm	Tension assignée V			
	50	150	250	500 ^b
1 Lignes de fuite et distances dans l'air entre les parties actives de polarité différente	0,6	0,8	1,5	3
2 Entre parties actives et parties métalliques externes non couvertes d'un matériau isolant: (cela inclut les vis des douilles à embase)				
— Lignes de fuite:				
isolation IRC ≥ 600 ^a	0,6	1,5	3	4
IRC < 600 ^a	1,2	1,6	3	5
— Distances dans l'air ^b	0,2	1,5	3	4
3 Distances dans l'air pour les douilles à embase ^c				
— entre parties actives de polarité différente, et				
— entre parties actives et les limites de l'espace prévu pour les fils d'alimentation dans les douilles à embases qui ne sont pas spécifiquement destinées à être encastrées:	0,6	1,5	3	4
IRC signifie Indice de Résistance au Cheminement, selon l'IEC 60142:2003/AMD1:2009. ^a Dans le cas de lignes de fuite vers des parties non alimentées ou non prévues pour être mises à la terre, où aucun cheminement ne peut se produire, les valeurs spécifiées pour les matériaux à IRC ≥ 600 s'appliquent à tous les matériaux (quel que soit l'IRC réel). — Pour les lignes de fuite soumises à des tensions de travail de durée inférieure à 60 s, les valeurs spécifiées pour les matériaux à IRC ≥ 600 s'appliquent à tous les matériaux. — Pour les lignes de fuite non sujettes à contamination par la poussière ou l'humidité, les valeurs spécifiées pour les matériaux d'IRC ≥ 600 s'appliquent (quel que soit l'IRC réel). ^b La distance dans l'air entre les parties actives et la chemise filetée non active dans une douille vide (lampe dévissée) ne doit pas être inférieure à 2 mm. ^c Ces valeurs tiennent compte des irrégularités éventuelles de la surface de montage. NOTE Les valeurs des lignes de fuite et distances dans l'air sont susceptibles d'être déterminées par interpolation linéaire des valeurs du tableau pour les valeurs intermédiaires des tensions assignées. Aucune valeur n'est spécifiée pour les tensions assignées inférieures à 25 V car l'essai de tension de 15.4 est considéré comme suffisant.				

Distances mm	Tension assignée V			
	50	150	250	500 ^d
Isolation de base				
1 Distances entre parties actives de polarité différente et entre les parties actives et la chemise fileté non active – Lignes de fuite isolation IRC ≥ 600 ^b IRC < 600 ^b – Distances dans l'air ^{c d}				
	0,6	0,8	1,5	3
	1,2	1,6	2,5	5
	0,2	0,5	1,5	3
2 Distances entre les parties actives et les parties métalliques externes, les surfaces de montage, les enveloppes métalliques non fixées, le cas échéant, la surface extérieure des parties en matériau isolant fixées en permanence à la douille ^a , y compris les vis ou les dispositifs de fixation des enveloppes ou de fixation de la douille à son support: – Lignes de fuite isolation IRC ≥ 600 ^b IRC < 600 ^b – Distances dans l'air ^c				
	0,6	1,5	3	5,5
	1,2	1,6	3	5,5
	0,2	1,5	3	5,5
Isolation renforcée				
Distances entre les parties actives et les parties métalliques externes, les surfaces de montage, les enveloppes métalliques non fixées, le cas échéant, la surface extérieure des parties en matériau isolant fixées en permanence à la douille ^a , y compris les vis ou les dispositifs de fixation des enveloppes ou de fixation de la douille à son support: – Lignes de fuite isolation IRC ≥ 600 ^b IRC < 600 ^b – Distances dans l'air ^c				
	-	3	5,5	8
	-	3,2	5,5	10
	-	3	5,5	8
Il est admis que les valeurs des lignes de fuite soient déterminées par interpolation linéaire des valeurs du tableau pour les valeurs intermédiaires des tensions assignées. Aucune valeur n'est spécifiée pour les tensions assignées inférieures à 25 V en courant alternatif et 60 V en courant continu lisse car l'essai de tension de 15.4 est considéré comme suffisant. Les lignes de fuite ne doivent pas être inférieures à la distance dans l'air minimale exigée. Pour le verre, les céramiques et d'autres matériaux isolants inorganiques qui ne sont pas sujets au cheminement, les lignes de fuite ne nécessitent pas d'être supérieures aux distances d'isolement associées dans le cadre de la coordination de l'isolement. Les dimensions de ce tableau sont appropriées. Au Japon, les valeurs indiquées dans le tableau ne sont pas applicables. Le Japon exige des valeurs supérieures aux valeurs données dans le tableau.				
^a Les distances entre les contacts sous tension et la face de la douille (plan de référence) doivent cependant être conformes aux feuilles de norme correspondantes de l'IEC 60061-2. ^b IRC (Indice de Résistance au Cheminement) selon l'IEC 60112:2003 et l'IEC 60112:2003/AMD1:2009. – Dans le cas de lignes de fuite vers des parties non alimentées ou non prévues pour être mises à la terre, où aucun cheminement ne peut se produire, les valeurs spécifiées pour les matériaux à IRC ≥ 600 s'appliquent à tous les matériaux (quel que soit l'IRC réel). – Pour les lignes de fuite soumises à des tensions de service de durée inférieure à 60 s, les valeurs spécifiées pour les matériaux à IRC ≥ 600 s'appliquent à tous les matériaux. – Pour les lignes de fuite non sujettes à contamination par la poussière ou l'humidité, les valeurs spécifiées pour les matériaux d'IRC ≥ 600 s'appliquent (quel que soit l'IRC réel). – Pour les lignes de fuite, la tension continue équivalente est égale à la valeur efficace de la tension alternative sinusoïdale. ^c Pour les distances dans l'air, la tension continue équivalente est égale à la valeur crête de la tension alternative. ^d Les distances dans l'air entre les parties actives et une chemise fileté métallique non active dans une douille vide (lampe dévissée) peuvent être réduites à 2 mm.				

NOTE 3 Des renseignements sur les valeurs normalisées attribuées aux types spécifiques de douilles sont donnés à l'Article 6.

Les distances dans l'air pour la tension d'amorçage assignée de la douille ne doivent pas être inférieures aux valeurs données dans le Tableau 14.

NOTE 4 Les douilles peuvent être soumises à une tension de service supérieure à la tension assignée dans les conditions suivantes:

- la tension nominale et la catégorie de surtension de la tension d'alimentation ne dépassent pas les valeurs assignées de la douille;
- la tension de service (efficace) et la tension de service de crête répétitive maximale ($\hat{U}_{out}$) figurant respectivement par marquage sur l'appareillage ne spécifient pas une ligne de fuite supérieure à la tension assignée de la douille;
- la tension de service ne spécifie pas de distance dans l'air supérieure à la tension assignée et la tension d'amorçage assignée de la douille.

NOTE 5 Dans le cas d'une combinaison de tension et de fréquence (> 30 kHz) nécessitant des lignes de fuite d'une valeur supérieure à celles exigées dans les Tableaux 13a et 13b, les détails de cette combinaison ($\hat{U}_{out}$ et sa fréquence correspondante f/U_{out}) figurent par marquage sur l'appareillage, voir l'IEC 61347-1:2015, 7.1, point w). Pour plus de détails et pour les valeurs exigées pour les lignes de fuite, voir l'IEC 61347-1:2015, 16.2.

Les dispositifs de blocage métalliques (voir 10.3) destinés à l'assemblage de la chemise extérieure et la calotte sont traités comme suit:

- si le dispositif de blocage fait partie du contact central, les distances dans l'air ~~données au point 1)~~ conformes à la note de bas de tableau "a" des Tableaux 13a et 13b s'appliquent;
- si le dispositif de blocage fait partie du ou des contacts latéraux, la note de bas ~~de page b~~ de tableau "d" des Tableaux 13a et 13b s'applique;
- si le dispositif de blocage est une partie séparée, il ne doit être pris en compte que dans la mesure où il raccourcit une autre distance dont le respect est exigé.

Tableau 14 – Distances minimales pour les tensions d'impulsion ~~non sinusoïdales~~ d'amorçage ou les tensions de crête équivalentes U_p

Tension d'impulsion assignée (crête kV)	2	2,5	3	4	5	6	8
Distances dans l'air minimales (mm)	4	1,5	2	3	4	5,5	8

Tension d'impulsion d'amorçage assignée kV	Distance dans l'air minimale mm	
	Isolation de base	Isolation renforcée
2	1	2,2
2,5	1,5	3
3	2	3,8
4	3	6
5	4	8
6	5,5	10,4
8	8	15

Pour les distances dans l'air soumises à la fois à des tensions sinusoïdales et à des tensions d'impulsion non sinusoïdales, la distance minimale exigée ne doit pas être inférieure à la plus élevée des valeurs dans les Tableaux 13a, 13b ou 14.

Les lignes de fuite ne doivent pas être inférieures à la distance minimale dans l'air exigée.

Les lignes de fuite et les distances dans l'air minimales entre les parties actives de polarités différentes doivent être réduites à 1 mm pour les douilles E5 et à 2 mm (pour IRC < 600) pour les douilles E10 destinées à être utilisées avec des lampes connectées en série (25 V de tension assignée maximale pour les douilles E5 et 60 V pour les douilles E10).

La conformité est vérifiée par des mesures, la douille étant successivement équipée et non équipée de conducteurs d'alimentation de la plus grande section spécifiée en 11.1.

NOTE 6 Les tensions d'impulsions d'amorçage ayant une durée d'impulsion totale > 750 µs ou dont la fréquence est supérieure à f_{crit} peuvent nécessiter des distances dans l'air supérieures alors même que sa valeur crête est inférieure à la tension d'amorçage assignée de la douille. Par conséquent, l'appareillage correspondant porte par marquage l'indication d'une tension de crête équivalente (U_p) directement comparable à la tension d'amorçage assignée de la douille.

18.2 La matière de remplissage ne doit pas dépasser le bord des cavités.

La conformité est vérifiée par examen.

19 Fonctionnement normal

En usage normal, il ne doit se produire ni usure excessive ni aucun autre dommage.

L'isolation et la protection contre un contact accidentel ne doivent pas être affectées de façon notable. Les revêtements intérieurs, les cloisons et pièces analogues doivent avoir une résistance mécanique appropriée et être fixés de façon sûre.

Les échauffements et les vibrations prévisibles en usage normal ne doivent pas provoquer le desserrage des connexions électriques.

La conformité est vérifiée par l'essai suivant.

Le spécimen doit être placé dans un appareil d'essai comme indiqué à la Figure 4. Un culot d'essai correspondant doit être, comme indiqué à la Figure 5, vissé et dévissé 100 fois à une cadence d'environ 15 fois par minute.

La douille doit être fixée par l'entrée taraudée, le fond ou l'embase, selon le type de douille durant la moitié du nombre des opérations, et par la chemise extérieure pendant l'autre moitié.

Le culot d'essai (voir les Figures 13, 14 et 15) est serré avec un couple de torsion de

- 0,4 Nm pour les douilles-bougies E14;
- 1 Nm pour les douilles E14;
- 1,5 Nm pour les douilles E27;
- 3 Nm pour les douilles E40.

À l'issue de l'essai, le spécimen ne doit pas présenter

- d'usure gênant son emploi;
- d'endommagement mettant en cause la protection contre les chocs électriques;
- de desserrage des contacts électriques;
- de desserrage de l'assemblage entre la chemise et le fond;
- de desserrage de la vis de blocage de l'entrée taraudée.

En outre, le spécimen doit satisfaire aux exigences de 9.2 et doit résister à l'essai diélectrique selon 15.4, la tension d'essai étant réduite de 500 V dans chaque cas.

NOTE Le traitement humide, selon l'Article 15, n'est pas répété avant cet essai de tension.

Ces exigences ne sont pas applicables aux douilles E5 et E10.

20 Généralités sur la résistance à la chaleur

20.1 Les douilles doivent être suffisamment résistantes à la chaleur.

La conformité est vérifiée par les essais de 20.2 à 20.4.

20.2

– *Pour les douilles E27:*

La douille est d'abord vérifiée au moyen des calibres conformes à l'édition en cours des feuilles de norme 7006-22C et 7006-22D de l'IEC 60061-3.

Après ces essais, un culot d'essai en acier massif (de préférence en acier inoxydable), conforme à la Figure 14, est vissé dans la douille montée comme pour l'emploi prévu, avec un couple de torsion de 1,5 Nm. La douille portant le culot d'essai est ensuite placée en position verticale, douille en haut (car le poids du culot d'essai ne doit pas porter sur la douille) dans une étuve réglée à une température d'environ 85 °C.

Cette température est portée à 175 °C en 1 h ± 15 min. Pour les douilles intégrées au luminaire, cette température est remplacée par celle mesurée selon les conditions de fonctionnement de 12.4.2 de l'IEC 60598-1, plus 10 K, avec une tolérance de ±5 °C.

Cette température étant atteinte et maintenue, la douille est mise sous tension de manière à être parcourue pendant 48 h par un courant égal au courant assigné de la douille.

Après cette période, la douille est retirée de l'étuve et laissée à refroidir pendant 24 h sans le culot d'essai.

Les essais au moyen des calibres 7006-22C et 7006-22D sont alors répétés.

La douille doit satisfaire de nouveau à ces calibres.

– *Pour les douilles E14:*

Un culot d'essai B en acier massif (de préférence en acier inoxydable) conforme à la Figure 13 est vissé dans une douille-bougie E14 montée comme pour l'emploi prévu, avec un couple de torsion de 0,4 Nm et dans toutes les autres douilles E14 avec un couple de torsion de 1 Nm. La douille portant le culot d'essai B est ensuite placée, en position verticale, douille en haut (car le poids du culot d'essai ne doit pas porter sur la douille), dans une étuve réglée à une température d'environ 70 °C. Cette température est portée à 145 °C en 1 h ± 15 min. Pour les douilles intégrées au luminaire, cette température est remplacée par celle mesurée selon les conditions de fonctionnement de 12.4.2 de l'IEC 60598-1, plus 10 K, avec une tolérance de ±5 °C.

Cette température étant atteinte et maintenue, la douille est mise sous tension de manière à être parcourue pendant 48 h par un courant égal au courant assigné de la douille.

Après cette période, la douille est retirée de l'étuve et laissée à refroidir pendant 24 h sans le culot d'essai.

Un culot d'essai A en laiton massif conforme à la Figure 13 est ensuite vissé dans la douille avec le même couple de torsion et puis dévissé. Cette séquence d'opérations est effectuée 10 fois, puis la résistance de contact entre les bornes de la douille est mesurée.

Cette mesure est effectuée, la douille étant montée dans un circuit alternatif alimenté sous une tension non supérieure à 6 V et débitant un courant égal au courant assigné de la douille; la résistance de contact des douilles à interrupteur est négligée. La résistance de contact mesurée ne doit pas être supérieure à 0,02 Ω.

NOTE 1 Le culot d'essai A est soigneusement nettoyé et poli avant d'être introduit dans la douille en vue de la mesure de la résistance de contact.

– Pour les douilles E27 et E14:

Les douilles à marquage T doivent être soumises aux essais à la température marquée plus 10 °C.

Les douilles prévues pour l'utilisation dans les réfrigérateurs et les congélateurs d'aliments doivent être soumises aux essais à la valeur supérieure de la température de fonctionnement assignée plus 10 °C.

NOTE 2 La valeur de 10 °C est à l'étude et est temporairement alignée sur les exigences actuelles des douilles E27.

Ces exigences ne s'appliquent pas aux douilles E5, E10 et E40.

20.3 Les contacts et les autres parties de la douille transportant le courant doivent être construits de façon qu'il ne se produise pas d'échauffement excessif.

La conformité est vérifiée par l'essai suivant qui doit être effectué immédiatement après l'essai de 20.2 sur la douille aux bornes de laquelle sont montés des conducteurs de la section maximale conformément à 11.1.

Les vis des bornes sont serrées sous un couple de torsion égal aux deux tiers du couple de torsion prescrit en 17.1; la douille est placée l'ouverture en bas et alimentée pendant 1 h par un courant égal à 1,25 fois son courant assigné.

L'échauffement des bornes ne doit pas dépasser 45 K.

Cette température est déterminée au moyen de témoins-fusibles ou de thermocouples, mais pas au moyen de thermomètres.

Pour cet essai, un culot d'essai spécial, représenté à la Figure 11, est utilisé.

Après l'essai, il faut vérifier, comme exigé en 11.4, que les conducteurs ne sont pas endommagés.

NOTE De petites pastilles de cire d'abeille (diamètre 3 mm, température de fusion 65 °C) sont susceptibles d'être utilisées comme témoins-fusibles, à condition que la température ambiante soit égale à 20 °C.

Ces exigences ne sont pas applicables aux douilles E5 et E10 pour une tension assignée inférieure ou égale à 60 V.

20.4 La résistance à la chaleur est ensuite soumise à essai dans une étuve à la température indiquée dans le Tableau 15.

Tableau 15 – Températures dans l'étuve

Douille	Température °C
E10 générale	75
E5 et E10 partie intégrante d'un luminaire ^a	75 ou température mesurée + 15 (prendre la valeur la plus élevée)
E14	170
E27	200
E40	260

^a Pour les douilles E5, E10 et autres douilles de petit format qui font partie intégrante du luminaire, telles que les guirlandes d'illumination des arbres de Noël, la température est mesurée dans le luminaire sur le culot à une distance de 2 mm de la jonction du verre de la lampe avec le culot.

Les douilles à marquage «T» sont soumises à l'essai sous la température marquée, majorée de 35 K.

Les douilles destinées à être utilisées dans des réfrigérateurs et des congélateurs doivent être soumises aux essais:

- a) à la température assignée minimale, et
- b) à la température assignée de fonctionnement majorée de 35 K.

Dans la situation a), la durée de l'essai doit être réduite à 16 h.

Immédiatement après cet essai, la douille doit être soumise à nouveau à l'essai de 16.6.

Un culot d'essai en acier massif (de préférence inoxydable), conforme aux Figures 13 (culot d'essai B), 14 ou 15, est vissé à fond dans la douille. La douille portant le culot d'essai est ensuite placée en position verticale, douille en haut (car le poids du culot ne doit pas porter sur la douille), dans une étuve où règne une température qui est environ la moitié de la valeur spécifiée dans le Tableau 15. La température est alors augmentée jusqu'à la température d'essai exigée en $1\text{ h} \pm 15\text{ min}$. Ensuite, l'essai est poursuivi pendant 168 h sans interruption.

La température d'essai est maintenue avec une tolérance de $\pm 5\text{ K}$.

Au cours de l'essai, les douilles ne doivent subir aucune modification affectant leur emploi ultérieur, en particulier

- la diminution de la protection contre les chocs électriques;
- un desserrage des contacts électriques;
- des fissures, des boursoflures ou des retraits;
- un écoulement de la matière de remplissage.

Le culot d'essai est enlevé de la douille après son refroidissement à une température voisine de la température ambiante.

A l'issue de l'essai, il faut vérifier que les filets Edison ne sont pas déformés. Cet essai est effectué à l'aide des calibres «Entre» suivant l'édition en vigueur des feuilles de normes 7006-25 ou 7006-25A de l'IEC 60061-3, selon le cas.

En outre, la douille doit satisfaire aux essais de résistance mécanique spécifiés en 16.2 et 16.6, le couple de torsion à appliquer étant cependant réduit à 50 % de la valeur originale et la hauteur de chute étant réduite à 5 cm.

La matière de remplissage ne doit pas couler au point de rendre apparentes les parties actives; un simple déplacement de la matière de remplissage n'est cependant pas pris en compte.

Cet essai n'est pas réalisé sur les douilles intégrées.

21 Résistance à la chaleur, au feu et aux courants de cheminement

21.1 Les parties maintenant les contacts et les parties extérieures des douilles en matière isolante et celles ayant une surface extérieure conductrice doivent résister à la chaleur.

Pour les matières autres que la céramique, la conformité est vérifiée par un essai à la bille au moyen de l'appareil représenté à la Figure 10.

Tous les essais exigés par l'Article 21 de la présente norme ne sont pas réalisés sur les douilles qui sont intégrées au luminaire, des essais similaires étant exigés dans l'Article 13 de

l'IEC 60598-1. Toutefois les conditions de fonctionnement de ces essais tiendront compte de celles spécifiques aux douilles et qui sont définies à l'Article 21 de la présente norme.

Pour les douilles E5 et E10, seules les parties maintenant les contacts sont soumises à l'essai à la bille.

La surface de la partie soumise à l'essai est disposée horizontalement et une bille d'acier de 5 mm de diamètre est pressée contre cette surface avec une force de 20 N.

L'essai est effectué dans une étuve à la température indiquée en 20.4, sauf pour les douilles E5 et E10, où la température est de 125 °C.

La charge d'essai et le support sont placés dans l'étuve pendant un temps suffisant pour être stabilisés à la température d'essai avant le début de l'essai.

Avant que la masse d'essai soit appliquée, la partie en essai est placée dans l'étuve pendant une période de 1 h.

Si la surface en essai fléchit, l'aire d'appui de la bille est soutenue. À cette fin et si l'essai ne peut être effectué sur la totalité du spécimen, il est admis d'en découper une partie convenable.

Le spécimen doit avoir une épaisseur minimale de 2,5 mm mais si cette épaisseur n'est pas atteinte, alors deux parties ou même plusieurs sont superposées.

Après 1 h, la bille est retirée du spécimen qui est alors immergé, dans les 10 s qui suivent, dans de l'eau froide pour le refroidir approximativement jusqu'à la température ambiante. Le diamètre de l'empreinte de la bille est mesuré et ne doit pas être supérieur à 2 mm.

NOTE S'il s'agit de surfaces courbes, telles que des chemises des douilles, et si l'empreinte est elliptique, le plus petit axe est mesuré.

~~En cas de doute, la profondeur de l'impression est mesurée et le diamètre ϕ calculé en utilisant la formule: $\phi = 2\sqrt{p(5-p)}$, où p est la profondeur de l'impression.~~

21.2 Les parties extérieures en matière isolante (chemise extérieure, chemise filetée, fond ou embase), qui assurent la protection contre les chocs électriques, de même que les parties en matière isolante (ensemble borne/contact) maintenant les parties actives ou les parties très basse tension (TBT) en position, doivent résister aux flammes et à l'inflammation.

Pour les matières autres que la céramique, la conformité est vérifiée par l'essai de 21.3 ou de 21.4.

Les chemises filetées qui ne sont actives que lorsqu'une lampe est vissée dans la douille ne sont pas considérées comme des parties actives en ce qui concerne cette exigence.

La matière isolante qui maintient les chemises de ce type en position est, par conséquent, vérifiée par l'essai de 21.3.

21.3 Les parties extérieures en matière isolante qui assurent la protection contre les chocs électriques, y compris celles dont la partie externe est conductrice, ainsi que les parties en matériau isolant maintenant les parties TBT en position sont soumises à l'essai au fil incandescent selon l'IEC 60695-2-11:2014, en tenant compte des dispositions suivantes.

- *Le spécimen est une douille complète. Il peut être nécessaire d'enlever certaines parties de la douille pour pouvoir effectuer l'essai; il convient cependant de veiller que les*

conditions d'essai ne soient pas sensiblement différentes des conditions normales d'utilisation.

- *Le spécimen est fixé au chariot et pressé contre l'extrémité du fil incandescent avec une force de 1 N, au centre de la surface en essai et de préférence à au moins 15 mm de son bord supérieur. La pénétration du fil incandescent dans le spécimen est limitée mécaniquement à 7 mm.*

Si le spécimen est trop petit pour permettre l'exécution de l'essai selon les exigences précédentes, l'essai ci-dessus est effectué sur un spécimen séparé du même matériau, constituant un carré de 30 mm × 30 mm et d'une épaisseur égale à l'épaisseur minimale du spécimen.

- *La température de l'extrémité du fil incandescent est de 650 °C.*

Après 30 s, le spécimen est retiré jusqu'à l'interruption du contact avec l'extrémité du fil incandescent. La température et le courant de chauffage du fil incandescent sont constants pendant 1 min avant le début de l'essai. Il convient de veiller à ce que le rayonnement thermique n'affecte pas le spécimen pendant cette période. La température de l'extrémité du fil incandescent est mesurée au moyen d'un thermocouple de fil fin gainé, constitué et étalonné suivant la description de l'IEC 60695-2-11:2014.

- *Toute flamme ou incandescence du spécimen doit disparaître dans les 30 s suivant le retrait du fil incandescent, et aucune goutte enflammée du matériau ne doit mettre le feu à un morceau de papier de soie comme spécifié en 4.187 de l'ISO 4046-4:2002, étalé horizontalement à 200 mm ± 5 mm sous le spécimen.*

21.4 Les parties en matière isolante qui maintiennent les parties actives ou les contacts de lampes TBT en position sont soumises à l'essai au brûleur-aiguille selon l'IEC 60695-11-5, en tenant compte des dispositions suivantes.

- *Le spécimen est une douille complète. Il peut être nécessaire d'enlever certaines parties de la douille pour pouvoir effectuer l'essai (par exemple les contacts, qui pourraient, autrement, masquer la zone soumise à l'essai); il convient cependant de veiller à ce que les conditions d'essai ne soient pas sensiblement différentes des conditions normales d'utilisation.*
- *La flamme d'essai est appliquée au centre de la surface en essai.*
- *La durée de l'application est de 10 s.*
- *Toute flamme auto-entretenue doit s'éteindre dans les 30 s suivant le retrait de la flamme d'essai et aucune goutte enflammée du matériau ne doit mettre le feu à un morceau de papier de soie étalé horizontalement à 200 mm ± 5 mm sous le spécimen.*

NOTE Pour des renseignements complémentaires, voir la feuille explicative, Figure 18.

21.5 Dans le cas des douilles protégées contre le ruissellement d'eau vertical, les parties en matière isolante maintenant des parties actives ou des parties TBT en position, doivent présenter une résistance adéquate au cheminement.

Pour les matériaux autres que les céramiques, le contrôle de la conformité doit s'effectuer par l'essai de résistance au cheminement selon l'IEC 60112:2003/AMD1:2009 en tenant compte des dispositions suivantes.

- *Si le spécimen ne comporte pas de surface plane d'au moins 15 mm × 15 mm, l'essai peut être effectué sur une surface plane de dimensions réduites, pourvu que des gouttes de liquide ne s'écoulent pas du spécimen pendant l'essai.*

Il convient qu'aucun moyen artificiel ne soit cependant utilisé pour retenir le liquide sur la surface. En cas de doute, l'essai peut être effectué sur une plaquette séparée de même matériau ayant les dimensions exigées et fabriquée selon le même procédé.

- *Si l'épaisseur du spécimen est inférieure à 3 mm, il convient d'empiler deux spécimens ou plus, si nécessaire, de façon à obtenir une épaisseur d'au moins 3 mm.*
- *L'essai doit être effectué en trois points du spécimen, ou sur trois spécimens.*

- Les électrodes doivent être en platine, et la solution d'essai A spécifiée en 7.3 de l'IEC 60112:2003/AMD1:2009 doit être utilisée.
- Pour les douilles protégées contre le ruissellement d'eau vertical, le spécimen doit résister sans défaillance à 50 gouttes de solution sous une tension d'essai d'IRC 175.
- Il y a défaillance si un courant égal ou supérieur à 0,5 A circule pendant au moins 2 s le long d'un trajet conducteur formé à la surface du spécimen entre les électrodes et déclenche ainsi le relais de surintensité, ou si le spécimen brûle sans déclencher le relais de surintensité.
- L'Article 9 de l'IEC 60112:2003/AMD1:2009, relatif à la détermination de l'érosion, n'est pas applicable.

22 Protection contre les contraintes résiduelles excessives (fissurations intercrystallines) et contre la rouille

22.1 Les contacts et autres parties en laminé de cuivre ou d'alliage de cuivre dont la défaillance serait susceptible de mettre en cause la sécurité de la douille ne doivent pas subir de dommage du fait de contraintes résiduelles excessives.

La conformité est vérifiée par l'essai suivant.

La surface des spécimens est soigneusement nettoyée, le vernis est enlevé à l'aide d'acétone, la graisse et les empreintes digitales étant enlevées au moyen de white spirit ou d'un produit similaire.

Les spécimens sont placés pendant 24 h dans une enceinte d'essai dont le fond est recouvert d'une solution de chlorure d'ammonium de pH égal à 10 (voir Annexe A pour plus d'informations concernant l'enceinte d'essai, la solution d'essai et la méthode d'essai).

Après ce traitement, les spécimens sont lavés à l'eau courante; 24 h plus tard, les échantillons ne doivent pas présenter de fissures lorsqu'ils sont examinés avec un grossissement optique de 8×.

Les fissures survenues sur des zones très limitées de la chemise extérieure d'une douille métallique, à proximité de l'endroit de fixation de la bague isolante, ne doivent pas être prises en considération.

Afin de ne pas influencer les résultats de l'essai, il convient de manipuler les spécimens avec précaution.

22.2 Les parties en matière ferreuse dont l'oxydation pourrait entraîner une diminution de la sécurité de la douille doivent être protégées convenablement contre la rouille.

La conformité est vérifiée par l'essai suivant.


Les parties en essai sont entièrement dégraissées par immersion pendant 10 min dans un agent dégraissant approprié. Puis elles sont immergées pendant 10 min dans une solution aqueuse à 10 % de chlorure d'ammonium maintenue à une température de 20 °C ± 5 °C.

On les suspend alors pendant 10 min, sans les sécher, mais après en avoir secoué les gouttes, dans une enceinte à atmosphère saturée d'humidité à une température de 20 °C ± 5 °C.

Après avoir été séchées pendant 10 min dans une étuve, à une température de 100 °C ± 5 °C, toute trace de rouille sur les bords aigus et tout film jaunâtre peuvent être éliminés par frottement, et les parties ne doivent montrer sur leurs surfaces aucun signe de rouille.

Pour les petits ressorts hélicoïdaux et organes analogues, et pour les parties en matières ferreuses exposées à l'abrasion, une couche de graisse est considérée comme une protection suffisante contre la rouille.

De telles parties ne sont pas soumises à l'essai.



Profil de base ^a

Profil d'exécution pour l'écrou

Profil d'exécution pour la vis


IEC

Dimensions en millimètres

Désignation	s	Vis					Ecou				
		d		d2		d1	D	D2		D1	
		Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.
M8×1	1	8,000	7,800	7,350	7,238	6,917	8,000	7,462	7,350	7,117	6,917
M10×1	1	10,000	9,800	9,350	9,238	8,917	10,000	9,462	9,350	9,117	8,917
M13×1	1	13,000	12,800	12,350	12,190	11,917	13,000	12,510	12,350	12,117	11,917
M16×1	1	16,000	15,800	15,350	15,190	14,917	16,000	15,510	15,350	15,117	14,917


^a Le profil de base est le profil auquel se rapportent les écarts qui déterminent les dimensions limites du filetage extérieur et du filetage intérieur.

Figure 1a – Filetage des raccords pour douilles de lampes: filetage métrique.
Profil de base et profil d'exécution pour l'écrou et pour la vis



Profil de base ^a

Profil d'exécution pour l'écrou



Profil d'exécution pour la vis

Dimensions en millimètres


Désignation	n ^a	Vis					Ecrou				
		d		d2		d1	D	D2		D1	
		Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.
G3/8A	19	16,662	16,412	15,806	15,681	14,950	16,662	15,931	15,806	15,395	14,50

^a Nombre de filets par pouce.

^a Le profil de base est le profil auquel se rapportent les écarts qui déterminent les dimensions limites du filetage extérieur et du filetage intérieur.

**Figure 1b – Filetage des raccords pour douilles de lampes: filetage ISO au pas du gaz.
Profil de base et profil d'exécution pour l'écrou et pour la vis**

Calibres pour la vis



--- Profil de base (voir Figure 1a)

Calibre "Entre"

Calibre "N'entre pas"


IEC

Dimensions en millimètres

Désignation	s	d		d2		d1		Usure
		Valeur	Tolérance	Valeur	Tolérance	Valeur	Tolérance	
M10×1	1	9,800	+0,004 -0,004	9,350	-0,012 -0,020	8,917	+0,004 -0,004	0,012
M13×1	1	12,800	+0,004 -0,004	12,350	-0,012 -0,020	11,917	+0,004 -0,004	0,012
M16×1	1	15,800	+0,004 -0,004	15,350	-0,012 -0,020	14,917	+0,004 -0,004	0,012

NOTE Les tolérances de la colonne d2 sont positionnées à dessein toutes les deux sur le même côté de la dimension pour sauvegarder un espace libre.

Calibres pour l'écrou



--- Profil de base (voir Figure 1a)

Calibre "Entre"

Calibre "N'entre pas"

IEC


Dimensions en millimètres

Désignation	s	D		D2		D1		Usure
		Valeur	Tolérance	Valeur	Tolérance	Valeur	Tolérance	
M10×1	1	10,000	+0,004 -0,004	9,350	+0,012 +0,020	9,117	+0,004 -0,004	0,012
M13×1	1	13,000	+0,004 -0,004	12,350	+0,012 +0,020	12,117	+0,004 -0,004	0,012
M16×1	1	16,000	+0,004 -0,004	15,350	+0,012 +0,020	15,117	+0,004 -0,004	0,012

NOTE Les tolérances de la colonne D2 sont positionnées à dessein toutes les deux sur le même côté de la dimension pour sauvegarder un espace libre.

Figure 2a – Calibres pour filetage métrique pour raccords de douilles

Calibres pour la vis



— — — Profil de base (voir Figure 1b)

 Calibre "Entre"

 Calibre "N'entre pas"


IEC

Dimensions en millimètres

Désignation	n ^a	d		d2		d1		Usure
			Tolérance		Tolérance		Tolérance	
G3/8A	19	16,412	+0 -0,008	15,806	+0 -0,020	14,950	+0 -0,018	—

^a Nombre de filets par pouce.

Calibres pour l'écrou



— — — Profil de base (voir Figure 1b)

 Calibre "Entre"

 Calibre "N'entre pas"


IEC

Dimensions en millimètres

Désignation	n ^a	D		D2		D1		Usure
			Tolérance		Tolérance		Tolérance	
G3/8A	19	16,662	+0,018 -0,005	15,806	+0,005 +0,028	15,395	+0,008 -0	0,005

^a Nombre de filets par pouce.

Figure 2b – Calibres pour filetage ISO au pas du gaz pour raccords de douilles



Dimensions en millimètres

Référence	Dimension	Tolérance	
		Fabrication	Usure
a	4,1	+0,03 –0,0	+0,0 –0,03
b	8,2	+0,03 –0,0	+0,0 –0,03
c	18	+0,1 –0,1	– –

Figure 3 – Calibre pour les trous de fixation des douilles à embase






Figure 4 – Appareil pour les essais de fonctionnement normal



IEC

Figure 5a – Culot d'essai E14/E27



IEC

Figure 5b – Culot d'essai E40


Matériau: Acier trempé

Les dimensions du filetage du culot d'essai doivent être comprises entre les valeurs maximales et minimales spécifiées pour les culots E14, E27 et E40 sur les feuilles de normes 7004-23, 7004-21 et 7004-24 de l'IEC 60061-1, respectivement.

Dimensions en millimètres

Douille	C	E	G	H	H1	S	T	α	β
E14	–	12	17	4,8	–	4	17	45°	45°
E27	–	23	32	9,5	–	7,7	23	45°	45°
E40	0,5	–	50	14	17	–	35	45°	45°
Tolérance	+0,1 –0,1	–	+0,5 –0,5	+0,1 –0,1	+0,1 –0	+0,1 –0	+0,1 –0,1	+30' –30'	+1° –1°

Figure 5 – Culots d'essai pour l'essai de l'Article 18




Culot d'essai

IEC

Figure 6 – Appareil pour la résistance à la torsion

Dimensions en millimètres (sauf indication contraire)



IEC

Le corps du tambour tournant doit être fabriqué en tôle d'acier de 1,5 mm d'épaisseur.

Les compartiments où stationnent les échantillons entre les chutes successives doivent être recouverts de caoutchouc résistant, de dureté 80 IRHD et les surfaces glissantes de ces mêmes compartiments doivent être faites d'une feuille de plastique laminé³.


Le tambour tournant doit être muni d'une ouverture avec un couvercle en acrylique transparent.

Le pivot du tambour tournant ne doit pas pénétrer dans le tonneau lui-même.

Figure 7 – Tambour tournant

³ Formica® est un exemple de produit approprié disponible sur le marché. Cette information est donnée à l'intention des utilisateurs du présent document et ne signifie nullement que l'IEC approuve ou recommande l'emploi exclusif du produit ainsi désigné.

Dimensions en millimètres




NOTE Cette figure est maintenue dans la présente norme pour information, bien qu'une norme de base existe.

En cas de doute sur le dessin, se référer à l'IEC 60068-2-75.

IEC

Figure 8a – Appareil pour l'essai de choc

Dimensions en millimètres (sauf indication contraire)




IEC

NOTE Cette figure est maintenue dans la présente norme pour information, bien qu'une norme de base existe. En cas de doute sur le dessin, se référer à l'IEC 60068-2-75.


Figure 8b – Support de montage

Figure 8 – Appareil pour l'essai de choc




IEC

Figure 9 – Appareil pour la résistance à la compression



IEC

Figure 10 – Appareil pour l'essai à la bille



Tolérances pour les valeurs sans autre indication:
- jusqu'à y compris 30 mm: $\pm 0,05$;
- au-delà 30 mm: $\pm 0,1$;
- sur les angles: $\pm 30'$.

IEC

^a Le matériau isolant doit être tel que son formage soit aisé, que ses dimensions soient stables et qu'il ait un IRC de 600; le PTFE est par exemple un matériau utilisable.

^b Relatif à la partie en métal seulement et n'est pas applicable pour l'essai du culot E10.
Les dimensions du filetage du culot d'essai doivent être comprises entre les valeurs maximales et minimales spécifiées pour les culots E10, E14, E27 et E40 sur les feuilles de normes 7004-22, 7004-23, 7004-21 et 7004-24 de l'IEC 60061-1, respectivement. Le diamètre intérieur du culot en laiton doit être de 2 mm inférieur à la valeur de la dimension d1 indiquée dans la feuille de norme correspondante. La section droite des conducteurs doit être de 0,75, 1,5, 1,5 et 4,0 mm², respectivement, pour les culots E10, E14, E27 et E40. Les conducteurs doivent être rigides (massifs ou à multibrins).

^c Pour le culot d'essai E14, un chanfrein de 45° est exigé sur la partie cylindrique du calibre.

NOTE Les dimensions pour les culots E5 sont à l'étude.


Dimensions en millimètres

Douille	d	h	B	C1	C2	H	S	E	T min.	K min.	A max.
E10	18	60	6	0,5	2,5	4	—	—	9,5	19	13
E14	38	80	9,5	0,5	3,8	6,2	4,5	12	16	27,2	17,1
E27	38	80	13,5	0,5	4,2	11,5	8,5	23	21,5	28,3	26,1
E40	55	100	25	1	8	18	10 ^a	34 ^a	34	47,8	39

^a Dans le cas des douilles E40, les dimensions S et E sont seulement nécessaires pour la construction des calibres.

Figure 11 – Culot d'essai pour les essais de 15.4 et 20.3

Dimensions en millimètres



IEC

Douille	a	b	G kg
E14	19	100	1
E27	25	100	2
E40	37	140	3

Figure 12 – Appareil pour la résistance à la flexion





Figure 13b – Culot d'essai B

^b Les dimensions du filet sur le culot d'essai B doivent être les valeurs minimales, avec une tolérance de $\pm 0,05$ mm, spécifiées sur la feuille de norme 7004-23 de l'IEC 60061-1.


Figure 13 (1 de 2)

Dimensions en millimètres (sauf indication contraire)

Référence	Dimensions		Tolérances	
	Culot d'essai A	Culot d'essai B	Culot d'essai A	Culot d'essai B
C1	0,5	1,0	+0,0 –0,1	+0,0 –0,1
C2	2,5	3,0	+0,0 –0,1	+0,0 –0,1
D	3,5	–	+0,1 –0,0	–
S	4,5	4,0	+0,06 –0,0	+0,0 –0,06
H1	4,8	4,8	+0,04 –0,04	+0,04 –0,04
H2	6	6	+0,04 –0,04	+0,04 –0,04
B	10	10	+0,04 –0,0	+0,06 –0,0
E	12	12	–	–
β	–	45°	–	+10' –10'

Figure 13 – Culot d'essai A et culot d'essai B pour les douilles E14 (2 de 2)

Dimensions en millimètres (sauf indication contraire)




Référence	Dimension	Tolérance
C1	1,2	+0,0 -0,04
C2	4,2	+0,0 -0,06
D1	5,45	+0,1 -0,0
D2	7,2	+0,1 -0,0
S	7,7	+0,0 -0,04
H1	9,5	+0,04 -0,04
H2	12,5	+0,04 -0,04
B1	18,5	+0,06 -0,0
B2	20	+0,06 -0,0
B3	22	+0,06 -0,0
E	23	–

IEC

^a Les dimensions du filet sur le culot d'essai doivent être les valeurs minimales, avec une tolérance de $\pm 0,05$ mm, spécifiées sur la feuille de norme 7004-21 de l'IEC 60061-1.

Figure 14 – Culot d'essai pour les douilles E27

Dimensions en millimètres (sauf indication contraire)




Référence	Dimension	Tolérance
C1	1,5	+0,0 -0,1
C2	7	+0,0 -0,1
S	9	+0,0 -0,06
H1	14	+0,04 -0,04
H2	19	+0,04 -0,04
B	30	+0,06 -0,0
E ^a	34	–
β	45°	+10' -10'

IEC

^a Les dimensions du filet sur le culot d'essai doivent être les valeurs minimales, avec une tolérance de $\pm 0,05$ mm, spécifiées sur la feuille de norme 7004-24 de l'IEC 60061-1.

Figure 15 – Culot d'essai pour les douilles E40



IEC

Matériau: métal, sauf spécification contraire.

Tolérances des dimensions sans indication de tolérance spécifique:

sur les angles: $0' / -10'$


sur les dimensions linéaires:

- jusqu'à 25 mm: 0/-0,05 mm

- au-dessus de 25 mm: $\pm 0,2$ mm

Les deux articulations doivent permettre un mouvement dans le même plan et le même sens de 90° avec une tolérance de 0° à +10°.

Figure 16 – Doigt d'épreuve normalisé (d'après l'IEC 60529)



IEC


Légende

- 1 ensemble borne/contact
- 2 chemise extérieure
- 3 chemise filetée
- 4 bague d'isolement
- 5 bague support d'abat-jour
- 6 fond
- 7 entrée taraudée

Les dessins sont destinés seulement à montrer les pièces typiques d'une douille; il convient qu'ils ne limitent pas la conception.

^a Dans cet exemple, les parties 2, 3 et 4 sont fixées l'une à l'autre de façon permanente. Dans d'autres constructions, les parties 1 et 3 peuvent former un ensemble intégré.


Figure 17 – Clarification de quelques définitions



IEC

Pour les douilles E14 et E27, une fente d'une largeur de 5 mm est pratiquée afin de permettre l'entrée de l'aiguille et pour assurer la ventilation.

La fente n'est pas exigée pour les douilles E40.



Le dessin de gauche indique comment exécuter l'essai au brûleur-aiguille pour les essais sur la zone du contact latéral (ne s'applique pas aux douilles E40).

Le dessin de droite indique comment exécuter l'essai au brûleur-aiguille pour les essais sur la zone du contact central.

La longueur minimale de l'aiguille est de 35 mm.

Figure 18 – Préparation des spécimens pour l'essai au brûleur-aiguille de 21.4

Annexe A (normative)

Essai de fissuration intercristalline et de corrosion

Dans l'intérêt de la protection environnementale, les exigences suivantes relatives à la solution d'essai, à son volume et au volume du récipient peuvent être modifiées à la discrétion du laboratoire d'essai.

Dans ce cas, il convient que le récipient d'essai contienne un volume entre 500 et 1 000 fois supérieur au volume de l'échantillon et il est recommandé que le volume de la solution d'essai soit tel que le rapport entre le volume du récipient et le volume de la solution se trouve entre 20:1 et 10:1. Toutefois, en cas de doute, les conditions d'essai de l'Article A.1 s'appliquent.

A.1 Enceinte d'essai

Des récipients en verre pouvant être bouchés doivent être utilisés pour l'essai. Ces récipients peuvent être, par exemple, des dessiccateurs ou de simples cuvettes à bord rodé et couvercle. Le volume des récipients doit être d'au moins 10 l.

Un certain rapport entre le volume de l'espace d'essai et le volume de la solution d'essai doit être respecté (de 20:1 à 10:1).

A.2 Solution d'essai

Préparation de 1 l de solution:

Dissoudre 107 g de chlorure d'ammonium (NH_4Cl catégorie réactif) dans environ 0,75 l d'eau distillée ou complètement déminéralisée, et ajouter autant de solution d'hydroxyde de sodium à 30 % (préparée à partir de NaOH , catégorie réactif, et d'eau distillée ou complètement déminéralisée) qu'il est nécessaire pour atteindre le pH 10 à 22 °C. Pour les autres températures, régler cette solution aux valeurs de pH correspondantes indiquées dans le Tableau A.1.

Tableau A.1 – Réglage du pH

Température °C	Solution d'essai pH
22 ± 1	10,0 ± 0,1
25 ± 1	9,9 ± 0,1
27 ± 1	9,8 ± 0,1
30 ± 1	9,7 ± 0,1

Après réglage du pH, ajuster à 1 l avec de l'eau distillée ou complètement déminéralisée. Cela ne modifie plus le pH.

Maintenir la température constante à ±1 °C en toute circonstance durant le réglage du pH. Exécuter les mesures de pH en utilisant un instrument permettant d'effectuer l'ajustement à ±0,02 près.

Les solutions d'essai peuvent être utilisées sur une période prolongée, mais la valeur du pH, qui représente une mesure de la concentration de l'ammoniac dans l'atmosphère de la vapeur, doit être vérifiée au moins toutes les trois semaines et réglée si nécessaire.

A.3 Méthode d'essai

Introduire, de préférence suspendus, les spécimens dans l'armoire d'essai d'une manière telle que la vapeur d'ammoniac puisse agir sans être gênée. Les spécimens ne doivent pas tremper dans la solution d'essai, ni entrer en contact l'un avec l'autre. Les supports ou dispositifs de suspension doivent être faits de matériaux non susceptibles d'être attaqués par la vapeur d'ammoniac, le verre ou la porcelaine, par exemple.

L'essai doit être exécuté à une température constante de (30 ± 1) °C pour exclure la formation d'eau condensée visible, causée par les fluctuations de température, ce qui pourrait fausser très sérieusement les résultats d'essai.

L'armoire d'essai contenant la solution d'essai doit être amenée, avant l'essai, à la température de (30 ± 1) °C. Elle doit ensuite être garnie aussi rapidement que possible des spécimens préalablement chauffés à 30 °C et fermée.

L'instant de la fermeture doit être considéré comme celui du début de l'essai.

Annexe B (informative)

Lignes directrices pour le choix des exigences de l'IEC 61058-1 applicables aux interrupteurs de douilles (voir 14.2)

Les articles et paragraphes mentionnés dans l'Annexe B se réfèrent à l'IEC 61058-1:2000.

6 Caractéristiques assignées

Les paragraphes 6.1 et 6.3 sont applicables avec les limitations suivantes:

6.1 La tension assignée maximale est 250 V.

6.3 Le courant assigné maximal est 2 A.

7.1 Classification des interrupteurs

7.1.1 Selon la nature de l'alimentation

Seul 7.1.1.1 est applicable.

7.1.2 Selon le type de charge à commander par chaque circuit de l'interrupteur

Seul 7.1.2.4, 7.1.2.7 et 7.1.2.8 sont applicables.

7.1.3 Selon la température ambiante

Seul 7.1.3.2 est applicable.

7.1.4 Selon le nombre de cycles de fonctionnement

Seul 7.1.4.4 est applicable.

Pour les douilles à interrupteurs destinées à être utilisées dans les réfrigérateurs ou les congélateurs, le paragraphe 7.1.4.2 s'applique si l'interrupteur est actionné par la porte du réfrigérateur ou du congélateur.

7.1.9 Selon la température du fil incandescent

Seul 7.1.9.1 est applicable.

8 Marquage et documentation

Non applicable; le 13.3 de la présente norme s'applique.

16 Echauffements

16.1 Prescriptions générales

Les interrupteurs des douilles destinées à être utilisées dans les réfrigérateurs ou les congélateurs sont soumis aux essais aux températures assignées de fonctionnement.

20 Distances d'isolement dans l'air, lignes de fuite, isolation solide et revêtements des cartes imprimées rigides équipées

20.2 Lignes de fuite

Le groupe de matériau IIIb n'est pas utilisable.

Pour les douilles à interrupteurs destinées à être utilisées dans les réfrigérateurs ou les congélateurs, la Note 5 est applicable.

IECNORM.COM : Click to view the full PDF of IEC 60238:2016+AMD1:2017+AMD2:2020 CSV

Annexe C (informative)

Lignes directrices relatives aux exigences spécifiques des normes d'appareillage – Appareils électrodomestiques et analogues

Cette norme est basée sur les exigences des normes de la série IEC 60598, relative aux luminaires. Dans le cas d'une application à d'autres appareils (appareils électrodomestiques, par exemple), il convient de respecter les exigences qui s'appliquent aux appareils concernés.

C.1 Liste des normes correspondantes

La liste suivante comporte les références des normes relatives aux appareils auxquels les douilles couvertes par la présente norme peuvent être intégrées, comme l'expérience a permis de le démontrer. Cette liste est une sélection des normes actuelles et ne prétend pas être exhaustive.

Publication	Titre
IEC 60335-1	Appareils électrodomestiques et analogues – Sécurité – Partie 1:Prescriptions générales
IEC 60335-2-6	Appareils électrodomestiques et analogues – Sécurité – Partie 2-6: Règles particulières pour les cuisinières, les tables de cuisson, les fours et appareils fixes analogues
IEC 60335-2-9	Appareils électrodomestiques et analogues – Sécurité – Partie 2-9: Règles particulières pour les grils, les grille-pain et appareils de cuisson mobiles analogues
IEC 60335-2-11	Appareils électrodomestiques et analogues – Sécurité – Partie 2-11 Règles particulières pour les sèche-linge à tambour
IEC 60335-2-24	Appareils électrodomestiques et analogues – Sécurité – Partie 2-24: Règles particulières pour les appareils de réfrigération, les sorbetières et les fabriques de glace
IEC 60335-2-25	Appareils électrodomestiques et analogues – Sécurité – Partie 2-25: Règles particulières pour les fours à micro-ondes, y compris les fours à micro-ondes combinés
IEC 60335-2-27	Appareils électrodomestiques et analogues – Sécurité – Partie 2-27: Règles particulières pour les appareils d'exposition de la peau aux rayonnements ultraviolets et infrarouges
IEC 60335-2-31	Appareils électrodomestiques et analogues – Sécurité – Partie 2-31: Règles particulières pour les hottes de cuisine
IEC 60335-2-36	Appareils électrodomestiques et analogues – Sécurité – Partie 2-36: Règles particulières pour les cuisinières, les fours, les tables de cuisson et les foyers de cuisson électriques à usage collectif
IEC 60335-2-42	Appareils électrodomestiques et analogues – Sécurité – Partie 2-42: Règles particulières pour les fours électriques à convection forcée, les cuiseurs à vapeur électriques et les fours combinés vapeur-convection électriques à usage collectif
IEC 60335-2-43	Appareils électrodomestiques et analogues – Sécurité – Partie 2-43: Règles particulières pour les appareils de séchage du linge et les sèche-serviettes
IEC 60335-2-49	Appareils électrodomestiques et analogues – Sécurité – Partie 2-49: Règles particulières pour les armoires chauffantes électriques à usage collectif
IEC 60335-2-59	Appareils électrodomestiques et analogues – Sécurité – Partie 2-59: Règles particulières pour les appareils destructeurs d'insectes
IEC 60335-2-99	Appareils électrodomestiques et analogues – Sécurité – Partie 2-99: Règles particulières pour les hottes de cuisine électriques à usage commercial

C.2 Références des exigences spécifiques

C.2.1 IEC 60335-1:2001

Article 8 – Protection contre l'accès aux parties actives

Article 11 – Echauffements

Tableau 3 – Echauffements normaux maximaux

Article 24 – Composants

Les paragraphes 24.1, 24.1.3 et 24.1.6 s'appliquent.

Article 29 – Distances dans l'air, lignes de fuite et isolation solide

Les exigences concernant la résistance aux courants de cheminement sont données en 29.2.

Les exigences concernant l'épaisseur de l'isolation solide sont données en 29.3.

Article 30 – Résistance à la chaleur et au feu

Annexe E (normative) – Essai au brûleur-aiguille

Annexe H (normative) – Interrupteurs

Annexe N (normative) – Essai de tenue au cheminement

Annexe O (informative) – Sélection et séquence des essais de l'Article 30

C.2.2 IEC 60335-2-24:2002

Article 7 – Marquage et instructions

Il n'y a pas d'exigences de marquage particulières pour les douilles dans l'Article 7 de l'IEC 60335-2-24:2002. Cependant, l'exigence suivante est considérée comme essentielle:

Dans le cas de douilles destinées à être utilisées dans les compartiments réfrigérés des réfrigérateurs et des congélateurs, la température minimale assignée à laquelle la douille peut être soumise doit être marquée sur la douille (–30 °C par exemple).

Article 8 – Protection contre l'accès aux parties actives

Article 24 – Composants

Les exigences particulières pour les interrupteurs de portes sont données en 24.1.3.

Article 29 – Distances dans l'air, lignes de fuite et isolation solide

Les exigences concernant la résistance aux courants de cheminement sont données en 29.2:

Pour les douilles destinées à être utilisées dans les compartiments réfrigérés des réfrigérateurs et des congélateurs, l'échantillon doit supporter 50 gouttes sans présenter de défaut à une tension d'IRC 250.

Annexe D (informative)

~~Liste des paragraphes amendés incluant des exigences plus strictes/critiques qui nécessitent la réalisation de nouveaux essais sur les produits~~

Articles contenant des exigences nouvelles ou plus contraignantes par rapport à l'édition précédente

La liste des articles donnée dans l'Annexe D détaille les exigences de ~~cette neuvième édition~~ cet Amendement 1 de l'IEC 60238 :2016 qui ~~nécessitent~~ peut nécessiter la réalisation de nouveaux essais pour démontrer la conformité à la présente norme mise à jour. La réalisation de nouveaux essais peut ne pas être nécessaire dans les cas où l'examen des précédents résultats d'essai confirme la conformité.

- a) ~~Paragraphe 10.2: Exigences supplémentaires concernant la réalisation d'essais de traction pour les douilles E5 et E10 possédant une partie insérable séparée montée dans un manchon extérieur (douilles bougies)~~

Article 18: Mise à jour des lignes de fuite et distances dans l'air pour les fréquences supérieures à 30 kHz et ajout de U_{out} de l'appareillage

Bibliographie

IEC 60061 (toutes les parties), *Culots de lampes et douilles ainsi que calibres pour le contrôle de l'interchangeabilité et de la sécurité*

IEC 60061-4, *Culots de lampes et douilles ainsi que calibres pour le contrôle de l'interchangeabilité et de la sécurité – Partie 4: Guide et information générale*

IEC 60068-2-20, *Essais d'environnement – Partie 2-20: Essais – Essai T: Méthodes d'essai de la brasabilité et de la résistance à la chaleur de brasage des dispositifs à broches*

IEC 60335-1:2010, *Appareils électrodomestiques et analogues – Sécurité – Partie 1: Prescriptions générales*

IEC 60598 (toutes les parties), *Luminaires*

IEC 60664-1, *Coordination de l'isolement des matériels dans les systèmes (réseaux) à basse tension – Partie 1: Principes, exigences et essais*

IEC 60664-4:2005, *Coordination de l'isolement des matériels dans les systèmes (réseaux) à basse tension – Partie 4: Considérations sur les contraintes de tension à haute fréquence*

IEC 60695-2-10, *Essais relatifs aux risques du feu – Partie 2-10: Essais au fil incandescent/chauffant – Appareillage et méthode commune d'essai*

IEC 61347-1:2015, *Appareillages de lampes – Partie 1: Exigences générales et exigences de sécurité*

FINAL VERSION

VERSION FINALE



Edison screw lampholders

Douilles à vis edison pour lampes

IECNORM.COM : Click to view the full PDF of IEC 60238:2016+AMD1:2017+AMD2:2020 CSV

CONTENTS

FOREWORD	4
INTRODUCTION to Amendment 2	6
1 Scope	7
2 Normative references	8
3 Terms and definitions	9
4 General requirement.....	14
5 General conditions for tests	14
6 Standard ratings	15
7 Classification	16
8 Marking	17
9 Dimensions.....	19
10 Protection against electric shock	22
11 Terminals	24
12 Provision for earthing	28
13 Construction	29
14 Switched lampholders.....	34
15 Moisture resistance, insulation resistance and electric strength	35
16 Mechanical strength	37
17 Screws, current-carrying parts and connections.....	41
18 Creepage distances and clearances	43
19 Normal operation	48
20 General resistance to heat.....	49
21 Resistance to heat, fire and tracking.....	52
22 Resistance to excessive residual stresses (season cracking) and to rusting	54
Annex A (normative) Season cracking/corrosion test	75
Annex B (informative) Guidance for requirements in IEC 61058-1 applicable to switches in lampholders (see 14.2)	77
Annex C (informative) Guidance for special requirements in appliance standards – Household and similar electrical appliances	79
Annex D (informative) Clauses containing new or more stringent requirements with respect to the previous edition	81
Bibliography.....	82
Figure 1a –Nipple thread for lampholders: metric thread. Basic profile and design profile for the nut and for the screw.....	55
Figure 1b –Nipple thread for lampholders: ISO standard pipe thread. Basic profile and design profile for the nut and for the screw	56
Figure 2a – Gauges for metric thread for nipples	57
Figure 2b – Gauges for ISO standard pipe thread for nipples	58
Figure 3 – Gauge for holes for backplate lampholder screws	59
Figure 4 – Normal operation test apparatus	60
Figure 5 – Test caps for the test of Clause 18.....	61
Figure 6 – Torque apparatus.....	62

Figure 7 – Tumbling barrel	63
Figure 8 – Impact-test apparatus	64
Figure 9 – Pressure apparatus	65
Figure 10 – Ball-pressure test apparatus	65
Figure 11 – Test cap for the tests of 15.4 and 20.3	66
Figure 12 – Bending apparatus	67
Figure 13 – Test cap A and test cap B for lampholders E14 (2 of 2)	69
Figure 14 – Test cap for lampholders E27	70
Figure 15 – Test cap for lampholders E40	71
Figure 16 – Standard test finger (according to IEC 60529)	72
Figure 17 – Clarification of some definitions	73
Figure 18 – Preparation of specimens for the needle-flame test of 21.4	74
Table 1 – Thickness of screw shells and contacts	20
Table 2 – Minimum effective screw lengths	21
Table 3 – Dimensions of threaded entries and set screws	22
Table 4 – Minimum dimensions of pillar-type terminals	26
Table 5 – Minimum dimensions of screw-type terminals	26
Table 6 – Pull and torque values	32
Table 7 – Insertion torque	34
Table 8 – Minimum and maximum removal torques	34
Table 9 – Test cap dimensions	38
Table 10 – Heights of fall	39
Table 11 – Maximum deformation values	41
Table 12 – Torque values	42
Table 13a – Minimum distances for AC sinusoidal voltages up to 30 kHz – Impulse withstand category II	45
Table 13b – Minimum distances for AC sinusoidal voltages up to 30 kHz – Impulse withstand category III	46
Table 14 – Minimum distances for ignition pulse voltages or equivalent peak voltages Up	48
Table 15 – Heating cabinet temperatures	51
Table A.1 – pH adjustment	75

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EDISON SCREW LAMPHOLDERS

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendments has been prepared for user convenience.

IEC 60238 edition 9.2 contains the ninth edition (2016-07) [documents 34B/1852/FDIS and 34B/1860/RVD], and its amendment 1 (2017-01) [documents 34B/1887/FDIS and 34B/1892/RVD] and its corrigendum (2018-01), and its amendment 2 (2020-01) [documents 34B/2029/CDV and 34B/2040A/RVC].

This Final version does not show where the technical content is modified by amendments 1 and 2. A separate Redline version with all changes highlighted is available in this publication.

International Standard IEC 60238 has been prepared by subcommittee 34B: Lamp caps and holders, of IEC technical committee 34: Lamps and related equipment.

This ninth edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Addition of a pull test for certain E5 and E10 lampholders.
- b) Annex D listing amended requirements/clauses which require products to be retested.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

In this standard, the following print types are used:

– *compliance statements: in italic type.*

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IECNORM.COM : Click to view the full PDF of IEC 60238:2016+AMD1:2017+AMD2:2020 CSV

INTRODUCTION to Amendment 2

Some changes and corrections needed for IEC 60238 became obvious during the work relating to the consolidated Edition 9.1 of IEC 60238.

Change 1:

Actual lamp holder safety standards require a ball pressure test in line with IEC 60695-10-2 in sections "Resistance to heat, fire and tracking". Within this test there is an alternative depth indentation method described for the calculation of the indentation diameter.

This alternative calculation option was removed from the latest edition of IEC 60695-10-2 dated 2014 and during its meeting held in Sydney in 2018, SC 34B/WG1 agreed to delete the alternative method as well from IEC 60238.

Change 2:

Based on IEC 60664-1:2007, 4.8.1.5 "Non tracking materials":

"For glass, ceramics or other inorganic insulating materials which do not track, creepage distances need not be greater than their associated clearance for the purpose of insulation coordination. The dimensions of Table F.2 for inhomogeneous field conditions are appropriate."

This is not completely reflected in TC 34 standards as revised recently. For applications with ELV it is of high importance whether the creepage distance shall be 0,6 mm or may be 0,2 mm in the case where inorganic insulating material is used.

Correction

In Amendment 1 to IEC 60238 Edition 9, a complete paragraph was deleted by accident. This was corrected with the publication of a corrigendum to Amendment 1, however an editorial correction needs to be made to the references to previous items, changed to table footnotes "a" and "d", as the referenced text was included in Tables 13a and 13b.

EDISON SCREW LAMPHOLDERS

1 Scope

This International Standard applies to lampholders with Edison thread E14, E27 and E40, designed for connection to the supply of lamps and semi-luminaires¹ only.

It also applies to switched-lampholders for use in AC circuits only, where the working voltage does not exceed 250 V r.m.s.

This standard also applies to lampholders with Edison thread E5 designed for connection to the supply mains of series connected lamps, with a working voltage not exceeding 25 V, to be used indoors, and to lampholders with Edison thread E10 designed for connection to the supply mains of series connected lamps, with a working voltage not exceeding 60 V, to be used indoors or outdoors. It also applies to lampholders E10 for building-in, for the connection of single lamps to the supply. These lampholders are not intended for retail sale.

As far as it reasonably applies, this standard also covers lampholders other than lampholders with Edison thread designed for connection of series-connected lamps to the supply.

NOTE This type of lampholder is for example used in Christmas tree lighting chains.

As far as it reasonably applies, this standard also covers adapters.

This standard also covers lampholders which are, wholly or partly, integral with a luminaire or intended to be built into appliances. It covers the requirements for the lampholder only. For all other requirements, such as protection against electric shock in the area of the terminals or of the lamp cap, the requirements of the relevant appliance standard are observed and tested after building into the appropriate equipment, when that equipment is tested according to its own standard. Such lampholders as well as lampholders provided with a snap-on outer shell, for use by luminaire manufacturers only, are not for retail sale.

This standard applies to lampholders to be used indoors or outdoors in residential as well as in industrial lighting installations. It also applies to candle lampholders. In locations where special conditions prevail, as for street lighting, on board ships, in vehicles and in hazardous locations, for example where explosions are liable to occur, special constructions may be required.

This standard does not apply to three-light lampholders E26d.

This standard is based on the following data relative to lamps for general lighting service:

- caps E14 are used for lamps with a current not exceeding 2 A;
- caps E27 are used for lamps with a current not exceeding 4 A;
- caps E40 are used for lamps with a current not exceeding 16 A, or 32 A if the nominal voltage of the supply does not exceed 130 V (see 5.5 and 6.3).

Where lampholders are used in luminaires, their maximum operating temperatures are specified in IEC 60598.

¹ Requirements for lampholders suitable for semi-luminaires are under consideration.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60061-1, *Lamp caps and holders together with gauges for the control of interchangeability and safety – Part 1: Lamp caps*

IEC 60061-2, *Lamp caps and holders together with gauges for the control of interchangeability and safety – Part 2: Lampholders*

IEC 60061-3, *Lamp caps and holders together with gauges for the control of interchangeability and safety – Part 3: Gauges*

IEC 60068-2-32:1975, *Basic environmental testing procedures – Part 2-32: Tests – Test Ed: Free fall*

IEC 60068-2-75:2014, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60112:2003, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*
Amendment 1:2009

IEC 60227 (all parts), *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V*

IEC 60245 (all parts), *Rubber insulated cables – Rated voltages up to and including 450/750 V*

IEC 60352-1:1997, *Solderless connections – Part 1: Wrapped connections – General requirements, test methods and practical guidance*

IEC 60399, *Barrel thread for lampholders with shade holder ring*

IEC 60417, *Graphical symbols for use on equipment* (available at: <http://www.graphical-symbols.info/equipment>)

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*
Amendment 1:1999
Amendment 2:2013²

IEC 60598-1, *Luminaires – Part 1: General requirements and tests*

IEC 60630, *Maximum lamp outlines for incandescent lamps*

IEC 60695-2-11:2014, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products (GWEPT)*

IEC 60695-11-5, *Fire hazard testing – Part 11-5: Test flames – Needle-flame test method – Apparatus, confirmatory test arrangement and guidance*

² A consolidated edition 2.2 (2013) exists including edition 2.0 (1989) and its Amendment 1 (1999) and Amendment 2 (2013).

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

cord-grip lampholder

lampholder incorporating a method of retaining a flexible cord by which it may then be suspended

3.2

threaded entry lampholder

lampholder incorporating a threaded component at the point of entry of the supply wires permitting the lampholder to be mounted on a mating threaded support

Note 1 to entry: A threaded entry lampholder was formerly called a “nipple lampholder”.

3.3

backplate lampholder

lampholder so designed as to be suitable for mounting by means of an associated or integral backplate, directly onto a supporting surface or appropriate box

3.4

lampholder for building-in

lampholder designed to be built into a luminaire, an additional enclosure or the like

3.4.1

unenclosed lampholder

lampholder for building-in so designed that it requires additional means, for example an enclosure, to meet the requirements of this standard with regard to protection against electric shock

3.4.2

enclosed lampholder

lampholder for building-in so designed that on its own it fulfils the requirements of this standard with regard to protection against electric shock and IP classification, if appropriate

3.5

independent lampholder

lampholder so designed that it can be mounted separately from a luminaire and at the same time providing all the necessary protection according to its classification and marking

3.6

terminal/contact assembly

part or assembly of parts which provides a means of connection between the termination of a supply conductor and the contact making surfaces of the corresponding lamp cap

Note 1 to entry: For clarification of some definitions, see also Figure 17.

3.7

outer shell

cylindrical component protecting the user from contact with the lamp cap.

Note 1 to entry: It may or may not be provided with an external screw thread for fixing a shade ring.

Note 2 to entry: For clarification of some definitions, see also Figure 17.

3.7.1

snap-on outer shell

outer shell for screwless assembly which does not contain the screw shell

Note 1 to entry: The lampholder should not be used when the snap-on outer shell is removed. It is therefore recommended to place an approval mark, if provided, in such a way that it is not visible when this type of outer shell is removed.

3.8

screw shell

cylindrical component having an internal screw thread of Edison form for the retention of the corresponding lamp (cap)

Note 1 to entry: In some constructions, the screw shell is permanently fixed to or integral with the outer shell.

Note 2 to entry: For clarification of some definitions, see also Figure 17.

3.9

insulating ring

cylindrical intermediate piece of insulating material separating a metal screw shell and a metal outer shell

Note 1 to entry: For clarification of some definitions, see also Figure 17.

3.10

shade ring

cylindrical component having an internal thread or other means to engage a corresponding support on the outer shell and intended to carry or retain a shade

Note 1 to entry: For clarification of some definitions, see also Figure 17.

3.11

dome

part of a cord-grip lampholder or threaded entry lampholder which shields the connecting terminals

Note 1 to entry: For clarification of some definitions, see also Figure 17.

3.12

basic insulation

insulation applied to live parts to provide basic protection against electric shock

Note 1 to entry: Basic insulation does not necessarily include insulation used exclusively for functional purposes.

3.13

supplementary insulation

independent insulation applied in addition to basic insulation in order to provide protection against electric shock in the event of a failure of basic insulation

3.14

double insulation

insulation comprising both basic insulation and supplementary insulation

3.15

reinforced insulation

single insulation system applied to live parts, which provides a degree of protection against electric shock equivalent to double insulation under the conditions specified

Note 1 to entry: The term "insulation system" does not imply that the insulation is one homogeneous piece. It may comprise several layers which cannot be tested singly as supplementary or basic insulation.

3.16

live part

conductive part which may cause an electric shock

3.17

type test

test or series of tests made on a type test sample, for the purpose of checking compliance of the design of a given product with the requirements of the relevant standard

3.18

type test sample

sample consisting of one or more similar specimens submitted by the manufacturer or responsible vendor for the purpose of a type test

3.19

semi-luminaire

unit similar to a self-ballasted lamp but designed to utilize a replaceable light source and/or starting device

3.20

rated operating temperature

highest temperature for which the holder is designed

3.21

rated minimum temperature

lowest temperature for which the holder is designed (applicable only to lampholders intended for use in refrigerators and food freezers)

3.22

angled lampholder

lampholder, the rear side of which (threaded entry and/or dome) is at an angled position to the screw shell axis

3.23

lampholder with retention device

lampholder with a device intended to prevent the lamp from becoming loose in the holder

Note 1 to entry: Lamps can, for example, become loose due to changes in temperature or to vibrations.

3.24

impulse withstand category

numeral defining a transient overvoltage condition

Note 1 to entry: Impulse withstand categories I, II, III and IV are used.

a) Purpose of classification of impulse withstand categories

Impulse withstand categories are to distinguish different degrees of availability of equipment with regard to required expectations on continuity of service and on an acceptable risk of failure.

By selection of impulse withstand levels of equipment insulation, co-ordination can be achieved in the whole installation, reducing the risk of failure to an acceptable level providing a basis for overvoltage control.

A higher characteristic numeral of an impulse withstand category indicates a higher specific impulse withstand of the equipment and offers a wider choice of methods for overvoltage control.

The concept of impulse withstand category is used for equipment energized directly from the mains.

b) Description of impulse withstand categories

Equipment of impulse withstand category I is equipment which is intended to be connected to the fixed electrical installations of buildings. Protective means are taken outside the equipment – either in the fixed installation or between the fixed installation and the equipment – to limit transient overvoltages to the specific level.

Equipment of impulse withstand category II is equipment to be connected to the fixed electrical installations of buildings.

Equipment of impulse withstand category III is equipment which is part of the fixed electrical installations and other equipment where a higher degree of availability is expected.

Equipment of impulse withstand category IV is for use at or in the proximity of the origin of the electrical installations of buildings upstream of the main distribution board.

3.25

primary circuit

circuit which is directly connected to the AC mains supply

Note 1 to entry: It includes, for example, the means for connection to the AC mains supply, the primary windings of transformers, motors and other loading devices.

3.26

secondary circuit

circuit which has no direct connection to a primary circuit and derives its power from a transformer, converter or equivalent isolation device, or from a battery

Note 1 to entry: Exception: autotransformers. Although having direct connection to a primary circuit, the tapped part of them is also deemed to be a secondary circuit in the sense of this definition.

Note 2 to entry: Mains transients in such a circuit are attenuated by the corresponding primary windings. Also inductive ballasts reduce the mains transient voltage height. Therefore, components located after a primary circuit or after an inductive ballast can be suited for an impulse withstand category of one step lower, i.e. for impulse withstand category II.

3.27

adapter

component used for the electrical and mechanical connection of a lamp to a lampholder

Note 1 to entry: This definition is specific for this standard. The definition of an adapter in principle could vary very much depending on its use. In most cases such a component is used to bridge differences in the screw thread diameter between the lampholder and the lamp.

3.28

enclosed reinforced insulated lampholder

lampholder for building-in so designed that on its own it fulfils the requirements for double or reinforced insulated parts in class II applications

3.29

partly reinforced insulated lampholder

lampholder for building-in so designed that some parts of the lampholder require additional means to fulfil the requirements with regard to double or reinforced insulation

Note 1 to entry: In some cases, the dimensions might be achieved only after mounting into the luminaire.

3.30

rated voltage

voltage declared by the manufacturer to indicate the highest working voltage for which the lampholder is intended

[SOURCE: IEC 60838-1:2016, 3.1]

3.31

working voltage

highest r.m.s. voltage that may occur across any insulation, transients being disregarded, both when the lamp is operating under normal conditions and when the lamp is removed

[SOURCE: IEC 60838-1:2016, 3.2]

3.32

rated current

current declared by the manufacturer to indicate the highest current for which the lampholder is intended

[SOURCE: IEC 60838-1:2016, 3.3]

3.33

critical frequency

f_{crit}

frequency at which the reduction of the breakdown voltage of a clearance begins (occurs)

Note 1 to entry: $f_{\text{crit}} \approx 0,2/d$ [MHz] where d (in mm) is the clearance according to Table 3 (basic or supplementary insulation and reinforced insulation respectively) disregarding the frequency.

[SOURCE: IEC 61347-1:2015, 3.40, modified – the note has been added]

3.34

ignition voltage

peak voltage applied to ignite a discharge lamp

[SOURCE: IEC 61347-1:2015, 3.46]

3.34.1

ignition pulse voltage

peak ignition voltage with a total duration of $\leq 750 \mu\text{s}$ (summation of all pulses durations) within 10 ms, with the duration time (width) of each pulse being measured at the level of 50 % of the maximum absolute peak value

Note 1 to entry: Ignition pulse waveforms, which are considered as ignition pulse voltage, should not contain any dominant frequency above 30 kHz or should be usually highly damped (after 20 μs the peak voltage level should be less than one half of the maximum peak voltage). For the assessment of the dominant frequency IEC 60664-4:2005, Annex E should be consulted.

[SOURCE: IEC 61347-1:2015, 3.46.1]

3.35

rated ignition voltage

highest peak value of an ignition pulse voltage the holder is able to withstand

3.36

maximum working voltage

U_{out}

maximum occurring working voltage (r.m.s.) between the output terminals of a controlgear or between the output terminals and earth, during normal or abnormal operating condition

Note 1 to entry: Transients and ignition voltages have to be neglected.

[SOURCE: IEC 61347-1:2015, 3.33, modified – "of a controlgear" has been added]

3.37

maximum working peak output voltage

$\hat{U}_{\text{out}}$

maximum repetitive occurring peak working voltage between the output terminals of a controlgear or between its output terminals and earth, during normal or abnormal operating condition and with transients neglected

[SOURCE: IEC 61347-1:2015, 3.45, modified – "of a controlgear" has been added]

3.38 equivalent transformed peak voltage

U_p
transformed output peak voltage, which is converted for the worst case peak voltage with its related frequency into an ignition pulse voltage

Note 1 to entry: The value of the declared equivalent transformed output peak voltage is the essential parameter for selecting the associated components.

Note 2 to entry: See 3.34.1.

Note 3 to entry: To determine the declared equivalent transformed output peak voltage for basic insulation U_p [basic] the worst case combination of the maximum occurring peak voltage and frequency has to be taken into account, which means the maximum clearance according to IEC 61347-1:2015, Table 10 for basic insulation.

Note 4 to entry: To determine the declared equivalent transformed output peak voltage for the reinforced insulation U_p [reinforced] the worst case combination of the maximum occurring peak voltage and frequency has to be taken into account, which means the maximum clearance according to IEC 61347-1:2015, Table 11 for reinforced insulation.

[SOURCE: IEC 61347-1:2015, 3.47]

4 General requirement

Lampholders shall be so designed and constructed that in normal use they function reliably and cause no danger to persons or surroundings.

In general, compliance is checked by carrying out all the tests specified.

In addition, the enclosure of independent lampholders shall comply with the requirements of IEC 60598-1, including the classification and marking requirements of that standard.

5 General conditions for tests

5.1 Tests according to this standard are type tests.

NOTE The requirements and tolerances permitted by this standard are related to testing of a type test sample submitted for that purpose.

Compliance of the type test sample does not ensure compliance of the whole production of a manufacturer with this safety standard.

In addition to type testing, conformity of production is the responsibility of the manufacturer and can include routine tests and quality assurance.

For further information on conformity testing during manufacture see IEC 60061-4.

5.2 Unless otherwise specified, the tests are made at an ambient temperature of $20\text{ °C} \pm 5\text{ °C}$ and with the holder tested as delivered and installed as in normal use.

5.3 The tests and inspections are carried out on a total of

- nine specimens for non-switched lampholders, or
- 12 specimens for switched lampholders

in the following order of clauses:

- three specimens: Clauses 2 to 13 (except for 10.1 and 11.2) and Clauses 15 to 18;
- three specimens: Clause 14 (switched-lampholder tests only);
- three specimens: 10.1 and Clauses 19 and 20;

- two specimens: Clause 21 (of which one specimen for the test of 21.1 and the other for the tests of 21.3 or 21.4);
- one specimen: 21.5 and Clause 22.

For testing lampholders with a retention device, the retention device shall be removed.

For testing lampholders with a retention device according to 13.14, three additional specimens are required with the retention device kept in place.

For testing of screwless terminals according to 11.2, separate specimens are required in addition.

5.4 *In case of doubt, gauges, test caps and mandrels are introduced into the specimens, unless otherwise specified, by applying the following torques:*

- 0,2 Nm for lampholders E5;
- 0,2 Nm for lampholders E10;
- 0,2 Nm for lampholders E14;
- 0,4 Nm for lampholders E27;
- 0,8 Nm for lampholders E40.

5.5 *For lampholders E40 with a rated current of 32 A, the tests shall be based on this rated current.*

5.6 *Lampholders are deemed to comply with this standard if no specimen fails in the complete series of tests specified in 5.3.*

If one specimen fails in one test, that test and the preceding ones which may have influenced the result of that test are repeated on another set of specimens to the number required by 5.3, all of which shall then comply with the repeated tests and with the subsequent tests. Lampholders are deemed not to comply with this standard if there are more failures than one.

6 Standard ratings

6.1 Standard rated voltages are 250 V and 500 V.

For lampholders E14, and for switched lampholders E27, a rated voltage of 250 V only is allowed.

For lampholders E5 and E10 intended for the connection of series-connected lamps to the supply, the rated voltage shall not exceed 25 V for lampholders E5 and not exceed 60 V for lampholders E10.

NOTE 1 These values refer to the voltage between parts of different polarity.

For lampholders E10 intended for the connection of single lamps to the supply, a rated voltage of 250 V only is allowed.

NOTE 2 These lampholders are also used for such special cases as series-connected lamps, where, because of the low number of lamps, 60 V per lampholder is exceeded.

With the exception given for lampholders E5 and E10, the rated voltage shall be not less than 250 V. Additionally a rated voltage of 125 V is allowed for lampholders E40.

Compliance is checked by inspection of the marking.

6.2 Standard rated currents are

- 0,2 A for lampholders E5;
- 0,5 A for lampholders E10;
- 2 A for lampholders E14;
- 2 A for switched-lampholders E27;
- 4 A for other lampholders E27;
- 16 A for lampholders E40.

The rated current shall be not less than the standard value.

Compliance is checked by inspection of the marking.

6.3 Lampholders E40 to be used on 125 V installations may have an additional nominal rating of 32 A.

NOTE This nominal rating covers the voltages up to and including 130 V.

Compliance is checked by inspection of the marking.

6.4 The rated operating temperature for lampholders intended for use in high temperature conditions (T marked holders) shall be not lower than 140 °C for lampholders E14, not lower than 170 °C for lampholders E27 and not lower than 230 °C for lampholders E40.

Compliance is checked by inspection of the marking.

NOTE The rated operating temperatures for Edison screw lampholders without T marking are given in IEC 60598-1, Table 12.1. They are

- 135 °C for lampholders E14;
- 165 °C for lampholders E27;
- 225 °C for lampholders E40.

7 Classification

Lampholders are classified as defined in 7.1 to 7.6.

7.1 According to the material of the external parts:

- lampholders of insulating material;
- metal lampholders.

NOTE Lampholders with external parts consisting partly of metal and lampholders comprising external parts of insulating material with a conductive outer surface, for example a metallized outer shell, are considered as metal lampholders (see 13.3). This does not apply to threaded entries and external parts, for example a metal shade ring mounted onto the outside of a lampholder of insulating material, which cannot become live even in the case of an insulation fault. Metal holders with insulating coverings are considered as metal lampholders (see 10.5).

In order to check whether or not a surface is conductive, two stripe-electrodes 1,5 mm wide, 25 mm long and with a distance of 2 mm from each other are applied to the surface (e.g. with silver conductive paint). In accordance with 15.4, the insulating resistance is measured between the stripes. The surface is considered to be conductive if the resistance is less than 5 MΩ.

7.2 According to degree of protection against ingress of water:

- ordinary lampholders;

- drip-proof lampholders.

7.3 According to method of fixing:

- threaded entry lampholders;
- cord-grip lampholders;
- backplate lampholders;
- other lampholders.

NOTE Examples of other lampholders are lampholders provided with a mechanical suspension device, e.g. a hook.

7.4 According to type:

- switched-lampholders, provided with an integral switch to control the supply to the lamp;
- non-switched lampholders.

7.5 According to protection against electric shock:

- unenclosed lampholders;
- enclosed lampholders;
- independent lampholders;
- partly reinforced insulated lampholders;
- enclosed reinforced insulated lampholders.

NOTE Where a lampholder is used with a working voltage of 50 % or less of its maximum rating, it can be regarded as equivalent to a reinforced insulated lampholder.

7.6 According to resistance to heat:

- lampholders for rated operating temperatures up to the limits given in 6.4;
- lampholders for operating in high temperature conditions (T marked holders).

8 Marking

8.1 Lampholders, other than lampholders E5 and E10, shall be marked with the following:

- rated current, in amperes;
- rated voltage, in volts
- rated ignition voltage, in kV, if higher than
 - 2,5 kV for lampholders rated 250 V,
 - 4 kV for lampholders rated 500 V;

If applicable, the rated ignition voltage of the lampholder (in kV) shall be marked either on the lampholder or made available in the manufacturer's catalogue or the like.

NOTE 1 Some lampholders still show rated voltages higher than 500 V. This is an earlier way of expressing the permissible ignition voltage via a rated voltage. For such lampholders, the creepage distances and clearances can be found in IEC 60598-1.

- symbol for nature of current, if required (for switched lampholders only);
- mark of origin (this may take the form of a trade mark, manufacturer's identification mark or the name of the responsible vendor);
- type reference;

Available technical documentation of the manufacturer like printed catalogues or online catalogues should allow a clear identification of a lampholder either by a unique catalogue number or by an identifying reference on the holder, specifying the essential characteristic features and the basic design of the product supplemented by a clear description.

Variations of the basic design like for example different cable length, fixing means, colours etc., which do not affect safety or performance of the lampholder, can be disregarded in the type reference marked on the product. Variations included in the type testing procedure are listed in the corresponding test reports.

- the degree of protection against ingress of water for drip-proof lampholders (see 8.2);
- rated operating temperature "T", indicating the highest operating temperature, if applicable.

The marking of the rated operating temperature is not required for lampholders whose exterior is made wholly of ceramic material. For these lampholders, this information, if applicable, shall either be marked on the lampholder or be made available in the manufacturer's catalogue.

For lampholders according to this standard, the distances for impulse withstand category II are usually applicable. For holders in equipment where a higher degree of availability is expected, distances for impulse withstand category III may be applicable. This information shall be indicated in the manufacturer's catalogue or the like.

Enclosed reinforced insulated lampholders offer an adequate level of protection for use in luminaires where they are accessible in normal use. This information shall be indicated in the manufacturer's catalogue or the like.

For partly reinforced insulated lampholders, sufficient creepage distances and clearances to outer accessible surfaces will require additional protection to some parts of the lampholder by the luminaire design or by use of additional attachment(s) or cover(s). This information shall be indicated in the manufacturer's catalogue or the like.

Lampholders E10 shall be marked with the following:

- rated voltage, in volts;
- mark of origin;
- type reference;

Available technical documentation of the manufacturer like printed catalogues or online catalogues should allow a clear identification of a lampholder either by a unique catalogue number or by an identifying reference on the holder, specifying the essential characteristic features and the basic design of the product supplemented by a clear description. Variations of the basic design like for example different cable length, fixing means, colours etc., which do not affect safety or performance of the lampholder, can be disregarded in the type reference marked on the product. Variations included in the type testing procedure are listed in the corresponding test reports.

- the degree of protection against ingress of water, if applicable.

Lampholders E5 shall be marked with the following:

- mark of origin;
- type reference.

Available technical documentation of the manufacturer like printed catalogues or online catalogues should allow a clear identification of a lampholder either by a unique catalogue number or by an identifying reference on the holder, specifying the essential characteristic features and the basic design of the product supplemented by a clear description. Variations of the basic design like for example different cable length, fixing means, colours etc., which do not affect safety or performance of the lampholder, can be disregarded in the type reference marked on the product. Variations included in the type testing procedure are listed in the corresponding test reports.

Compliance is checked by inspection.

NOTE 2 The type reference for lampholders E10 and E5 can be a catalogue number.

8.2 If symbols are used for current and voltage, A shall denote amperes and V volts.

Alternatively, for volt and ampere ratings, figures may be used alone, the figure for the rated current being marked before or above that for the rated voltage and separated from the latter by an oblique stroke or line.

Therefore the marking of current and voltage may be as follows:

2 A 250 V or 2/250 or $\frac{2}{250}$.

The symbol for direct current shall be --- (IEC 60417-5031:2002-10).

The symbol for protection against ingress of water for drip-proof lampholders shall be IPX1.

NOTE Where X is used in the IP number it indicates a missing numeral in the example, but both the appropriate numerals in accordance with IEC 60529 are marked.

The letter T shall be followed by the value of the rated operating temperature in degrees Celsius.

Compliance is checked by inspection.

8.3 The marking of the degree of protection against ingress of water shall be on the outside of the holder.

Compliance is checked by inspection.

8.4 An earthing terminal shall be indicated by the symbol --- (IEC 60417-5019:2002-10).

This symbol shall not be placed on screws, removable washers or other easily removable parts.

Compliance is checked by inspection.

8.5 Marking shall be durable and easily legible.

Compliance is checked by inspection and, after the tests of Clause 19 have been completed, by trying to remove the marking by rubbing lightly for 15 s with a piece of cloth soaked with water and for a further 15 s with a piece of cloth soaked with petroleum spirit.

After the tests the marking shall be still legible.

NOTE The petroleum spirit used typically consists of a solvent hexane with a content of aromatics of maximum 0,1 volume percentage, a kauri-butanol value of 29, an initial boiling-point of approximately 65 °C, a dry-point of approximately 69 °C and a specific density of approximately 0,68 g/cm³.

9 Dimensions

9.1 Lampholders E10, E14, E27 and E40 shall comply with the current edition of the standard sheets of the IEC 60061 series.

Compliance shall be checked by measuring in conformity with IEC 60061-2, Standard Sheet 7005-20.

The minimum dimensions of the screw thread and dimension X shall be checked by means of gauges according to Standard Sheets 7006-25 (E10, E14 and E40) and 7006-25A (E27), and by means of the gauge according to Standard Sheet 7006-26 of IEC 60061-3.

Lampholders designed with a barrel thread for shade holder rings and shade holder rings shall comply with IEC 60399.

Compliance is checked by means of the gauges given in IEC 60399.

9.2 Lampholders shall allow insertion of all corresponding lamps so as to make contact.

Compliance is checked by means of gauges according to the current edition of the following standard sheets of IEC 60061-3 and according to the indications of these sheets:

- *lampholders E14: 7006-30 and 7006-31;*
- *candle lampholders E14: 7006-30A and 7006-31;*
- *lampholders E27: 7006-21 and 7006-22A;*
- *lampholders E40: 7006-23 and 7006-24.*

Pending gauges for lampholders E5 and E10, the contact-making is checked by means of the corresponding lamps. It is presumed that the manufacturer of the lampholder for the purpose of the test delivers the lamps for which the lampholder is intended.

The checking of contact-making is done on lampholders as delivered and after the tests of Clauses 19 and 20.2.

For lampholders for use in appliances other than luminaires only:

If the fixing means of lampholders are integrated parts of the rim and the lampholder is designed for use with a selected standardized lamp only, parts of the lampholder rim could interfere with the relevant contact-making gauge. In this case, compliance with the requirements for maximum lamp outlines according to IEC 60630 for the lamp indicated in the lampholder manufacturer's instructions shall be checked. Following this checking, the contact-making gauge shall be applied after those parts of the lampholder interfering with the gauge have been removed.

For testing such lampholders, two additional specimens specially prepared to accept the relevant contact-making gauge are required.

9.3 The following dimensions shall be not less than the values shown in Table 1.

Table 1 – Thickness of screw shells and contacts

Dimension	Lampholder				
	E5	E10	E14	E27	E40
Thickness of the screw shell, if any (mm):					
– when the shell is unsupported	0,20	0,20	0,30	0,30	0,50
– when the shell is supported by insulating material over a total distance of at least three-quarters of the circumference of the shell	0,15	0,15	0,25	0,25	0,40
Thickness of side or central contacts, if resilient (mm)	0,18	0,18	0,28	0,38	0,48 ^a
^a For the use of side-contacts in lampholders E40, see 13.11.					

Compliance is checked by measurement.

NOTE 1 Thicknesses are measured by means of a micrometer with pointed noses and ratchet screw.

For the screw shell, two sets of three measurements are made, each set carried out on one of two different generating lines of the screw shell. The mean value of the six measurements shall be at least equal to the specified value.

NOTE 2 The deletion of dimensional requirements is under consideration.

9.4 The effective length of screw engagement, if any, of outer shell and dome shall meet one of the following requirements whereby the engagement shall always be over one full turn.

Either the effective length shall be not less than the values shown in Table 2, or the effective length shall be at least two turns provided the test according to 16.3 is withstood with a torque equal to 1,2 times the torque given in 16.2.

Table 2 – Minimum effective screw lengths

Dimension	Lampholder		
	E14	E27	E40
Minimum effective screw length (mm):			
– Metal lampholders for rolled thread	5,0	7,0	10,0
– Metal lampholders for cut thread	5,0	5,0	7,0
– Lampholders of insulating material	5,0	7,0	10,0

These requirements do not apply to lampholders E5 and E10.

Compliance is checked by measurement.

9.5 The threaded entries of lampholders shall be provided with one of the following screw threads:

- lampholders E14: M10×1;
- lampholders E27: M10×1, M13×1 or M16×1;
- lampholders E40: M13×1, M16×1 (or G3/8A).

NOTE 1 The size between brackets is non-preferred; in addition, the threaded entry M10 is mainly intended for internal wiring of luminaires.

NOTE 2 In France, threaded entry lampholders with 11 mm × 19 TPI and 17 mm × 19 TPI (turns per inch) screw threads are permitted for replacement.

The thread of the entry shall comply with Figure 1a or Figure 1b.

These requirements do not apply to lampholders E5 and E10.

Compliance is checked by measurement and by means of gauges according to Figure 2a or Figure 2b.

In case of doubt, the gauge is introduced into the entry by applying a torque of 0,5 Nm.

9.6 The dimensions of threaded entries and set screws, if any, shall be not less than the values shown in Table 3.

Table 3 – Dimensions of threaded entries and set screws

Dimensions in millimetres

Dimension	Nominal thread diameter	
	M10×1 M13×1	M16×1 G3/8A
Length of the thread:		
– metal entry	3	8
– entry of insulating material	5	10
Diameter of set-screw:		
– screw with head	2,5	3,0
– screw without head:		
– in case of one screw	3,0	4,0
– in case of more than one screw	3,0	3,0

A negative deviation of 0,15 mm from the nominal values for thread diameter is allowed.

Compliance is checked by measurement.

These requirements do not apply to lampholders E5 and E10.

NOTE If it is necessary to take the lampholder apart in order to check compliance with the requirements under 9.3 to 9.6, such checking is done after the test of Clause 18.

9.7 Lampholders shall be so designed that they do not interfere with the proper engagement or disengagement of lamps, even if the lamp cap is slightly dented. In no case shall the holder contacts present a cutting edge to the lamp cap.

Compliance is checked by the following test:

For lampholders E27, compliance shall be checked by means of a gauge according to the current edition of Standard Sheet 7006-22B of IEC 60061-3.

For lampholders other than E27, compliance shall be checked by inspection.

10 Protection against electric shock

10.1 Lampholders E5, E10, E14 and E27 shall be so designed that the lamp caps are not accessible when they become live during insertion.

NOTE 1 Details for checking compliance regarding protection against accidental contact with live parts during insertion for lampholders E5 and E10 are under consideration. Because of this, lampholders E10 with a rated voltage exceeding 60 V are for sale to luminaire or other equipment manufacturers only.

For lampholders E10 with a rated voltage exceeding 60 V, the protection against electric shock can be provided by measures taken in the luminaire or equipment where the lampholders are used.

Lampholders E40 shall be so designed that the lamp cap is not accessible when fully inserted.

Candle lampholders are tested without decorative cover, unless this cover cannot be removed without making the lampholders obviously useless.

Compliance is checked as follows:

- for lampholders E10, by means of corresponding lamps and the standard test finger, shown in Figure 16. For the purpose of the test, the lampholder manufacturer shall provide the lamps for which the lampholder is intended;

- for lampholders E14, E27 and E40, by means of gauges according to the current edition of the following standard sheets of IEC 60061-3:
 - 7006-31 for lampholders E14;
 - 7006-22A for lampholders E27;
 - 7006-24 for lampholders E40.

NOTE 2 In order to ensure protection against electric shock during insertion on unused lampholders, the tests according to 10.1 are made on new specimens.

10.2 The external parts of enclosed and independent lampholders shall be so designed that live parts of the lampholder ready for use and with a corresponding normal lamp inserted are not accessible.

Candle lampholders are tested without decorative cover, unless this cover cannot be removed without making the lampholder obviously useless.

Compliance is checked by means of the standard test finger.

For the purpose of the test:

- enclosed lampholders are mounted as in normal use, for example on a threaded support, or the like, if appropriate, and provided with the most unfavourable conductor size fitted for which the lampholders are intended;
- independent lampholders shall be mounted as in normal use on an appropriate plane surface.

The standard test finger shown in Figure 16 is applied in every possible position with a force of 10 N, an electrical indicator being used to show contact with live parts.

It is recommended that a voltage of not less than 40 V be used.

NOTE Unenclosed lampholders are only tested after appropriate installation in a luminaire or other additional enclosure.

For E5 and E10 lampholders with a separate insert part mounted in an outer sleeve, the insert part shall be subjected to a pull force of 60 N for 1 min in the axial direction.

The test shall be performed by hand in order to simulate any axial misalignment as normally occurs in practice. The axial misalignment movement performed during the test should be up to 10° in any direction.

During this test, the insert part shall not become loose to such an extent that live parts become accessible with the standard test finger.

10.3 Parts providing protection against accidental contact with the lamp cap shall be reliably secured so that they will not become detached when a tightly fitting lamp is removed, or when rotating the shade, if applicable.

Compliance is checked by the following test:

The coupling between dome and outer shell is tightened initially with a torque equal to two-thirds of the torque test value specified below. The relevant parts are then subjected to a torque during 1 min in an anticlockwise direction with the following test values:

- 1 Nm for lampholders E14;
- 2 Nm for lampholders E27.

The lampholder is mounted as in normal use and is tested first with and then without the appropriate test cap according to Figure 13 (test cap B) or Figure 14.

After the test, the parts providing protection against accidental contact with the lamp cap shall not have become dismantled.

It shall not be possible to dismantle lampholders E5 and E10 without the aid of a tool.

Requirements for lampholders E40 (see Figure 15) are under consideration.

10.4 Where provision is made for attaching a shade to the lampholder, it is fitted to the lampholder by separate means, such as a shade ring; it is not permitted to fix a shade between parts providing protection against electric shock.

Compliance is checked by inspection.

10.5 The external parts of

- drip-proof lampholders,
- lampholders with a rated voltage of more than 250 V,
- switched-lampholders, and
- lampholders E5 and E10

shall be of insulating material, with the exception of threaded entries and of those parts which cannot become live even in the event of a fault.

Lacquer or enamel is not deemed to provide adequate protection for the purpose of Clause 10.

Compliance is checked by inspection.

NOTE 1 Parts which are separated from live parts by double or reinforced insulation are considered as parts which cannot become live in the event of a fault.

NOTE 2 An example of an external part which cannot become live, even in the event of a fault, is a metal shade ring mounted on the outside of an insulated lampholder.

Switched-lampholders with external metal parts are permitted under the conditions of 13.3.

11 Terminals

11.1 Lampholders, other than those provided with connecting leads (tails), shall be provided with terminals which allow connection of conductors having the following nominal cross-sectional areas:

- 0,5 mm² to 0,75 mm² for lampholders E10;
- 0,5 mm² to 1,0 mm² for lampholders E14 and E27 with M10×1 threaded entry;
- 0,5 mm² to 2,5 mm² for other lampholders E27;
- 1,5 mm² to 4 mm² for lampholders E40 with a rated current of 16 A;
- 2,5 mm² to 6 mm² for lampholders E40 with a rated current of 32 A.

Compliance is checked by inspection and by fitting conductors of the smallest and largest cross-sectional area specified. For cord-grip lampholders, lampholders E10, E14 and lampholders E27 with M10×1 threaded entry, stranded conductors are used; in all other cases the conductors are of the solid type.

Threaded entry lampholders are tested in a screwed conduit.

Lampholders E27 with screwless terminals intended for use by luminaire or equipment manufacturers only need not fulfil the requirements for all the appropriate nominal cross-sectional areas.

11.2 Connections

11.2.1 Lampholders shall be provided with at least one of the following means of connection:

- screw type terminals;
- screwless terminals;
- tabs or pins for push-on connections;
- posts for wire wrapping;
- soldering lugs;
- connecting leads (tails).

Terminal screws and nuts shall have a metric ISO thread or a thread comparable in pitch and mechanical strength.

Conductors may be connected to E5, E10 and similar small lampholders by soldering, welding, crimping or other equally effective means.

Lampholders with screwless terminals, unless intended for sale to luminaire or equipment manufacturers, shall be provided with terminals which are equally satisfactory with both rigid (solid or stranded) conductors and flexible cables or cords.

Compliance is checked by the tests of 11.2.2.

11.2.2 Terminals shall comply with the following requirements, with the restriction that the requirements referring to internal wiring relate to wiring inside independent holders and to wiring inside luminaires for holders for building-in.

All terminal tests shall be made on separate specimens which have not been subjected to any other test:

- *terminals with screw clamping shall comply with the requirements specified in 11.3 to 11.6 inclusive, and 11.8;*
- *screwless terminals shall comply with Clause 15 of IEC 60598-1, provided that the heating test is carried out at the rated operating temperature of the lampholder ± 5 °C;*
- *tabs or pins for push-on connections shall comply with Clause 15 of IEC 60598-1;*
- *posts for wire wrapping shall comply with IEC 60352-1. Wire wrapping applies only to single solid round wire for internal wiring;*
- *soldering lugs shall comply with the requirements for good solderability. Suitable requirements can be found in IEC 60068-2-20;*
- *connecting leads (tails) shall comply with the requirements specified in 11.10.*

11.3 Terminals shall be fixed in such a way that they will not work loose when fastening or loosening the conductors.

For screw terminals, compliance is checked by inspection and by fastening and loosening a conductor of the largest cross-sectional area specified in 11.1 10 times, the applied torque being two-thirds of the torque specified in Clause 14 of IEC 60598-1.

NOTE Terminals can be prevented from working loose by fixing with one screw in a recess without appreciable play, or by other suitable means. Covering with sealing compound without other means of locking is not deemed to be sufficient.

11.4 Screw terminals shall be so designed that they clamp the conductor between metal surfaces with sufficient contact pressure and without damage to the conductor. Terminals shall be so designed that they will prevent a conductor slipping out when the screws or nuts are tightened. They shall allow a conductor to be connected without special preparation (e.g. soldering of the strands of the conductor, use of cable lugs, formation of eyelets, etc.).

Compliance is checked by inspection of the conductors after fitting according to 11.1 and after the test of 20.3.

NOTE The conductors are considered to be damaged if they show deep or sharp indentations.

11.5 Terminals of the pillar type shall have dimensions not less than those shown in Table 4.

Table 4 – Minimum dimensions of pillar-type terminals

Lampholder	Nominal thread diameter mm	Diameter of hole for conductor mm	Length of thread in pillar mm
E10	2,5	2,5	1,8
E14	2,5	2,5	1,8
E27	2,5	2,5	1,8
E40	3,5	3,5	2,5
The diameter of the hole shall be not more than 0,6 mm larger than the diameter of the screw.			

The length of the threaded part of the terminal screw shall be not less than the sum of the diameter of the hole for the conductor and the length of thread in the pillar.

NOTE The length of the thread of the pillar is measured to the point where the thread is broken by the pillar hole.

Compliance is checked by measurement.

11.6 Screw terminals shall have dimensions not less than those shown in Table 5.

Table 5 – Minimum dimensions of screw-type terminals

Lampholder	Nominal thread diameter mm	Length of thread under the head mm	Length of thread in nut mm	Nominal difference between diameter of head and shank of screw mm	Height of head mm
E10	2,5	4,0	1,5	2,5	1,4
E14	3,0	5,0	1,5	3,0	1,8
E27	3,5	5,0	1,5	3,5	2,0
E40	4,0	6,0	2,5	4,0	2,4

If an intermediate part locked against rotation, such as a washer or a pressure plate, is used between the head of the screw and the conductor, the difference in diameter between head and shank of the screw may be reduced by 1 mm.

Compliance is checked by measurement.

A negative deviation of 0,15 mm from the nominal values of the thread diameter and of the difference in diameter of head and shank is allowed.

NOTE If it is necessary to take the lampholder apart in order to check compliance with the requirements under 11.5 and 11.6, such checking is done after the test of Clause 18.

11.7 Terminals shall be so located that, after correct fitting of the wires, there is no risk of accidental contact between live parts and accessible metal parts.

Compliance is checked by inspection and by the following test:

The insulation is removed over a length of 4 mm from the end of a flexible conductor having the minimum nominal cross-sectional area specified in 11.1. One wire of the stranded conductor is left free and the remainder are fully inserted into and clamped in the terminal of the lampholder, mounted and installed as in normal use (locking screws tightened, etc.).

The free wire is bent without tearing the insulation back, in every possible direction, but without making sharp bends around barriers.

The free wire of a conductor connected to a live terminal shall not touch any metal part which is not a live part, and that of a conductor connected to the earthing terminal shall not touch any live part.

If necessary, the test is repeated with the free wire in another position.

NOTE The prohibition against making sharp bends around barriers does not imply that the free wire is kept straight during the test. Sharp bends are, moreover, made if it is considered likely that such bends can occur during the normal assembly of the lampholder. See also 13.3.

11.8 Pillar terminals in which the end of the conductor is not visible shall have a length of hole beyond the terminal screw at least equal to half the value of the diameter of the screw or 2,5 mm, whichever is the higher.

Compliance is checked by measurement.

11.9 Terminals which are floating shall show no appreciable lateral play and shall not move longitudinally more than 3 mm when a lamp is removed or inserted.

Compliance is checked by measurement.

11.10 The requirements of 11.2 to 11.6 inclusive and of 11.8 do not apply to lampholders intended to be factory-mounted in luminaires and which are provided with connecting leads (tails).

Lampholders intended to be factory-mounted in luminaires or built into equipment may be provided with connecting leads (tails), tab-terminals or equally effective means.

Connecting leads (tails) shall be connected to the lampholders by soldering, welding, crimping or by any other at least equivalent method.

Leads shall consist of insulated conductors.

Insulation of the free end of the leads may be stripped.

Fixing of the leads to the lampholders shall withstand the mechanical forces that may occur in normal use.

Compliance is checked by inspection and by the following test, which is made after the test of 20.2 on the same three specimens.

Each connecting lead is subjected to a pull of 20 N, the pull is applied without jerks for 1 min in the most unfavourable direction.

During the test leads shall not move from their fixing.

After the test, the lampholders shall show no damage within the meaning of this standard.

12 Provision for earthing

12.1 Threaded entry lampholders, cord-grip lampholders and backplate lampholders, with provisions for earthing, other than those provided with connecting leads, shall have at least one internal earthing terminal; other lampholders without threaded entry, for example, lampholders for building-in, may be provided with an external earthing terminal.

Compliance is checked by inspection.

NOTE Lampholders intended to be earthed but not provided with an earthing terminal or with connecting leads are not for retail sale.

12.2 Accessible metal parts of lampholders without earthing terminal, which may become live in the event of an insulation fault, shall allow reliable earthing.

There shall be earth continuity between a metal dome and the outer shell, if of metal, when the shell is not separated from live parts by double or reinforced insulation.

NOTE For the purpose of this requirement, small isolated metal screws and the like for fixing bases or covers are not deemed to be accessible parts which can become live in the event of an insulation fault.

Compliance is checked by the following test:

A rigid conductor having the smallest cross-sectional area for which the holder is intended is fitted to the earthing terminal, if provided.

When earth continuity between the dome and the outer shell also has to be checked, the coupling between these parts shall be tightened with the torque specified:

- 1 Nm for lampholders E14;
- 2 Nm for lampholders E27;
- 4 Nm for lampholders E40.

Immediately after the tests of 15.3, the resistance between the means of earthing and the dome (or the outer shell as appropriate) is measured.

For lampholders with an earthing terminal, the means of earthing is the point where the conductor leaves the terminal and for lampholders without an earthing terminal, it is the point where the earthing connection is intended to be made.

A current of at least 10 A, derived from a source with a no-load voltage not exceeding 12 V, shall be passed between the earthing terminal or earthing contact and each of the accessible metal parts in turn.

The voltage drop between the means of earthing and accessible metal part shall be measured. The resistance, calculated from the voltage drop and the current, shall not exceed 0,1 Ω .

12.3 Earthing terminals shall comply with the requirements of Clause 11.

Their clamping means shall be adequately locked against accidental loosening, and it shall not be possible to loosen screw terminals by hand and screwless terminals unintentionally by hand.

Compliance is checked by inspection and by the tests of Clause 11.

NOTE In general, the designs commonly used for current-carrying terminals (complying with the requirements of this standard) provide sufficient resilience to comply with the latter requirement; for other designs special provisions, such as the use of an adequate resilient part which is not likely to be removed inadvertently, may be necessary.

12.4 The metal of earthing terminals shall be such that there is no risk of corrosion resulting from contact with the copper of the earthing conductor.

The screw or the body of the earthing terminal shall be of brass or other metal no less resistant to corrosion, and the contact surfaces shall be bare metal.

Compliance is checked by inspection.

NOTE The risk of corrosion is particularly great when copper is in contact with aluminium.

12.5 Metal parts of the cord anchorage, including clamping screws, shall be insulated from the earthing circuit.

Compliance is checked by inspection.

13 Construction

13.1 Lampholders shall be provided with a screw thread of Edison form for holding the lamp.

For lampholders other than E5 and E10, this thread shall be either of metal and shall be continuous over a length not less than that specified in the current edition of standard sheet 7005-20 of IEC 60061-2, or comply with the following requirements.

NOTE The requirement for a minimum length of screw thread for lampholders E5 and E10 is under consideration.

Deviation from the requirements for a metal thread is allowed provided the design and production tolerances are such that proper engagement with all gauges is ensured throughout the life of the holder delivered. On this subject, further information will be available in the annex: Surveillance tests, under consideration.

In addition, the terminal/contact assembly and the screw shell shall be so constructed and located as to prevent canting or rotation which would impair the use of the lampholder.

Deviation from the requirement for a continuous thread is allowed if this is necessary to provide a special technical advantage, such as the inclusion of a lamp retention device in a cut-away.

Compliance is checked by inspection and by a manual test with the relevant gauges, referred to in Clause 8, applied in all positions which can be achieved with reasonable force, and the holder shall still comply with the gauges, especially the feeler gauge of 0,08 mm × 5,0 mm.

Furthermore, it shall not be possible to score the neck of the bulb of a lamp made to normal standards during engagement and disengagement.

The male screw thread of an adapter shall be of the same size or larger than the female screw thread shell of the adapter.

13.2 There shall be adequate space for the supply wires in the dome of the lampholder. Parts of the lampholder with which insulated conductors may come into contact shall have no sharp edges or a shape likely to damage the insulation.

Threaded entry lampholders shall be provided with means to prevent the conduit entering too far into the entry, unless it is evident from the design that the conduit is unlikely to enter too far into the entry, for example in certain candle lampholders.

Compliance is checked by inspection and by fitting flexible cables or cords of the largest cross-sectional area according to 11.1 for lampholders E14 and lampholders E27 with M10×1 threaded entries, with conductors with a nominal cross-sectional area one size less than specified for other lampholders E27 and lampholders E40.

For cord-grip lampholders, lampholders E14 and lampholders E27 with M10×1 threaded entries, an ordinary sheathed flexible cord is used; in all other cases, two or three PVC insulated single-core cables are used.

For threaded entry lampholders, the dome of the lampholder is screwed onto a conduit having a length of about 10 cm. The cables are then introduced into the conduit and dome. The ends of the cables, after having been prepared in the usual manner, are connected to the terminals of the lampholder. If possible, the connection is made with the part carrying the terminals in a position where the shortest distance between the plane of the upper edge of the dome and the nearest part of the terminals is 10 mm. With the terminals held in this position, the cables are tightened and clamped at the free end of the conduit. After this, the lampholder is assembled.

After dismantling, the cables and cords shall not be damaged.

NOTE 1 For lampholders E27 and E40, a test with conductors with maximum cross-sectional area according to 11.1 is under consideration.

NOTE 2 The requirement concerning sharp edges is not meant for the outer end of the threaded entry, since they are not in contact with the wires when the lampholder is mounted on a conduit.

In case of doubt with regard to the means to prevent the conduit entering too far into the entry of a threaded entry lampholder, the lampholder is screwed onto a steel conduit or mandrel having squared ends (edges left sharp). The conduit or the mandrel is provided with a full thread having the minimum dimensions shown in Figure 1a or Figure 1b.

During this test, the following torque is applied for 1 min:

- 1,0 Nm for threaded entries M10×1;
- 1,3 Nm for threaded entries M13×1;
- 1,6 Nm for threaded entries M16×1 and G3/8A.

After this test, the conduit or the mandrel shall not have entered into the space provided for the supply wires in the dome of the lampholder, and the lampholder shall not show any change impairing its further use.

13.3 Accessible parts of switched lampholders shall be of insulating material unless the design is such that a live wire detached from its terminal cannot touch accessible metal parts or parts of the earthing circuit and that terminal screws or screws in threaded entries which have become loose cannot bridge accessible metal parts, including earthing terminals, and live parts.

Compliance is checked by inspection.

NOTE This requirement does not necessarily imply either complete or partial insulating lining.

13.4 In case of lampholders with metal screw shell and metal outer shell, contact between these parts shall be prevented by an insulating ring which shall not be separable from the live parts or the metal outer shell by hand.

Compliance is checked by inspection.

NOTE The protection by the insulating ring is considered sufficient if its length is approximately equal to that of the screw shell.

13.5 It shall be possible to lock the threaded entry on the conduit. Locking devices can either be part of the lampholder or be provided by the design of a luminaire.

Except for angled lampholders, it shall be possible to operate the locking device from the inside, if provided as part of the lampholder.

If a locking device is provided by the design of a luminaire, its efficiency cannot be checked when testing the lampholder; such a check shall be made during testing of the luminaire.

NOTE Such lampholders are not intended for retail sale.

This requirement does not apply to lampholders E5 and E10.

Compliance is checked by inspection and, for lampholders having an integral locking device, by the test of 16.4.

13.6 Cord-grip lampholders and all lampholders designed for chain connection shall be provided with a device allowing the lampholder to be so fixed to a flexible cord that the conductors are relieved from strain, including twisting, where they are connected to the terminals, and that the outer covering of the cord is gripped in the lampholder and is protected from abrasion. It shall be clear how the relief from strain and the prevention of twisting is intended to be effected.

It shall not be possible to push the cord into the lampholder to such an extent that the cord is subjected to undue mechanical or thermal stress.

Makeshift precautions, such as tying the cord into a knot or tying the end with string, are not permissible.

The device shall be of insulating material or be provided with a fixed insulating lining if otherwise an insulation fault on the cord could make accessible metal parts live.

The design shall be such that the device:

- is at least one part fixed to or integral with the lampholder;
- is suitable for the different types of flexible cord which may be connected to the lampholder;
- does not exert excessive pressure on the cord;
- is unlikely to be damaged when it is tightened or loosened as in normal use.

The device shall be suitable for flexible cords of the following types:

- 60245 IEC 51;
- 60245 IEC 53 or the like;
- 60227 IEC 52.

Compliance is checked by inspection and by the following test:

The lampholder is fitted with a flexible cord, the device for strain and twist relief being appropriately used. The conductors are introduced into the terminals and the terminal screws are slightly tightened, so that the conductors cannot easily change their position. After this preparation, it shall not be possible to push the cord further into the lampholder.

The flexible cord is then subjected 100 times to a pull of the appropriate value shown in the Table 6, each for a duration of 1 s. The pull shall not be applied in jerks.

Immediately afterwards, the flexible cord is subjected for a period of 1 min to a torque as specified in Table 6.

Table 6 – Pull and torque values

Total nominal cross-sectional area of all conductors together mm ²	Pull N	Torque Nm
Up to and including 1,5	60	0,15
Over 1,5 up to and including 3	60	0,25
Over 3 up to and including 5	80	0,35
Over 5 up to and including 8	120	0,35

The lampholders are tested with each of the appropriate types of cord, as specified before, complying with IEC 60245 or IEC 60227.

The test is first made with conductors of the smallest cross-sectional area specified in 11.1 as well as with conductors of either the largest cross-sectional area allowed by the suspending device or the largest cross-sectional area specified in 11.1, whichever is the smaller.

For lampholders designed for chain connection, the test is carried out with the cables for which the lampholder is designed. The cable is subjected 50 times to a pull of 30 N. The torque test is not carried out.

During the test, no damage to the flexible cord shall be caused by the device for strain and twist relief. At the end of the test, the cord shall not have been displaced by more than 2 mm, and the ends of the conductors shall not have been noticeably displaced in the terminals.

In order to enable the displacement to be measured, before starting the test, a mark is made on the cord under strain at a distance approximately 2 cm from the strain-relieving device. At the end of the test, the displacement of this mark in relation to the strain device is measured while the cord is still under strain.

13.7 Suspending devices of enclosed and independent lampholders shall have no accessible metal parts which can become live, even in the event of a fault in the lampholder. Moreover, suspending devices intended to be screwed into threaded entry lampholders shall comply with the requirements of 13.2.

Compliance is checked by inspection and by the test of 13.6.

13.8 Backplate lampholders not specifically intended for building-in shall have a recess for supply wires. This recess shall have the following minimum dimensions in order to allow back entry from a conduit perpendicular to the mounting surface of the lampholder:

- height 7 mm;
- length equal to diameter or width of the base;

- width 16 mm enlarged to a circular space 23 mm in diameter in the centre.

Compliance is checked by measurement.

The dimensional requirement does not apply to lampholders E5 and E10.

13.9 The base of backplate lampholders, other than those specifically intended for building-in, shall be suitable for fixing by means of screws with a diameter of at least 4 mm.

Compliance is checked by means of a gauge according to Figure 3. For this test, the plug is inserted into the hole from the back and the bush is placed on the plug from the front.

The bush shall enter the recess for the screw head.

This requirement does not apply to lampholders E5 and E10.

13.10 Where provision for cable entry/entries is made on the accessible external surface of a backplate lampholder, they shall allow the introduction of cable covering, conduit or trunking etc., as appropriate, so as to afford mechanical protection at least for a distance of 1 mm measured from the accessible external surface of the backplate lampholder.

Compliance is checked by measurement and by the installation test of 11.1.

13.11 The contacts shall be designed and constructed so as to ensure during normal use effective and reliable electrical contact.

The functioning of the contacts shall be independent of the functioning of an optional locking device between the dome and the outer shell.

New E40 lampholder designs shall be of the contact-making shell type.

NOTE Contact-making problems with actual lamp caps have shown that the contact-making shell type is the only practical solution in this respect.

Compliance is checked by inspection and by the test of 20.2.

A single side-contact is allowed.

13.12 Lampholders shall not be fitted with a socket-outlet.

Compliance is checked by inspection.

13.13 Devices for bridging the lamp filament shall not be integral with the lampholder.

Compliance is checked by inspection and, if necessary, by test.

13.14 Lampholders with a retention device shall be able to withstand a certain unscrewing torque.

A commercially available brass lamp cap complying with the relevant standard sheets shall be inserted into the sample lampholder with retention device, with a torque according to the type of lampholder as specified in Table 7.

Table 7 – Insertion torque

Lamp cap	Torque Nm
E27	$1,5 \pm 0,1$
E40	$2,0 \pm 0,1$

The lamp is then unscrewed for about 30°. In this position, the removal torque is measured.

The removal torque shall not be less than the minimum value and shall not exceed the maximum value specified in Table 8.

Table 8 – Minimum and maximum removal torques

Lamp cap	Minimum torque Nm	Maximum torque Nm
E27	0,5	2,0
E40	1,0	4,0

When the lamp cap is damaged or is showing wear, a new cap should be used for the tests.

14 Switched lampholders

14.1 Switches are allowed only in ordinary lampholders E14 and in ordinary lampholders E27 for use up to and including 250 V.

Compliance is checked by inspection.

14.2 Switched lampholders shall comply with the constructional requirements of 13.3 and with the additional requirements of 14.3 to 14.5, or with the relevant requirements given in IEC 61058-1.

NOTE Guidance for the selection of the relevant requirements in IEC 61058-1 is given in Annex B.

14.3 Switches in lampholders shall be capable of making and breaking a load comprising a filament lamp or self-ballasted lamp for general lighting service (GLS).

Compliance is checked by the following tests:

Switches in lampholders E14 shall be tested for an operating temperature of 100 °C, and switches in lampholders E27 shall be tested for an operating temperature of 125 °C.

Switches in lampholders intended for use in refrigerators or food freezers shall be tested at the rated operating temperatures.

Switches in lampholders with temperature marking shall be tested for operating temperatures as follows:

- *lampholders E14: the temperature marking of the lampholder minus 40 °C;*
- *lampholders E27: the temperature marking of the lampholder minus 50 °C.*

The switch is tested with alternating current ($\cos \varphi = 0,6 \pm 0,05$) at 1,1 times rated voltage and 1,25 times rated current.

The switch shall be operated in a normal manner for 200 switch movements at a rate of 30 movements per minute at regular intervals.

The switch is then tested with alternating current ($\cos \varphi = 1$) at rated voltage and rated current.

The switch shall be operated in a normal manner for 20 000 switch movements at a rate of 30 movements per minute at regular intervals.

NOTE Replacement of the above test by the corresponding test of IEC 61058-1 is under consideration.

At the conclusion of the test, the lampholder shall withstand the tests specified in 15.4 for insulation resistance and electric strength and shall be in satisfactory working order.

14.4 Switched lampholders shall be so constructed that accidental contact between moving parts of the switch and the supply wires is prevented.

Compliance is checked by the test of 11.1 and by a manual test.

14.5 The switch-operating member shall be effectively insulated from live parts and, if it is broken or damaged, it shall not expose live parts.

Compliance is checked by inspection and by the tests specified in 14.3.

14.6 Switches in lampholders intended for use in refrigerators or food freezers may be tested with a lamp according to the expected wattage rating for lamps of the appliance.

15 Moisture resistance, insulation resistance and electric strength

15.1 The enclosure of drip-proof lampholders shall provide the necessary degree of protection against ingress of water.

Compliance is checked by the following test.

Lampholders are fitted with the cables or conduits for which they are designed.

Backplate lampholders are mounted on a vertical surface with one drain hole, if any, open and directed downwards. Other lampholders are mounted with their lamp entry pointing vertically downwards.

The test is made by means of equipment, the principle of which is shown in Figure 3 of IEC 60529:1989. The rate of discharge shall be reasonably uniform over the whole area of the apparatus and shall produce a rainfall of between 3 mm and 5 mm of water per minute, falling vertically from a height of 200 mm measured from the lampholder. The test duration is 10 min. The water used for the test shall be at a temperature of $15\text{ }^{\circ}\text{C} \pm 10\text{ }^{\circ}\text{C}$.

Immediately after this treatment, the lampholder shall withstand the same electric strength test as specified in 15.4, and inspection shall show that water has not entered to an appreciable extent.

NOTE It is considered that water has entered to an appreciable extent if it has come into contact with live parts. In this case, a screw shell which is only live when a lamp is inserted is not considered as a live part.

15.2 Inlet openings of drip-proof lampholders shall allow the connection of the supply wires in such a way that drops of water running along the wires cannot reach the inside of the lampholder.

Compliance is checked by inspection.

15.3 Lampholders shall be proof against humid conditions which may occur in normal use.

Compliance is checked by the humidity treatment described in 15.3 followed immediately by the measurement of the insulation resistance and by the electric strength test specified in 15.4.

Cable entries, if any, are left open; if knock-outs are provided, one of them is opened.

The humidity treatment is carried out in a humidity cabinet containing air with a relative humidity maintained between 91 % and 95 %. The temperature of the air, at all places where specimens can be located, is maintained within 1 °C of any convenient value t between 20 °C and 30 °C.

Before being placed in the humidity cabinet, the specimens are brought to a temperature between t and $(t + 4)$ °C.

Lampholders are kept in the cabinet:

- *two days (48 h) for ordinary lampholders;*
- *seven days (168 h) for IPX1 drip-proof lampholders.*

NOTE 1 In most cases, the specimens can be brought to the specified temperature by keeping them at this temperature for at least 4 h before the humidity treatment.

NOTE 2 Relative humidity between 91 % and 95 % can be obtained by placing in the humidity cabinet a saturated solution of sodium sulphate (Na_2SO_4) or potassium nitrate (KNO_3) in water, having a sufficiently large contact surface with the air. In order to achieve the specified conditions within the cabinet using this method, it is important to ensure constant circulation of the air within and, in general, to use a cabinet which is thermally insulated.

After this treatment, the lampholders shall show no damage within the meaning of this standard.

15.4 The insulation resistance and the electric strength shall be adequate:

- a) between live parts of different polarity;
- b) between such live parts and external metal parts, including fixing screws of the base or enclosure of backplate lampholders, and accessible assembling screws;
- c) between the inner and outer surfaces of the lining of metal enclosures, if such accessible lining is required in accordance with 13.3 to give protection or if the distance between any live part and the metal of the enclosure is smaller than that required under footnote b in Tables 13a and 13b.

Compliance is checked by an insulation-resistance measurement and an electric strength test made immediately after the humidity treatment in the humidity cabinet, or in the room in which the specimens were brought to the prescribed temperature.

The insulation resistance is measured with a DC voltage of approximately 500 V, the measurement being made 1 min after application of the voltage.

The insulation resistance is measured consecutively:

- a) *between live parts of different polarity;*
- b) *between such live parts connected together and the body;*
- c) *between accessible metal parts and metal foil in contact with the inner surface of insulating lining, if any.*

The term "body" used in item b) includes external metal parts, fixing screws of the base and of the enclosure, accessible assembling screws and metal foil in contact with the surface of external insulating parts.

Measurements prescribed in items a) and b) are first made on the lampholder in which the test cap shown in Figure 11 is inserted and then on the empty lampholder.

The switch, if any, is placed in the "on" position.

If metal foil is used for the test on the empty lampholder, it shall also be in contact with the metal screw shell if this shell has to be insulated from the contacts.

The insulation resistance shall be not less than:

- 2 M Ω for the measurement according to item a);*
- 4 M Ω in all other cases.*

Immediately after the insulation resistance test, an AC voltage of substantially sine wave form, with a frequency of 50 Hz or 60 Hz and with an r.m.s. value of $(2 U + 1\,000)$ V (where U is the rated voltage) is applied for 1 min between the points prescribed. For enclosed and unenclosed reinforced insulated lampholders, the test voltage shall be determined from Table 10.2 of IEC 60598-1. Additionally, for switched lampholders, this voltage shall be applied between live parts of different polarity and other metal parts with the switch both closed and open.

The electric strength test voltage between live parts of different polarity for lampholders E5 and E10 with a rated voltage not exceeding 60 V is reduced to 500 V.

Initially, not more than half the prescribed voltage is applied, it is then raised rapidly to the full value.

No flashover or breakdown shall occur during the test.

The high-voltage transformer used for the test shall be so designed that, when the output terminals are short-circuited after the output voltage has been adjusted to the appropriate test voltage, the output current is at least 200 mA.

The overcurrent relay shall not trip when the output current is less than 100 mA.

Care is taken that the r.m.s. value of the test voltage applied is measured within ± 3 %.

Glow discharges without drop in voltage are neglected.

16 Mechanical strength

16.1 Lampholders shall have adequate mechanical strength and shall withstand the strain due to the insertion of a lamp as well as that caused by the screwing of the lampholder to a conduit.

Compliance is checked by the tests of 16.2 to 16.7.

With the exception of candle lampholders, brackets or similar devices for the mounting or attachment of lampholders are not covered by the requirements of Clause 16. The mechanical strength of such devices shall comply with the requirements of the standard for the equipment for which the lampholder is intended.

16.2 The mechanical strength of the outer shell, the screw shell and the dome is checked by screwing a test cap (see Figures 13, 14 and 15) into the specimen, the following torque being applied for 1 min:

- 0,3 Nm for lampholders E5;
- 0,3 Nm for lampholders E10;
- 0,5 Nm for candle lampholders E14, when the lampholder is fixed by the threaded entry;
- 1,2 Nm for candle lampholders E14, when the lampholder is clamped by the outer shell;
- 1,2 Nm for other lampholders E14;
- 2 Nm for lampholders E27;
- 4 Nm for lampholders E40.

The test cap dimensions are as specified in Table 9.

Table 9 – Test cap dimensions

Lampholder	Dimension S ^a mm	Diameter of central contact mm
E14	5,5	4,8
E27	9,5	9,5
E40	11,0	14,0
^a For the meaning of dimension S, see Figures 13, 14 or 15.		

The dimensions of the test caps for lampholders E5 and E10 are under consideration. For the time being, the test is carried out with a cap having the same dimensions as the cap of the lamp for which the lampholder is designed.

The test is made twice: first with the specimen clamped at the outer shell and secondly with the specimen fixed by the threaded entry, dome or backplate, according to type of lampholder.

At the end of the test, the specimen shall not show any change impairing its normal use.

16.3 The dome or backplate of the specimen is fixed and a torque as indicated under 16.2 is applied to the outer shell for 1 min so as to tighten the screwed connection between shell and dome.

This test shall cause neither loosening of the connection between shell and dome nor any other damage.

The test does not apply to lampholders E5 and E10.

16.4 *The dome of threaded entry lampholders is fixed to a brass conduit in the normal way, the set-screws being tightened with a torque equal to the values indicated in Table 12. The locking of the screwed entry is tested by the application for 1 min of a torque as indicated under 16.2, but in an anti-clockwise direction.*

The application of this torque shall not loosen the threaded entry from the brass conduit.

If, however, the threaded entry loosens, the set-screw is further tightened with the smallest torque necessary to prevent the entry from loosening during this test, and this minimum value is noted.

NOTE It is practical to increase the torque by increments of about 20 % during this test.

The minimum value of the torque applied is noted for the purpose of the test of 17.1.

For the tests under 16.2 to 16.4, the use of an apparatus according to Figure 6 is recommended.

16.5 The strength of the connection between dome and threaded entry is checked as indicated in Figure 12.

The specimen is fixed by the threaded entry in a horizontal position. A mandrel with a thread having the maximum IEC dimensions acceptable for caps, and with other dimensions according to Figure 12, is screwed into the lampholder and is loaded for 1 min with a mass, as indicated in Figure 12. The end of the mandrel shall not sag more than 5 mm.

The specimen shall not be damaged. If a permanent deformation occurs, the specimen is forced into the original position and the test is repeated five times, after which the specimen shall show no damage impairing its normal use.

This test does not apply to candle lampholders.

16.6 The mechanical strength of the outer shell of insulating material with or without a conductive outer surface and of insulating rings between the screw shell and the exterior of metal lampholders is checked by means of the pendulum hammer test specified in IEC 60068-2-75 (see Figure 8), subject to the following details (see 3.9 of IEC 60068-2-75:2014).

a) Method of mounting:

The specimen shall be held against the plywood sheet of the mounting fixture in such a manner that its axis is horizontal and parallel to the support and its outer edge touches the plywood.

NOTE For lampholders different from the cylindrical shape, the condition of the axis parallel to the plywood sheet can be obtained by adequate pine wood shimmings.

b) Height of fall:

The striking element shall fall from one of the heights given in Table 10.

Table 10 – Heights of fall

Material	Height of fall mm
Ceramic parts	100 ± 1
Parts made of other material	150 ± 1,5

Candle lampholders, if tested without decorative covers, shall, however, be tested with a height of fall of 100 mm.

c) Number of impacts:

Four blows shall be applied to points equally divided over the circumference of the outer edge of the shell and of the ring.

For lampholders of insulating material, the outer shell shall be hit at the outer edge. For metal lampholders, the outer shell shall be hit at the position of the insulating ring between the screw shell and the exterior.

For such candle lampholders as prescribed in b), one blow shall be applied in two places at 90° on the circumference. The blows shall be applied at 5 mm from the outer edge of the lampholder.

d) Pre-conditioning:

Not applicable.

e) Initial measurements:

Not applicable.

f) *Attitudes and impact locations:*

See c) above.

g) *Operating mode and functional monitoring:*

The sample shall not operate during impact.

h) *Acceptance and rejection criteria:*

After the test, the sample shall show no serious damage within the meaning of this standard, in particular

1) *live parts shall not have become accessible.*

Damage to the lampholder which does not reduce creepage distances or clearances below the values specified in Clause 18 and small chips which do not adversely affect the protection against electric shock or ingress of water shall be ignored;

2) *cracks not visible to the naked eye and surface cracks in fibre-reinforced mouldings and the like shall be ignored.*

Cracks or holes in the outer surface of any part of the lampholder shall be ignored if the lampholder complies with this standard even if that part is omitted.

i) *Recovery:*

Not applicable.

j) *Final measurements:*

See h) above.

The mechanical strength of lampholders E5 and E10 shall be checked by means of the free fall test specified in IEC 60068-2-32:1975.

The lampholder E5 or E10 shall withstand, without damage affecting safety, 50 falls of 500 mm onto a 3 mm thick steel plate in the tumbling barrel (see Figure 7) turning at 5 r/min (that is 10 falls per minute).

NOTE The mechanical strength of lampholders used in luminaires or other equipment can be checked by means of the spring hammer specified in IEC 60068-2-75. In IEC 60598-1, the test impact energy used varies from 0,2 Nm to 0,7 Nm depending on component material and luminaire type.

Additionally, for lampholders provided with a snap-on outer shell the following tests are carried out.

A push and a pull force along the lampholder axis is applied for 1 min. to the outer shell by means of a mass of 5 kg.

After this test the outer shell shall have remained in its intended position.

Additionally it shall not be possible to remove the outer shell by use of the standard fingertip, applied in all possible positions, with a force of 30 N.

16.7 For metal lampholders the mechanical strength of external metal parts (outer shell and dome) is tested by means of an apparatus according to Figure 9.

The various parts are tested on the complete lampholder. Each part is subjected twice for 1 min to a pressure as indicated in Table 11; the pressure is applied on two diameters at right angles to each other. The test is not made on outer shells and domes of insulating material with a conductive outer surface.

During and after the test, the deformation of the specimen shall not exceed the values indicated in Table 11.

Table 11 – Maximum deformation values

Lampholder	Pressure N	Maximum deformation	
		During the test mm	After the test mm
E14	75	1	0,3
E27	100	2	0,3
E40	100	4	0,5

This test does not apply to lampholders E5 and E10 and similar small lampholders.

16.8 Entry spouts and glands shall withstand the mechanical stresses occurring during normal fitting and use.

Compliance is checked by the following test.

Screwed glands are fitted with a cylindrical metal rod having a diameter equal to the nearest whole number of millimetres below the internal diameter of the packing. The glands are then tightened by means of a suitable spanner, a force of 30 N for metal glands, or 20 N for glands of moulded material, being applied for 1 min, at a radius of 25 cm.

At the end of the test, the glands, the spouts and the enclosures shall show no damage.

16.9 Backplate lampholders shall be designed to withstand fixing to a support without damage.

Compliance is checked by the following test.

The backplate of the lampholder is fixed by means of 4 mm screws to a rigid flat steel sheet. This sheet has two drilled and tapped holes at a distance equal to the distance between the axes of the fixing holes of the backplate. The screws are gradually tightened, the maximum torque applied being 1,2 Nm.

The backplate of lampholders shall be fixed by means of screws to a rigid flat steel sheet as follows:

- 3 mm screws for lampholders E10;
- 4 mm screws for lampholders other than E10.

The screws shall be gradually tightened, the maximum torque applied being:

- 0,5 Nm for 3 mm screws, and
- 1,2 Nm for 4 mm screws.

These requirements do not apply to lampholders E5.

For backplate lampholders specifically intended for building-in, this test is carried out with the means of attachment specified by the manufacturer.

After this test, the backplate lampholder shall show no damage impairing its further use.

17 Screws, current-carrying parts and connections

17.1 Screws and mechanical connections, the failure of which might cause the holder to become unsafe, shall withstand the mechanical stresses occurring in normal use.

Compliance is checked by inspection and by the following test.

NOTE 1 Screwed connections are already partially checked by the tests of Clause 16.

Screws and nuts which may be operated when connections are made to the lampholders are tightened and loosened

- *five times for screws operating in a female thread in metal;*
- *ten times for screws operating in a female thread in insulating material*

by means of a suitable test screwdriver applying a torque as indicated in Table 12, except for set-screws tightened with an increased torque during the test of 16.4 when the increased torque is applied. Column 1 applies to screws without heads if the screw, when tightened, does not protrude from the hole. Column 2 applies to other screws. Screws operating in a female thread in insulating material are each time completely removed and reinserted.

The test shall cause no damage impairing the further use of the screwed connections.

Table 12 – Torque values

Nominal diameter of screw mm	Torque Nm	
	1	2
Up to and including 2,8	0,2	0,4
Over 2,8 up to and including 3,0	0,25	0,5
Over 3,0 up to and including 3,2	0,3	0,6
Over 3,2 up to and including 3,6	0,4	0,8
Over 3,6 up to and including 4,1	0,7	1,2
Over 4,1 up to and including 4,7	0,8	1,8
Over 4,7 up to and including 5,3	0,8	2,0
Over 5,3 up to and including 6,0	–	2,5
Over 6,0 up to and including 8,0	–	8,0
Over 8,0 up to and including 10,0	–	17,0
Over 10,0 up to and including 12,0	–	29,0
Over 12,0 up to and including 14,0	–	48,0
Over 14,0 up to and including 16,0	–	114,0
NOTE Column 1 applies to screws without heads if the screw, when tightened, does not protrude from the hole. Column 2 applies to other screws.		

NOTE 2 Screws to be operated when connections are made to the holder include, for example, screws for fixing covers when they have to be loosened for making connections, etc. Conduit thread connections and screws to fasten the holders to their supports are excluded.

The shape of the blade of the test screwdriver shall suit the slot of the screw to be tested. The screw shall not be tightened in jerks.

17.2 In the case of screws operating in a thread in insulating material, the length of the thread shall be not less than 3 mm plus one-third of the nominal screw diameter, except that this length need not exceed 8 mm.

Correct introduction of the screw into the thread shall be ensured.

Compliance is checked by inspection, by measurement and by a manual test.

NOTE The requirement with regard to the correct introduction is met if introduction of the screw in a slanting manner is prevented, for example by guiding the screw by the part to be fixed, by a recess in the female thread or by the use of a screw with the leading thread removed.

17.3 Electrical connections shall be so designed that contact pressure is not transmitted through insulating material other than ceramic, unless there is sufficient resiliency in the metal parts to compensate for any possible shrinkage of the insulating material.

Screws shall not be of a metal which is soft or liable to creep, such as zinc or aluminium.

Screws transmitting contact pressure and screws with a nominal diameter of less than 3 mm which may be operated when connections are made to the lampholder, shall screw into a metal nut or metal insert; locking screws are excepted from this requirement.

Compliance is checked by inspection.

17.4 Screws and rivets, which serve as electrical as well as mechanical connections, shall be locked against loosening.

Compliance is checked by inspection and by a manual test.

NOTE 1 Spring washers can provide satisfactory locking. For rivets, a non-circular shank or an appropriate notch can be sufficient for locking.

NOTE 2 Sealing compound which softens on heating provides satisfactory locking only for screw connections not subject to torsion during normal use.

17.5 Current-carrying parts shall be of copper, an alloy containing at least 50 % copper or material having characteristics at least equivalent.

This requirement does not apply to screws which do not essentially contribute to the current conduction such as terminal screws.

Compliance is checked by inspection and, if necessary, by chemical analysis.

The tests of Clauses 19 and 22 will show whether current-carrying parts are equivalent to copper in respect to current-carrying capacity, mechanical strength and corrosion likely to be met in normal service.

Special care should be taken with regard to corrosion and mechanical properties.

18 Creepage distances and clearances

18.1 Creepage distances and clearances shall be not less than the values shown in Tables 13a and 13b, the lampholder being fitted as in normal use and a lamp being inserted into or removed from the lampholder.

The central contact of the lamp cap shall have a diameter of

- 2,4 mm for lampholders E5;
- 3,8 mm for lampholders E10;
- 5,5 mm for lampholders E14;
- 10,5 mm for lampholders E27;
- 16,0 mm for lampholders E40.

The movement of any floating part shall be so limited as to prevent a decrease of creepage distances or clearances below the specified values.

The distances specified in Table 13a apply to impulse withstand category II, the distances specified in Table 13b apply to impulse withstand category III in accordance with IEC 60664-1. Both tables refer to pollution degree 2, where normally only non-conductive pollution occurs but occasionally a temporary conductivity caused by condensation is to be expected.

NOTE 1 IEC 60664-1 gives information on distances for other impulse withstand categories and higher pollution degrees.

Attention is drawn to the fact that the values for creepage distance and clearance given in Clause 18 are the absolute minimum.

NOTE 2 The voltages shown in Tables 13a and 13b are rated voltages, not ignition voltages.

IECNORM.COM : Click to view the full PDF of IEC 60238:2016+AMD1:2017+AMD2:2020 CSV

**Table 13a – Minimum distances for AC sinusoidal voltages up to 30 kHz –
Impulse withstand category II**

Distances mm	Rated voltage V			
	50	150	250	500 ^d
Basic insulation				
1 Distances between live parts of different polarity, between live parts and a non-live screw shell, and				
2 Distances between live parts and external metal parts, mounting surfaces, loose metal cover, if any, the outer surface of parts of insulating material which are permanently fixed to the holder ^a , including screws or devices for fixing covers or fixing the holder to its support:				
– Creepage distances				
insulation PTI ≥ 600 ^b	0,6	0,8	1,5	3
PTI < 600 ^b	1,2	1,6	2,5	5
– Clearances ^{c d}	0,2	0,5	1,5	3
Reinforced insulation				
Distances between live parts and external metal parts, mounting surfaces, loose metal cover, if any, the outer surface of parts of insulating material which are permanently fixed to the holder ^a , including screws or devices for fixing covers or fixing the holder to its support:				
– Creepage distances				
insulation PTI ≥ 600 ^b	–	1,6	3	5,5
PTI < 600 ^b	–	3,2	5	10
– Clearances ^c	0,4	1,6	3	5,5
Values for creepage distances may be found for intermediate values of rated voltages by linear interpolation between tabulated values. No values are specified for rated voltages below 25 V AC and 60 V DC ripple free as the voltage test of 15.4 is considered sufficient. Creepage distances shall not be less than the required minimum clearance. For glass, ceramics or other inorganic insulating materials which do not track, creepage distances need not be greater than their associated clearance for the purpose of insulation coordination. The dimensions of this table are appropriate. In Japan, the values given in the table are not applicable. Japan requires larger values than the values given in the table.				
^a The distances between live contacts and the lampholder face (reference plane) shall, however, be in accordance with the relevant standard sheets of IEC 60061-2. ^b PTI (proof tracking index) in accordance with IEC 60112:2003 and IEC 60112:2003/AMD1:2009. – In the case of creepage distances to parts not energized or not intended to be earthed, where no tracking can occur, the values specified for material with PTI ≥ 600 apply for all materials (in spite of the real PTI). – For creepage distances subjected to working voltages of less than 60 s duration, the values specified for material with PTI ≥ 600 apply for all materials. – For creepage distances not liable to contamination by dust or moisture, the values specified for material with PTI ≥ 600 apply for all materials (independent of the real PTI). – For creepage distances, the equivalent DC voltage is equal to the r.m.s. value of the sinusoidal AC voltage. ^c For clearances, the equivalent DC voltage is equal to the peak of the AC voltage. ^d Clearances between live parts and a non-live metal screw shell in an empty lampholder (unscrewed lamp) can be reduced to 2 mm.				

**Table 13b – Minimum distances for AC sinusoidal voltages up to 30 kHz –
Impulse withstand category III**

Distances mm	Rated voltage V			
	50	150	250	500 ^d
Basic insulation				
1 Distances between live parts of different polarity and between live parts and a non-live screw shell – Creepage distances insulation PTI $\geq 600^b$ PTI $< 600^b$ – Clearances ^{c d}				
	0,6	0,8	1,5	3
	1,2	1,6	2,5	5
	0,2	0,5	1,5	3
2 Distances between live parts and external metal parts, mounting surfaces, loose metal cover, if any, the outer surface of parts of insulating material which are permanently fixed to the holder ^a , including screws or devices for fixing covers or fixing the holder to its support: – Creepage distances insulation PTI $\geq 600^b$ PTI $< 600^b$ – Clearances ^c				
	0,6	1,5	3	5,5
	1,2	1,6	3	5,5
	0,2	1,5	3	5,5
Reinforced insulation				
Distances between live parts and external metal parts, mounting surfaces, loose metal cover, if any, the outer surface of parts of insulating material which are permanently fixed to the holder ^a , including screws or devices for fixing covers or fixing the holder to its support: – Creepage distances insulation PTI $\geq 600^b$ PTI $< 600^b$ – Clearances ^c				
	-	3	5,5	8
	-	3,2	5,5	10
	-	3	5,5	8
Values for creepage distances may be found for intermediate values of rated voltages by linear interpolation between tabulated values. No values are specified for rated voltages below 25 V AC and 60 V DC ripple free as the voltage test of 15.4 is considered sufficient. Creepage distances shall not be less than the required minimum clearance. For glass, ceramics or other inorganic insulating materials which do not track, creepage distances need not be greater than their associated clearance for the purpose of insulation coordination. The dimensions of this table are appropriate. In Japan, the values given in the table are not applicable. Japan requires larger values than the values given in the table.				

- | |
|--|
| <p>^a The distances between live contacts and the lampholder face (reference plane) shall, however, be in accordance with the relevant standard sheets of IEC 60061-2.</p> <p>^b PTI (proof tracking index) in accordance with IEC 60112:2003 and IEC 60112:2003/AMD1:2009.</p> <ul style="list-style-type: none">– In the case of creepage distances to parts not energized or not intended to be earthed, where no tracking can occur, the values specified for material with $PTI \geq 600$ apply for all materials (in spite of the real PTI).– For creepage distances subjected to working voltages of less than 60 s duration, the values specified for material with $PTI \geq 600$ apply for all materials.– For creepage distances not liable to contamination by dust or moisture, the values specified for material with $PTI \geq 600$ apply for all materials (independent of the real PTI).– For creepage distances, the equivalent DC voltage is equal to the r.m.s. value of the sinusoidal AC voltage. <p>^c For clearances, the equivalent DC voltage is equal to the peak of the AC voltage.</p> <p>^d Clearances between live parts and a non-live metal screw shell in an empty lampholder (unscrewed lamp) can be reduced to 2 mm.</p> |
|--|

NOTE 3 Information on standard ratings for specific holder types is given in Clause 6.

The clearances for the rated ignition voltage of the holder shall not be less than the values given in Table 14.

NOTE 4 Lampholders can be subjected to a working voltage higher than the rated voltage under the following conditions:

- the nominal voltage and the overvoltage category of the supply voltage does not exceed the rated values of the lampholder;
- the working voltage (r.m.s.) and the maximum repetitive peak working voltage ($\hat{U}_{out}$) marked on the controlgear respectively do not specify a higher creepage distance than the rated voltage of the lampholder;
- the working voltage does not specify a higher clearance than the rated voltage and the rated ignition voltage of the lampholder.

NOTE 5 In case of combination of voltage and frequency (> 30 kHz) requiring higher creepage distances than the values required in Tables 13a and 13b, the controlgear is marked with the details of this combination ($\hat{U}_{out}$ and its corresponding frequency fU_{out}), see IEC 61347-1:2015, 7.1, item w). For details and the required values for creepage distances see IEC 61347-1:2015, 16.2.

Metal locking devices (see 10.3) for the coupling between outer shell and dome are considered as follows:

- if the locking device forms part of the centre contact, the clearances according to footnote "a" of Table 13a and Table 13b, applies;
- if the locking device forms part of the side contact(s), footnote "d" of Table 13a or Table 13b applies;
- if the locking device is a separate part, it shall only be taken into account in so far as it shortens any other required distance.

**Table 14 – Minimum distances for ignition pulse voltages
or equivalent peak voltages U_p**

Rated ignition pulse voltage kV	Minimum clearance mm	
	Basic insulation	Reinforced insulation
2	1	2,2
2,5	1,5	3
3	2	3,8
4	3	6
5	4	8
6	5,5	10,4
8	8	15

For distances subjected to both sinusoidal voltages and non-sinusoidal pulse voltages, the minimum required distance shall not be less than the highest value indicated in Tables 13a or 13b or 14.

Creepage distances shall be not less than the required minimum clearance.

Minimum creepage distances and clearances between live parts of different polarity shall be reduced to 1 mm for lampholders E5 and to 2 mm (for $PTI < 600$) for lampholders E10 intended for series connected lamps (maximum rated voltage 25 V for lampholders E5 and 60 V for lampholders E10).

Compliance is checked by measuring with and without supply wires of the largest cross-sectional area according to 11.1 connected to the terminals.

NOTE 6 Ignition pulse voltages having a total pulse duration of $> 750 \mu s$ or having a higher frequency than f_{crit} can require higher clearances although its peak value is lower than the rated ignition voltage of the lampholder. Therefore, the respective controlgear is marked with an equivalent peak voltage (U_p) which is directly comparable to the rated ignition voltage of the lampholder.

18.2 Sealing compound shall not protrude above the edge of the cavity.

Compliance is checked by inspection.

19 Normal operation

Normal use shall cause no excessive wear or other harmful effect.

Insulation and protection against accidental contact shall not be seriously affected. Linings, barriers and the like shall have adequate mechanical strength and shall be reliably fixed.

Temperature rise and vibration to be expected in normal use shall not cause loosening of electrical connections.

Compliance is checked by the following test.

The specimen shall be placed in a test apparatus as shown in Figure 4. A corresponding test cap, according to Figure 5 shall be screwed in and out 100 times at a rate of about 15 times per minute.

The lampholder shall be fixed during half the number of operations by the threaded entry, dome or backplate according to the type of lampholder, and during the other half clamped at the outer shell.

The test cap (see Figures 13, 14 and 15) is screwed in with a torque of

- 0,4 Nm for candle lampholders E14;
- 1 Nm for lampholders E14;
- 1,5 Nm for lampholders E27;
- 3 Nm for lampholders E40.

At the end of the test, the specimen shall show

- *no wear impairing its operation;*
- *no damage impairing protection against electric shock;*
- *no loosening of electrical contacts;*
- *no loosening of the connection between shell and dome;*
- *no loosening of the set screw locking the threaded entry.*

Finally the specimen shall comply with the requirements of 9.2 and shall withstand an electric strength test according to 15.4, the test voltage being 500 V lower in each case.

NOTE The moisture treatment of Clause 15 is not repeated before this voltage test.

These requirements do not apply to lampholders E5 and E10.

20 General resistance to heat

20.1 Lampholders shall be sufficiently resistant to heat.

Compliance is checked by the tests of 20.2 to 20.4.

20.2

- *For E27 lampholders:*

The lampholder is first checked by means of the gauges according to the current edition of standard sheets 7006-22C and 7006-22D of IEC 60061-3.

After these tests, a solid steel (preferably stainless steel) test cap complying with Figure 14 is screwed into the lampholder, mounted according to its intended use, with a torque of 1,5 Nm. The lampholder, with the test cap screwed in, is then placed in a vertical holder-up position (because the weight of the test cap shall not bear on the holder), in a heating cabinet having a temperature of approximately 85 °C.

This temperature is raised to 175 °C within 1 h ± 15 min. For lampholders which form an integral part of the luminaire, this temperature is replaced by that one measured according to the operating conditions given in 12.4.2 of IEC 60598-1, plus 10 K, with a tolerance of ±5 °C.

After reaching and maintaining this temperature, the lampholder is loaded for 48 h with a current equal to the rated current of the lampholder.

After this period, the lampholder is removed from the heating cabinet and allowed to cool down for 24 h without the test cap.

The tests with gauges 7006-22C and 7006-22D of IEC 60061-3 are then repeated.

The lampholder shall still comply with these gauges.

- *For E14 lampholders:*

A solid steel (preferably stainless steel) test cap B complying with Figure 13 is screwed into a candle lampholder E14, mounted according to its intended use, with a torque of 0,4 Nm and into all other lampholders E14 with a torque of 1 Nm. The lampholder, with test cap B screwed in, is then placed in a vertical holder-up position (because the weight of the test cap shall not bear on the holder), in a heating cabinet having a temperature of approximately 70 °C. This temperature is raised to 145 °C within 1 h $\pm$ 15 min. For lampholders which form an integral part of the luminaire, this temperature is replaced by that one measured according to the operating conditions given in 12.4.2 of IEC 60598-1, plus 10 K, with a tolerance of $\pm$ 5 °C.

After reaching and maintaining this temperature, the lampholder is loaded for 48 h with a current equal to the rated current of the lampholder.

After this period, the lampholder is removed from the heating cabinet and allowed to cool down for 24 h without the test cap.

A solid brass cap A complying with Figure 13 is then screwed into the lampholder with the same torque and then unscrewed. This sequence of operations is performed 10 times, after which the contact resistance between the terminals of the lampholder is measured.

This measurement is made at the rated current of the lampholder, in an AC circuit of not more than 6 V; for switched lampholders the contact resistance in the switch is neglected. The measured contact resistance shall not exceed 0,02 Ω .

NOTE 1 Test cap A is carefully cleaned and polished before being screwed into the lampholder for the contact resistance measurement.

– For E27 and E14 lampholders:

T-marked lampholders shall be tested at the marked temperature plus 10 °C.

Lampholders intended for use in refrigerators and food freezers shall be tested at the upper value of the rated operating temperature plus 10 °C.

NOTE 2 The value of 10 °C is being studied and is temporarily kept in line with the present requirements for E27 lampholders.

These requirements do not apply to lampholders E5, E10 and E40.

20.3 Contacts and all other current-carrying parts shall be so constructed as to prevent excessive temperature rise.

Compliance is checked by the following test which shall be made immediately after the test of 20.2 on the lampholder in whose terminals conductors of the maximum cross-sectional area according to 11.1 are fitted.

The terminal screws are tightened with a torque equal to two-thirds of the torque specified in 17.1; the lampholder is placed with the open end downwards and loaded for 1 h with 1,25 times its rated current.

The temperature rise of terminals shall not exceed 45 K.

This temperature is determined with the aid of melting particles or by thermocouples, not by means of thermometers.

For this test, a special test cap shown in Figure 11 is used.

After the test, it is verified that, as required in 11.4, the conductors are not damaged.

NOTE Pellets of beeswax (diameter 3 mm, melting temperature 65 °C) can be used as melting particles provided that the ambient temperature equals 20 °C.

These requirements do not apply to lampholders E5 and E10 with a rated voltage not exceeding 60 V.

20.4 The resistance to heat is then tested in a heating cabinet at the temperature indicated in Table 15.

Table 15 – Heating cabinet temperatures

Lampholder	Temperature °C
E10 general	75
E5 and E10 integral part of luminaire ^a	75 or measured temperature + 15 (whichever is the highest)
E14	170
E27	200
E40	260
^a For E5, E10 and similar small lampholders which form an integral part with the luminaire such as Christmas tree lighting chains, the temperature is measured in the luminaire on the lamp cap at a distance of 2 mm from the lamp glass-to-cap junction.	

T-marked lampholders are tested at the marked temperature plus 35 K.

Lampholders intended for use in refrigerators and food freezers are tested:

- a) at the rated minimum temperature, and*
- b) at the rated operating temperature plus 35 K.*

In case of a) the duration of the test shall be reduced to 16 h.

Immediately after this test, the lampholders shall once more be subjected to the test of 16.6.

A solid steel (preferably stainless steel) test cap complying with Figure 13 (test cap B), 14 or 15 is screwed fully home in the lampholder. The lampholder with the test cap screwed in is then placed in a vertical holder-up position (because the weight of the test cap shall not bear on the holder), in a heating cabinet having approximately half the temperature specified in Table 15. This temperature is raised to the required test temperature within 1 h ± 15 min. Following this, the test is continued for 168 h without interruption.

The test temperature is maintained with a tolerance of ±5 K.

During the test, the lampholder shall not undergo any change impairing its further use especially in the following respects:

- reduction of the protection against electric shock;*
- loosening of electrical contacts;*
- cracks, swelling or shrinking;*
- sealing compound flowing out.*

The test cap is removed from the lampholder after cooling down to approximate room temperature.

At the end of the test, it is checked if the Edison threads are not deformed. The test is made by means of the "Go" gauges shown in the current edition of standard sheets 7006-25 or 7006-25A of IEC 60061-3, as appropriate.

In addition, the holder shall withstand the mechanical strength tests made under the conditions specified in 16.2 and 16.6, the torque, however, being reduced to 50 % of the original value and the height of fall being reduced to 5 cm, respectively.

Sealing compound shall not flow to such an extent that live parts are exposed; a mere displacement of the compound is neglected.

This test is not made on integral lampholders.

21 Resistance to heat, fire and tracking

21.1 Parts retaining the contacts and external parts of lampholders of insulating material and of lampholders comprising external parts of insulating material with a conductive outer surface shall be resistant to heat.

For material other than ceramic, compliance is checked with the aid of the ball-pressure test by means of the apparatus shown in Figure 10.

All the tests required by Clause 21 of this standard are not performed on lampholders which are integral with a luminaire, as similar tests are required in Clause 13 of IEC 60598-1. However, the operating conditions of these tests will take into account those specific to lampholders and defined in Clause 21 of this standard.

For lampholders E5 and E10, only the parts retaining the contacts are subjected to the ball-pressure test.

The surface of the part under test is placed in the horizontal position and a steel ball of 5 mm diameter is pressed against this surface with a force of 20 N.

The test is made in a heating cabinet at a temperature shown in 20.4, except for lampholders E5 and E10, where the temperature is 125 °C.

The test load and the supporting means are placed in the heating cabinet for a sufficient time to ensure that they have attained the stabilized testing temperature before the test commences.

The part to be tested is placed in the heating cabinet for a period of 1 h, before the test load is applied.

If the surface under test bends, the part where the ball presses is supported. For this purpose, if the test cannot be made on the complete specimen, a suitable part may be cut from it.

The specimen shall be at least 2,5 mm thick, but if such a thickness is not available on the specimen then two or more pieces are placed together.

After 1 h, the ball is removed from the specimen which is then immersed within 10 s in cold water for cooling down to approximately room temperature. The diameter of the impression caused by the ball is measured and shall not exceed 2 mm.

NOTE In the event of curved surfaces, such as lampholder shells, the shorter axis is measured if the indent is elliptical.

21.2 External parts of insulating material (outer shell, screw shell, dome or backplate) providing protection against electric shock, and parts of insulating material (terminal/contact assembly) retaining live parts or extra-low voltage (ELV) parts in position, shall be resistant to flame and ignition.

For materials other than ceramic, compliance is checked by the test of 21.3 or 21.4.

Screw shells which are only live when a lamp is inserted into the lampholder are not deemed to be live parts for the purpose of this requirement.

Insulating material retaining such shells in place is therefore checked by the test of 21.3.

21.3 External parts of insulating material, including those with a conductive exterior, providing protection against electric shock, and parts of insulating material retaining ELV parts in position, are subjected to the glow-wire test in accordance with IEC 60695-2-11:2014, subject to the following details.

- *The specimen is a complete holder. It may be necessary to take away parts of the holder to perform the test, but care should be taken to ensure that the test conditions are not significantly different from those occurring in normal use.*
- *The specimen is mounted on the carriage and pressed against the glow-wire tip with a force of 1 N, preferably 15 mm or more from the upper edge, into the centre of the surface to be tested. The penetration of the glow-wire into the specimen is mechanically limited to 7 mm.*

If it is not possible to make the test on a specimen as described above because the specimen is too small, the above test is made on a separate specimen of the same material, 30 mm × 30 mm square and with a thickness equal to the smallest thickness of the specimen.

- *The temperature of the tip of the glow-wire is 650 °C.*

After 30 s the specimen is withdrawn from contact with the glow-wire tip. The glow-wire temperature and heating current are constant for 1 min prior to commencing the test. Care should be taken to ensure that heat radiation does not influence the specimen during this period. The glow-wire tip temperature is measured by means of a sheathed fine wire thermocouple constructed and calibrated as described in IEC 60695-2-11:2014.

- *Any flame or glowing of the specimen shall extinguish within 30 s of withdrawing the glow-wire and any flaming drops of the material shall not ignite a piece of tissue paper, as specified in definition 4.187 of ISO 4046-4:2002, spread out horizontally 200 mm ± 5 mm below the specimen.*

21.4 Parts of insulating material retaining live parts or ELV lamp contacts in position are subjected to the needle-flame test in accordance with IEC 60695-11-5, subject to the following details.

- *The specimen is a complete lampholder. It may be necessary to take away parts of the lampholder to perform the test (for example contacts, which would otherwise shield the area to be tested), but care should be taken to ensure that the test conditions are not significantly different from those occurring in normal use.*
- *The test flame is applied to the centre of the surface to be tested.*
- *The duration of application is 10 s.*
- *Any self-sustaining flame shall extinguish within 30 s of removal of the gas flame and any flaming drops of the material shall not ignite a piece of tissue paper, spread out horizontally 200 mm ± 5 mm below the specimen.*

NOTE For additional information see the explanatory sheet, Figure 18.

21.5 For drip-proof lampholders, insulating parts retaining live parts or ELV parts in position shall have adequate resistance to tracking.

For materials other than ceramic, compliance shall be checked by the proof tracking test in accordance with IEC 60112:2003/AMD1:2009, subject to the following details.

- *If the specimen has no flat surface of at least 15 mm × 15 mm, the test may be carried out on a flat surface with reduced dimensions provided drops of liquid do not flow off the specimen during the test.*

No artificial means should, however, be used to retain the liquid on the surface. In case of doubt, the test may be made on a separate strip of the same material, having the required dimensions and manufactured by the same process.

- *If the thickness of the specimen is less than 3 mm, two specimens, or more if necessary, should be stacked to obtain a thickness of at least 3 mm.*
- *The test shall be made at three places of the specimen or on three specimens.*
- *The electrodes shall be of platinum, and test solution A specified in 7.3 of IEC 60112:2003/AMD1:2009 shall be used.*
- *For drip-proof lampholders the specimen shall withstand 50 drops without failure at a test voltage of PTI 175.*
- *A failure has occurred if a current of 0,5 A or more flows for at least 2 s in a conducting path between the electrodes on the surface of the specimen, thus operating the overcurrent relay, or if the specimen burns without releasing the overcurrent relay.*
- *Clause 9 of IEC 60112:2003/AMD1:2009 regarding determination of erosion, does not apply.*

22 Resistance to excessive residual stresses (season cracking) and to rusting

22.1 *Contacts and other parts of rolled sheets of copper or copper alloy whose failure might cause the lampholder to become unsafe shall not be damaged due to excessive residual stresses.*

Compliance is checked by the following test.

The surface of the specimens is carefully cleaned, varnish being removed by acetone, and grease and finger prints by petroleum spirit or the like.

The specimens are placed for 24 h in a test cabinet, the bottom of which is covered by an ammonium chloride solution having a pH value of 10 (for details of the test cabinet, the test solution and the test procedure, see Annex A).

After this treatment, the specimens are washed in running water; 24 h later they shall show no cracks when inspected at an optical magnification of 8×.

Cracks which may occur in very restricted areas of the outer shell of metal lampholders near the fixing areas of the insulating ring shall not be considered.

In order not to influence the results of the test, the specimens should be handled with care.

22.2 *Ferrous parts, the rusting of which may endanger the safety of the lampholder, shall be adequately rust protected.*

Compliance is checked by the following test.



All grease is removed from parts to be tested by immersion in a suitable degreasing agent for 10 min. The parts are then immersed for 10 min in a water solution of 10 % ammonium chloride at a temperature of 20 °C ± 5 °C.

Without drying, but after shaking off drops of water, the parts are placed for 10 min in a box containing air saturated with moisture at a temperature of 20 °C ± 5 °C.

After the parts have been dried for 10 min in a heating cabinet at a temperature of 100 °C ± 5 °C, any traces of rust on sharp edges and any yellowish film may be removed by rubbing, after which their surface shall show no signs of rust.

For small helical springs and the like, and for ferrous parts exposed to abrasion, a layer of grease is deemed to provide sufficient rust protection.

Such parts are not subjected to the test.




Dimensions in millimetres

Designation	s	Screw					Nut				
		d		d2		d1	D	D2		D1	
		Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.
M8×1	1	8,000	7,800	7,350	7,238	6,917	8,000	7,462	7,350	7,117	6,917
M10×1	1	10,000	9,800	9,350	9,238	8,917	10,000	9,462	9,350	9,117	8,917
M13×1	1	13,000	12,800	12,350	12,190	11,917	13,000	12,510	12,350	12,117	11,917
M16×1	1	16,000	15,800	15,350	15,190	14,917	16,000	15,510	15,350	15,117	14,917

^a The basic profile is the profile to which the deviations defining the limits of the external and the internal threads are applied.

**Figure 1a –Nipple thread for lampholders: metric thread.
Basic profile and design profile for the nut and for the screw**



$$h = 0,960\,491\,s$$


$$h/6 = 0,160\,082\,s$$

$$t_0 = 2/3h = 0,640\,327\,s$$

$$r = 0,137\,329\,s$$

Basic profile ^a

Design profile for the nut



Design profile for the screw

IEC

Dimensions in millimetres


Designation	n ^a	Screw					Nut				
		d		d2		d1	D	D2		D1	
		Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.
G3/8A	19	16,662	16,412	15,806	15,681	14,950	16,662	15,931	15,806	15,395	14,50

^a Number of threads per inch.

^a The basic profile is the profile to which the deviations defining the limits of the external and the internal threads are applied.

Figure 1b –Nipple thread for lampholders: ISO standard pipe thread.
Basic profile and design profile for the nut and for the screw

Gauges for the screw



--- Basic profile (see Figure 1a)

"Go" gauge

"Not Go" gauge


IEC

Dimensions in millimetres

Designation	s	d		d2		d1		Wear
		Value	Tolerance	Value	Tolerance	Value	Tolerance	
M10×1	1	9,800	+0,004 -0,004	9,350	-0,012 -0,020	8,917	+0,004 -0,004	0,012
M13×1	1	12,800	+0,004 -0,004	12,350	-0,012 -0,020	11,917	+0,004 -0,004	0,012
M16×1	1	15,800	+0,004 -0,004	15,350	-0,012 -0,020	14,917	+0,004 -0,004	0,012

NOTE The tolerances in column d2 are deliberately positioned both on the same side of the dimension to safeguard a no-man's-land.

Gauges for the nut



--- Basic profile (see Figure 1a)

"Go" gauge

"Not Go" gauge

IEC


Dimensions in millimetres

Designation	s	D		D2		D1		Wear
		Value	Tolerance	Value	Tolerance	Value	Tolerance	
M10×1	1	10,000	+0,004 -0,004	9,350	+0,012 +0,020	9,117	+0,004 -0,004	0,012
M13×1	1	13,000	+0,004 -0,004	12,350	+0,012 +0,020	12,117	+0,004 -0,004	0,012
M16×1	1	16,000	+0,004 -0,004	15,350	+0,012 +0,020	15,117	+0,004 -0,004	0,012

NOTE The tolerances in column D2 are deliberately positioned both on the same side of the dimension to safeguard a no-man's-land.

Figure 2a – Gauges for metric thread for nipples

Gauges for the screw



--- Basic profile (see Figure 1b)

▨ "Go" gauge

▨ "Not Go" gauge


IEC

Dimensions in millimetres

Designation	n ^a	d		d2		d1		Wear
		Value	Tolerance	Value	Tolerance	Value	Tolerance	
G3/8A	19	16,412	+0 -0,008	15,806	+0 -0,020	14,950	+0 -0,018	–

^a Number of threads per inch.

Gauges for the nut



--- Basic profile (see Figure 1b)

▨ "Go" gauge

▨ "Not Go" gauge


IEC

Dimensions in millimetres

Designation	n ^a	D		D2		D1		Wear
		Value	Tolerance	Value	Tolerance	Value	Tolerance	
G3/8A	19	16,662	+0,018 -0,005	15,806	+0,005 +0,028	15,395	+0,008 -0	0,005

^a Number of threads per inch.


Figure 2b – Gauges for ISO standard pipe thread for nipples



Dimensions in millimetres


Reference	Dimension	Tolerance	
		Manufacture	Wear
a	4,1	+0,03 –0,0	+0,0 –0,03
b	8,2	+0,03 –0,0	+0,0 –0,03
c	18	+0,1 –0,1	– –

Figure 3 – Gauge for holes for backplate lampholder screws




IEC

Figure 4 – Normal operation test apparatus



IEC

Figure 5a – Test cap E14/E27



IEC

Figure 5b – Test cap E40


Material: Hardened steel

The dimensions of the thread on the test cap shall be between the maximum and minimum values specified for E14, E27 and E40 caps in standard sheets 7004-23, 7004-21 and 7004-24 of IEC 60061-1, respectively.

Dimensions in millimetres

Lampholder	C	E	G	H	H1	S	T	α	β
E14	–	12	17	4,8	–	4	17	45°	45°
E27	–	23	32	9,5	–	7,7	23	45°	45°
E40	0,5	–	50	14	17	–	35	45°	45°
Tolerance	+0,1 –0,1	–	+0,5 –0,5	+0,1 –0,1	+0,1 –0	+0,1 –0	+0,1 –0,1	+30' –30'	+1° –1°

Figure 5 – Test caps for the test of Clause 18




Test cap

IEC

Figure 6 – Torque apparatus

Dimensions in millimetres (unless otherwise indicated)



IEC

The body of the tumbling barrel shall be made of steel sheet of 1,5 mm thickness.

The compartments where the sample rests between individual falls shall be backed by a rubber part made of chip-resistant rubber with a hardness of 80 IRHD and the sliding surfaces of these parts shall be made of laminated plastic sheet³.

The tumbling barrel shall be provided with an aperture with lid made of transparent acrylic.

The shaft of the tumbling barrel shall not protrude into the barrel itself.


Figure 7 – Tumbling barrel

³ Formica® is an example of a suitable product available commercially. This information is given for the convenience of users of this document and does not constitute an endorsement by IEC of this product.

Dimensions in millimetres

NOTE For information, this drawing has been retained in this standard, although there is a basic standard.


In case of doubt regarding the drawing, refer to IEC 60068-2-75.



IEC

Figure 8a – Impact-test apparatus

Dimensions in millimetres (unless otherwise indicated)




IEC

NOTE For information this drawing has been retained in this standard, although there is a basic standard. In case of doubt regarding the drawing, refer to IEC 60068-2-75.


Figure 8b – Mounting support

Figure 8 – Impact-test apparatus




IEC

Figure 9 – Pressure apparatus



IEC

Figure 10 – Ball-pressure test apparatus



Tolerances for values without any indication:

- up to and including 30 mm: $\pm 0,05$;
- over 30 mm: $\pm 0,1$;
- on angles: $\pm 30'$.

IEC

^a The insulating material shall be such that it is dimensionally stable, easy to shape and having a PTI of 600; PTFE, for example, is a suitable material.

^b Refers to the metal part only; not applicable to test cap E10.
The dimensions of the thread on the test cap shall be between the maximum and minimum values specified for E10, E14, E27 and E40 caps in standard sheets 7004-22, 7004-23, 7004-21 and 7004-24 of IEC 60061-1, respectively. The inner diameter of the brass cap shall be 2 mm less than the dimension d1 indicated on the relevant standard sheet. The cross-sectional area of the conductors shall be 0,75, 1,5, 1,5 and 4,0 mm² for E10, E14, E27 and E40, respectively. The conductors shall be rigid (solid or stranded).

^c For the E14 test cap, a 45° chamfer is required on the cylindrical portion of the gauge.

NOTE Values for E5 lampholders are under consideration.


Dimensions in millimetres

Lampholder	d	h	B	C1	C2	H	S	E	T min.	K min.	A max.
E10	18	60	6	0,5	2,5	4	–	–	9,5	19	13
E14	38	80	9,5	0,5	3,8	6,2	4,5	12	16	27,2	17,1
E27	38	80	13,5	0,5	4,2	11,5	8,5	23	21,5	28,3	26,1
E40	55	100	25	1	8	18	10 ^a	34 ^a	34	47,8	39

^a In case of lampholders E40, dimensions S and E are only needed for the design of the gauges.

Figure 11 – Test cap for the tests of 15.4 and 20.3

Dimensions in millimetres



IEC

Lampholder	a	b	G kg
E14	19	100	1
E27	25	100	2
E40	37	140	3

Figure 12 – Bending apparatus

Dimensions in millimetres (unless otherwise indicated)




Figure 13a – Test cap A




Figure 13b – Test cap B

- ^a The dimensions of the thread on test cap A shall be between the maximum and minimum values specified in standard sheet 7004-23 of IEC 60061-1.
- ^b The dimensions of the thread on test cap B shall be the minimum values, with a tolerance of $\pm 0,05$ mm, specified in standard sheet 7004-23 of IEC 60061-1.


Figure 13 (1 of 2)

Dimensions in millimetres (unless otherwise indicated)

Reference	Dimensions		Tolerances	
	Test cap A	Test cap B	Test cap A	Test cap B
C1	0,5	1,0	+0,0 –0,1	+0,0 –0,1
C2	2,5	3,0	+0,0 –0,1	+0,0 –0,1
D	3,5	–	+0,1 –0,0	–
S	4,5	4,0	+0,06 –0,0	+0,0 –0,06
H1	4,8	4,8	+0,04 –0,04	+0,04 –0,04
H2	6	6	+0,04 –0,04	+0,04 –0,04
B	10	10	+0,04 –0,0	+0,06 –0,0
E	12	12	–	–
β	–	45°	–	+10' –10'

Figure 13 – Test cap A and test cap B for lampholders E14 (2 of 2)

Dimensions in millimetres (unless otherwise indicated)




Reference	Dimension	Tolerance
C1	1,2	+0,0 -0,04
C2	4,2	+0,0 -0,06
D1	5,45	+0,1 -0,0
D2	7,2	+0,1 -0,0
S	7,7	+0,0 -0,04
H1	9,5	+0,04 -0,04
H2	12,5	+0,04 -0,04
B1	18,5	+0,06 -0,0
B2	20	+0,06 -0,0
B3	22	+0,06 -0,0
E	23	-

IEC

^a The dimensions of the thread on the test cap shall be the minimum values, with a tolerance of $\pm 0,05$ mm, specified in standard sheet 7004-21 of IEC 60061-1.

Figure 14 – Test cap for lampholders E27

Dimensions in millimetres (unless otherwise indicated)



Reference	Dimension	Tolerance
C1	1,5	+0,0 -0,1
C2	7	+0,0 -0,1
S	9	+0,0 -0,06
H1	14	+0,04 -0,04
H2	19	+0,04 -0,04
B	30	+0,06 -0,0
E ^a	34	—
β	45°	+10' -10'

IEC

^a The dimensions of the thread on the test cap shall be the minimum values, with a tolerance of $\pm 0,05$ mm, specified in standard sheet 7004-24 of IEC 60061-1.


Figure 15 – Test cap for lampholders E40

[illegible]

Material: metal, except where otherwise specified.

on angles: 0'–10'
on linear dimensions:
- up to 25 mm: 0/–0,05 mm
- over 25 mm: ±0,2 mm

Figure 16 – Standard test finger (according to IEC 60529)



IEC


Key

- 1 terminal/contact assembly
- 2 outer shell
- 3 screw shell
- 4 insulating ring
- 5 shade ring
- 6 dome
- 7 threaded entry

The drawings are intended only to show typical parts of a lampholder and should not limit the design.

^a In this example, parts 2, 3 and 4 are permanently connected together. In other constructions parts 1 and 3 may form one assembly.


Figure 17 – Clarification of some definitions



IEC

For E14 and E27 lampholders, a slot having a width of 5 mm is made to allow entry of the needle and for ventilation.

For E40 lampholders no slot is required.



IEC

The left hand drawing shows how to perform the needle-flame test for testing the side-contact area (not applicable to lampholders E40).

The right-hand drawing shows how to perform the needle-flame test for testing the centre-contact area.

The minimum length of the needle is 35 mm.

Figure 18 – Preparation of specimens for the needle-flame test of 21.4

Annex A (normative)

Season cracking/corrosion test

In the interest of environmental protection, the following requirements relating to test solution, volume and volume of vessel can be modified at the discretion of the test laboratory.

In this event, the test vessel should retain a volume in the range 500 to 1 000 times larger than the volume of the sample and the volume of test solution should be such that the ratio of vessel volume to solution volume is in the range of 20:1 to 10:1. In case of doubt, however, the conditions of Clause A.1 apply.

A.1 Test cabinet

Closeable glass vessels shall be used for the test. These may, for example, be desiccator vessels or simple glass troughs with ground rim and lid. The vessel volume shall be at least 10 l.

A certain ratio of test space to volume of test solution shall be maintained (20:1 to 10:1).

A.2 Test solution

Preparation of 1 l of solution:

Dissolve 107 g ammonium chloride (reagent grade NH_4Cl) in about 0,75 l of distilled or fully demineralized water and add as much of 30 % sodium hydroxide solution (prepared from reagent grade NaOH and distilled or fully demineralized water) as is necessary to reach a pH value of 10 at 22 °C. For other temperatures, adjust this solution to the corresponding pH values specified in Table A.1.

Table A.1 – pH adjustment

Temperature °C	Test solution pH
22 ± 1	10,0 ± 0,1
25 ± 1	9,9 ± 0,1
27 ± 1	9,8 ± 0,1
30 ± 1	9,7 ± 0,1

After the pH adjustment, make up to 1 l with distilled or fully demineralized water. This does not change the pH value any further.

Keep the temperature constant in any event to within ±1 °C during the pH adjustment, and carry out the pH measurement using an instrument which permits an adjustment of the pH value to within ±0,02.

The test solutions may be used over a prolonged period, but the pH value, which represents a measure of the ammonia concentration in the vapour atmosphere, shall be checked at least every three weeks and adjusted if necessary.

A.3 Test procedure

Introduce, preferably suspended, the specimens in the test cabinet in such a way that the ammonia vapour can take effect unhindered. The specimens shall not dip into the test solution nor touch each other. Supports or suspension devices shall be made of materials which are not susceptible to attack by ammonia vapour, e.g. glass or porcelain.

Testing shall be carried out at a constant temperature of $(30 \pm 1) ^\circ\text{C}$ to exclude visible condensed water formation caused by temperature fluctuations, which could severely falsify the test result.

Prior to testing, the test cabinet containing the test solution shall be brought to a temperature of $(30 \pm 1) ^\circ\text{C}$. The test cabinet shall subsequently be filled as quickly as possible with the specimens pre-heated to $30 ^\circ\text{C}$ and closed.

This moment is to be considered the beginning of the test.

IECNORM.COM : Click to view the full PDF of IEC 60238:2016+AMD1:2017+AMD2:2020 CSV

Annex B (informative)

Guidance for requirements in IEC 61058-1 applicable to switches in lampholders (see 14.2)

The clauses and subclauses mentioned in Annex B refer to IEC 61058-1:2000.

6 Rating

Subclauses 6.1 and 6.3 are applicable with the following limitations:

6.1 The maximum rated voltage is 250 V.

6.3 The maximum rated current is 2 A.

7.1 Classification of switches

7.1.1 According to nature of supply

Only 7.1.1.1 is applicable.

7.1.2 According to type of load to be controlled by each circuit of the switch

Only 7.1.2.4, 7.1.2.7 and 7.1.2.8 are applicable.

7.1.3 According to ambient temperature

Only 7.1.3.2 is applicable.

7.1.4 According to number of operating cycles

Only 7.1.4.4 is applicable.

For switched lampholders intended to be used in refrigerators or food freezers, 7.1.4.2 applies if the switch is actuated by the door of the refrigerator or food freezer.

7.1.9 According to the glow wire temperature

Only 7.1.9.1 is applicable.

8 Marking and documentation

Not applicable; 13.3 of this standard applies.

16 Heating

16.1 General requirements

Switches in lampholders intended to be used in refrigerators or food freezers are tested at the rated operating temperatures.

20 Clearances, creepage distances, solid insulation and coatings of rigid printed board assemblies

20.2 Creepage distances

Material group IIIb is not useable.

For switched lampholders intended to be used in refrigerators or food freezers, Note 5 is applicable.

IECNORM.COM : Click to view the full PDF of IEC 60238:2016+AMD1:2017+AMD2:2020 CSV

Annex C (informative)

Guidance for special requirements in appliance standards – Household and similar electrical appliances

This standard is based on the requirements of the IEC 60598 series for luminaires. For application in other appliances (e.g. household appliances) the requirements of the relevant appliance standard should be observed.

C.1 List of relevant standards

The following list contains references to appliance standards in which experience has shown that lampholders covered by this standard may be built-in. This list shows a selection of the existing standards and does not lay claim to be exhaustive.

Publication	Title
IEC 60335-1	Household and similar electrical appliances – Safety – Part 1: General requirements
IEC 60335-2-6	Household and similar electrical appliances – Safety – Part 2-6: Particular requirements for stationary cooking ranges, hobs, ovens and similar appliances
IEC 60335-2-9	Household and similar electrical appliances – Safety – Part 2-9: Particular requirements for grills, toasters and similar portable cooking appliances
IEC 60335-2-11	Household and similar electrical appliances – Safety – Part 2-11: Particular requirements for tumble dryers
IEC 60335-2-24	Household and similar electrical appliances – Safety – Part 2-24: Particular requirements for refrigerating appliances, ice-cream appliances and ice-makers
IEC 60335-2-25	Household and similar electrical appliances – Safety – Part 2-25: Particular requirements for microwave ovens, including combination microwave ovens
IEC 60335-2-27	Household and similar electrical appliances – Safety – Part 2-27: Particular requirements for appliances for skin exposure to ultraviolet and infrared radiation
IEC 60335-2-31	Household and similar electrical appliances – Safety – Part 2-31: Particular requirements for range hoods and other cooking fume extractors
IEC 60335-2-36	Household and similar electrical appliances – Safety – Part 2-36: Particular requirements for commercial electric cooking ranges, ovens, hobs and hob elements
IEC 60335-2-42	Household and similar electrical appliances – Safety – Part 2-42: Particular requirements for commercial electric forced convection ovens, steam cookers and steam-convection ovens
IEC 60335-2-43	Household and similar electrical appliances – Safety – Part 2-43: Particular requirements for clothes dryers and towel rails
IEC 60335-2-49	Household and similar electrical appliances – Safety – Part 2-49: Particular requirements for commercial electric hot cupboards
IEC 60335-2-59	Household and similar electrical appliances – Safety – Part 2-59: Particular requirements for insect killers
IEC 60335-2-99	Household and similar electrical appliances – Safety – Part 2-99: Particular requirements for commercial electric hoods

C.2 Reference to special requirements

C.2.1 IEC 60335-1:2001

Clause 8 – Protection against access to live parts

Clause 11 – Heating

Table 3 – Maximum normal temperature rises

Clause 24 – Components

Subclauses 24.1, 24.1.3 and 24.1.6 apply.

Clause 29 – Clearances, creepage distances and solid insulation

Requirements regarding resistance to tracking are given in 29.2.

Requirements regarding thickness of solid insulation are given in 29.3.

Clause 30 – Resistance to heat and fire

Annex E (normative) – Needle-flame test

Annex H (normative) – Switches

Annex N (normative) – Proof tracking test

Annex O (informative) – Selection and sequence of the tests of Clause 30

C.2.2 IEC 60335-2-24:2002

Clause 7 – Marking and instructions

There is no special marking requirement for lampholders within Clause 7 of IEC 60335-2-24:2002. Nevertheless the following requirement is considered to be essential:

In case of lampholders intended for use in a refrigerated compartment of refrigerators and food freezers, the rated minimum temperature to which the lampholder can be subjected shall be marked on the lampholder (e.g. –30 °C).

Clause 8 – Protection against access to live parts

Clause 24 – Components

Particular requirements for switches in doors are given in 24.1.3.

Clause 29 – Clearances, creepage distances and solid insulation

Requirements regarding resistance to tracking are given in 29.2:

For lampholders intended for use in a refrigerated compartment of refrigerators and food freezers, the specimen shall withstand 50 drops without failure at a test voltage of PTI 250.

Annex D (informative)

Clauses containing new or more stringent requirements with respect to the previous edition

The schedule of clauses given in Annex D details the requirements of this Amendment 1 of IEC 60238:2016 which may require retesting to show compliance to this updated standard. Retesting may not be required in cases where examination of previous test results confirms conformity.

- a) Clause 18: Update on creepage distances and clearances for frequencies above 30 kHz and inclusion of U_{out} from controlgear.

IECNORM.COM : Click to view the full PDF of IEC 60238:2016+AMD1:2017+AMD2:2020 CSV

Bibliography

IEC 60061 (all parts), *Lamp caps and holders together with gauges for the control of interchangeability and safety*

IEC 60061-4, *Lamp caps and holders together with gauges for the control of interchangeability and safety – Part 4: Guidelines and general information*

IEC 60068-2-20, *Environmental testing – Part 2-20: Tests – Test T: Test methods for solderability and resistance to soldering heat of devices with leads*

IEC 60335-1:2001, *Household and similar electrical appliances – Safety – Part 1: General requirements*

IEC 60335-2-24:2002, *Household and similar electrical appliances – Safety – Part 2-24: Particular requirements for refrigerating appliances, ice-cream appliances and ice-makers*

IEC 60598 (all parts), *Luminaires*

IEC 60664-1, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60664-4:2005, *Insulation coordination for equipment within low-voltage systems – Part 4: Consideration of high-frequency voltage stress*

IEC 60695-2-10, *Fire hazard testing – Part 2-10: Glowing/hot-wire based test methods – Glow-wire apparatus and common test procedure*

IEC 61347-1:2015, *Lamp controlgear – Part 1: General and safety requirements*

IECNORM.COM : Click to view the full PDF of IEC 60238:2016+AMD1:2017+AMD2:2020 CSV

SOMMAIRE

AVANT-PROPOS	86
INTRODUCTION à l'Amendement 2	88
1 Domaine d'application	89
2 Références normatives	90
3 Termes et définitions	91
4 Exigences générales	96
5 Conditions générales des essais	97
6 Valeurs normalisées	98
7 Classification	99
8 Marquage	100
9 Dimensions	102
10 Protection contre les chocs électriques	105
11 Bornes	107
12 Dispositions en vue de la mise à la terre	111
13 Construction	113
14 Douilles à interrupteur	118
15 Résistance à l'humidité, résistance d'isolement et rigidité diélectrique	119
16 Résistance mécanique	121
17 Vis, parties transportant le courant et connexions	126
18 Lignes de fuite et distances dans l'air	128
19 Fonctionnement normal	132
20 Généralités sur la résistance à la chaleur	133
21 Résistance à la chaleur, au feu et aux courants de cheminement	135
22 Protection contre les contraintes résiduelles excessives (fissurations intercristallines) et contre la rouille	138
Annexe A (normative) Essai de fissuration intercristalline et de corrosion	159
Annexe B (informative) Lignes directrices pour le choix des exigences de l'IEC 61058- 1 applicables aux interrupteurs de douilles (voir 14.2)	161
Annexe C (informative) Lignes directrices relatives aux exigences spécifiques des normes d'appareillage – Appareils électrodomestiques et analogues	163
Annexe D (informative) Articles contenant des exigences nouvelles ou plus contraignantes par rapport à l'édition précédente	165
Bibliographie	166
Figure 1a – Filetage des raccords pour douilles de lampes: filetage métrique. Profil de base et profil d'exécution pour l'écrou et pour la vis	139
Figure 1b – Filetage des raccords pour douilles de lampes: filetage ISO au pas du gaz. Profil de base et profil d'exécution pour l'écrou et pour la vis	140
Figure 2a – Calibres pour filetage métrique pour raccords de douilles	141
Figure 2b – Calibres pour filetage ISO au pas du gaz pour raccords de douilles	142
Figure 3 – Calibre pour les trous de fixation des douilles à embase	143
Figure 4 – Appareil pour les essais de fonctionnement normal	144
Figure 5 – Culots d'essai pour l'essai de l'Article 18	145

Figure 6 – Appareil pour la résistance à la torsion	146
Figure 7 – Tambour tournant.....	147
Figure 8 – Appareil pour l'essai de choc.....	148
Figure 9 – Appareil pour la résistance à la compression	149
Figure 10 – Appareil pour l'essai à la bille.....	149
Figure 11 – Culot d'essai pour les essais de 15.4 et 20.3.....	150
Figure 12 – Appareil pour la résistance à la flexion	151
Figure 13 – Culot d'essai A et culot d'essai B pour les douilles E14 (2 de 2)	153
Figure 14 – Culot d'essai pour les douilles E27	154
Figure 15 – Culot d'essai pour les douilles E40.....	155
Figure 16 – Doigt d'épreuve normalisé (d'après l'IEC 60529)	156
Figure 17 – Clarification de quelques définitions	157
Figure 18 – Préparation des spécimens pour l'essai au brûleur-aiguille de 21.4	158
Tableau 1 – Epaisseur des chemises filetées et des contacts	103
Tableau 2 – Longueurs effectives minimales du filetage.....	104
Tableau 3 – Dimensions des entrées taraudées et des vis d'arrêt	105
Tableau 4 – Dimensions minimales des bornes à trous	109
Tableau 5 – Dimensions minimales des bornes à serrage	110
Tableau 6 – Valeurs de traction et de torsion	116
Tableau 7 – Couple d'insertion.....	117
Tableau 8 – Couples de dévissage minimal et maximal.....	118
Tableau 9 – Dimensions des culots d'essai.....	122
Tableau 10 – Hauteurs de chute	123
Tableau 11 – Valeurs de déformation maximales	125
Tableau 12 – Valeurs de torsion	126
Tableau 13a – Distances minimales pour les tensions sinusoïdales en courant alternatif jusqu'à 30 kHz – Catégorie de résistance aux chocs II	129
Tableau 13b – Distances minimales pour les tensions sinusoïdales en courant alternatif jusqu'à 30 kHz – Catégorie de résistance aux chocs III	130
Tableau 14 – Distances minimales pour les tensions d'impulsion d'amorçage ou les tensions de crête équivalentes U_p	131
Tableau 15 – Températures dans l'étuve	134
Tableau A.1 – Réglage du pH	159

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

DOUILLES À VIS EDISON POUR LAMPES

AVANT-PROPOS

- 1) La Commission Electrotechnique Internationale (IEC) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de l'IEC). L'IEC a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, l'IEC – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de l'IEC"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec l'IEC, participent également aux travaux. L'IEC collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de l'IEC concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de l'IEC intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de l'IEC se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de l'IEC. Tous les efforts raisonnables sont entrepris afin que l'IEC s'assure de l'exactitude du contenu technique de ses publications; l'IEC ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de l'IEC s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de l'IEC dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de l'IEC et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) L'IEC elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de l'IEC. L'IEC n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à l'IEC, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de l'IEC, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de l'IEC ou de toute autre Publication de l'IEC, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de l'IEC peuvent faire l'objet de droits de brevet. L'IEC ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets et de ne pas avoir signalé leur existence.

Cette version consolidée de la Norme IEC officielle et de ses amendements a été préparée pour la commodité de l'utilisateur.

L'IEC 60238 édition 9.2 contient la neuvième édition (2016-07) [documents 34B/1852/FDIS et 34B/1860/RVD], et son amendement 1 (2017-01) [documents 34B/1887/FDIS et 34B/1892/RVD] et son corrigendum (2018-01), et son amendement 2 (2020-01) [documents 34B/2029/CDV and 34B/2040A/RVC].

Cette version Finale ne montre pas les modifications apportées au contenu technique par les amendements 1 et 2. Une version Redline montrant toutes les modifications est disponible dans cette publication.

La Norme internationale IEC 60238 a été établie par le sous-comité 34B: Culots et douilles, du comité d'études 34 de l'IEC: Lampes et équipements associés.

Cette neuvième édition constitue une révision technique.

Cette édition inclut les modifications techniques majeures suivantes par rapport à l'édition précédente:

- a) Addition d'un essai de traction pour certaines douilles E5 et E10.
- b) Une Annexe D répertoriant les exigences/articles amendés nécessitant la réalisation de nouveaux essais sur les produits.

Cette publication a été rédigée selon les Directives ISO/IEC, Partie 2.

Dans cette norme, les caractères d'imprimerie suivants sont utilisés:

- *les déclarations de conformité: en italique.*

Le comité a décidé que le contenu de la publication de base et de ses amendements ne sera pas modifié avant la date de stabilité indiquée sur le site web de l'IEC sous "<http://webstore.iec.ch>" dans les données relatives à la publication recherchée. A cette date, la publication sera

- reconduite,
- supprimée,
- remplacée par une édition révisée, ou
- amendée.

INTRODUCTION à l'Amendement 2

Certaines modifications et corrections nécessaires pour l'IEC 60238 sont devenues évidentes au cours des travaux portant sur l'Édition consolidée 9.1 de l'IEC 60238.

Modification 1:

Les normes de sécurité des douilles de lampe réelles exigent un essai à la bille aligné sur l'IEC 60695-10-2 dans les sections "Résistance à la chaleur, au feu et au cheminement". Dans le cadre de cet essai, il existe une méthode alternative par mesure de profondeur d'empreinte décrite pour le calcul du diamètre d'empreinte.

Cette option alternative de calcul a été supprimée de la dernière édition de l'IEC 60695-10-2 datant de 2014 et au cours de sa réunion à Sydney en 2018, le SC 34B/GT1 a convenu également de supprimer cette méthode alternative de l'IEC 60238.

Modification 2:

Sur la base de l'IEC 60664-1:2007, 4.8.1.5, "Matériaux non sujets au cheminement":

"Pour le verre, les céramiques et d'autres matériaux isolants inorganiques qui ne sont pas sujets au cheminement, les lignes de fuite ne nécessitent pas d'être supérieures aux distances d'isolement associées dans le cadre de la coordination de l'isolement. Les dimensions du Tableau F.2 sont donc appropriées dans des conditions de champ hétérogène."

Ceci n'est pas complètement répercuté dans les normes du CE 34 telles que récemment révisées. Pour les applications avec TBT, il est primordial de déterminer si la ligne de fuite doit être de 0,6 mm ou si elle peut être de 0,2 mm, dans le cas d'une utilisation de matériau isolant inorganique.

Correction

Avec l'Amendement 1 à l'IEC 60238 Edition 9, un alinéa complet a été supprimé par accident. Ceci a été corrigé par la publication d'un corrigendum à l'Amendement 1, néanmoins, une correction éditoriale doit être apportée pour les références aux points qui doivent être modifiés en notes de bas de tableau "a" et "d", dans la mesure où le texte de référence a été inclus dans les Tableaux 13a et 13b.

DOUILLES À VIS EDISON POUR LAMPES

1 Domaine d'application

La présente Norme internationale s'applique aux douilles à vis Edison E14, E27 et E40 destinées uniquement au raccordement des lampes et des semi-luminaires¹ à l'alimentation.

Elle s'applique aussi aux douilles à interrupteur destinées exclusivement aux circuits de courant alternatif dont la tension de travail ne dépasse pas 250 V (valeur efficace).

La présente norme est également applicable aux douilles à vis Edison E5 destinées à être raccordées au réseau d'alimentation de lampes montées en série et dont la tension de travail ne dépasse pas 25 V, pour utilisation à l'intérieur, ainsi qu'aux douilles à vis Edison E10 destinées au raccordement au réseau d'alimentation de lampes montées en série et dont la tension de travail ne dépasse pas 60 V, pour utilisation à l'intérieur ou à l'extérieur. Elle s'applique également aux douilles E10 à incorporer, pour le raccordement de lampes individuelles à l'alimentation. Ces douilles ne sont pas destinées à la vente au détail.

Pour autant que la présente norme soit raisonnablement applicable, elle couvre également d'autres douilles que celles à vis Edison destinées au raccordement à l'alimentation de lampes branchées en série.

NOTE Ce type de douille est employé par exemple dans les guirlandes lumineuses pour arbres de Noël.

Pour autant que l'on puisse raisonnablement l'appliquer, cette norme couvre également les adaptateurs.

La présente norme couvre aussi les douilles totalement ou partiellement intégrées au luminaire ou prévues pour être montées dans les appareils. Elle ne couvre que les exigences relatives à la douille. Pour toutes les autres exigences telles que la protection contre les chocs électriques dans la zone des bornes ou du culot de la lampe, les exigences de la norme de l'appareil concerné sont respectées et les essais réalisés après incorporation dans l'appareil approprié, lorsque cet appareil est soumis aux essais selon sa propre norme. De telles douilles ainsi que les douilles pourvues d'un écran extérieur enclenchable, destinées aux fabricants de luminaires exclusivement, ne sont pas destinées à la vente au détail.

La présente norme s'applique aux douilles utilisées à l'intérieur ou à l'extérieur de bâtiments et destinées aux installations d'éclairage domestique ou industriel. Elle s'applique également aux douilles-bougies. Des constructions spéciales peuvent être exigées dans des endroits où règnent des conditions particulières, comme dans le cas de l'éclairage public, à bord des navires, dans les véhicules et dans les locaux à atmosphère dangereuse présentant, par exemple, des risques d'explosion.

La présente norme n'est pas applicable aux douilles E26d pour lampes à trois puissances.

La présente norme est fondée sur les données suivantes, relatives aux lampes pour éclairage général:

- les culots E14 sont utilisés pour des lampes absorbant un courant ne dépassant pas 2 A;
- les culots E27 sont utilisés pour des lampes absorbant un courant ne dépassant pas 4 A;
- les culots E40 sont utilisés pour des lampes absorbant un courant ne dépassant pas 16 A, ou 32 A si la tension nominale de l'alimentation ne dépasse pas 130 V (voir 5.5 et 6.3).

¹ Les exigences applicables aux douilles pour semi-luminaires sont à l'étude.

Quand les douilles sont utilisées dans des luminaires, leurs températures maximales de travail sont spécifiées dans l'IEC 60598.

2 Références normatives

Les documents suivants sont cités en référence de manière normative, en intégralité ou en partie, dans le présent document et sont indispensables pour son application. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

IEC 60061-1, *Culots de lampes et douilles ainsi que calibres pour le contrôle de l'interchangeabilité et de la sécurité – Partie 1: Culots de lampes*

IEC 60061-2, *Culots de lampes et douilles ainsi que calibres pour le contrôle de l'interchangeabilité et de la sécurité – Partie 2: Douilles*

IEC 60061-3, *Culots de lampes et douilles ainsi que calibres pour le contrôle de l'interchangeabilité et de la sécurité – Partie 3: Calibres*

IEC 60068-2-32:1975, *Essais fondamentaux climatiques et de robustesse mécanique – Partie 2-32: Essais – Essai Ed: Chute libre*

IEC 60068-2-75:2014, *Essais d'environnement – Partie 2-75: Essais – Essai Eh: Essais aux marteaux*

IEC 60112:2003, *Méthode de détermination des indices de résistance et de tenue au cheminement des matériaux isolants solides*
Amendement 1:2009

IEC 60227 (toutes les parties), *Conducteurs et câbles isolés au polychlorure de vinyle, de tension nominale au plus égale à 450/750 V*

IEC 60245 (toutes les parties), *Conducteurs et câbles isolés au caoutchouc – Tension assignée au plus égale à 450/750 V*

IEC 60352-1:1997, *Connexions sans soudure – Partie 1: Connexions enroulées – Règles générales, méthodes d'essai et guide pratique*

IEC 60399, *Filetage à filets ronds pour douilles avec bague support d'abat-jour*

IEC 60417, *Symboles graphiques utilisables sur le matériel* (disponible sous: <http://www.graphical-symbols.info/equipment>)

IEC 60529:1989, *Degrés de protection procurés par les enveloppes (Code IP)*
Amendement 1:1999
Amendement 2:2013²

IEC 60598-1, *Luminaires – Partie 1: Exigences générales et essais*

IEC 60630, *Encombrement maximal des lampes à incandescence*

² Il existe une édition consolidée 2.2 (2013) comprenant l'édition 2.0 (1989) et ses Amendement 1 (1999) et Amendement 2 (2013).

IEC 60695-2-11:2014, *Essais relatifs aux risques du feu – Partie 2-11: Essais au fil incandescent/chauffant – Méthode d'essai d'inflammabilité pour produits finis*

IEC 60695-11-5, *Essais relatifs aux risques du feu – Partie 11-5: Flammes d'essai – Méthode d'essai au brûleur-aiguille – Appareillage, dispositif d'essai de vérification et lignes directrices*

IEC 61058-1:2000, *Interrupteurs pour appareils – Partie 1: Règles générales*

ISO 4046-4:2002, *Papier, carton, pâtes et termes connexes – Vocabulaire – Partie 4: Catégories et produits transformés de papier et de carton*

3 Termes et définitions

Pour les besoins du présent document, les termes et définitions suivants s'appliquent.

3.1

douille à serre-fil

douille pourvue d'un dispositif retenant un câble souple par lequel elle peut être suspendue

3.2

douille à entrée taraudée

douille pourvue d'une pièce taraudée au point d'entrée des câbles d'alimentation, permettant à la douille d'être montée sur un support fileté

Note 1 à l'article: La douille à entrée taraudée était précédemment nommée "douille à raccord"

3.3

douille à embase

douille conçue pour permettre le montage au moyen d'une embase associée ou incorporée, directement sur une surface d'appui ou une boîte appropriée

3.4

douille à incorporer

douille conçue pour être incorporée dans un luminaire, dans une enveloppe supplémentaire ou dans un dispositif analogue

3.4.1

douille non protégée

douille à incorporer, conçue de manière que des moyens additionnels, par exemple une enveloppe, soient indispensables pour satisfaire aux exigences de la présente norme concernant la protection contre les chocs électriques

3.4.2

douille protégée

douille à incorporer, conçue de manière qu'elle satisfasse par elle-même aux exigences de la présente norme concernant la protection contre les chocs électriques et, le cas échéant, la classification IP

3.5

douille indépendante

douille conçue de manière qu'elle puisse être installée séparément d'un luminaire tout en assurant toute la protection nécessaire conformément à sa classification et à son marquage

3.6

ensemble borne/contact

pièce ou ensemble de pièces assurant la connexion entre l'extrémité d'un conducteur d'alimentation et les faces de contact du culot de lampe correspondant

Note 1 à l'article: Pour plus de précisions sur certaines définitions, voir également la Figure 17.

3.7

chemise extérieure

pièce cylindrique protégeant l'utilisateur contre le contact avec le culot de la lampe

Note 1 à l'article: Elle peut être munie ou non d'un filetage extérieur pour fixation d'une bague d'abat-jour.

Note 2 à l'article: Pour plus de précisions sur certaines définitions, voir également la Figure 17.

3.7.1

écran extérieur enclenchable

écran extérieur pour un assemblage sans vis qui ne contient pas d'écran vissable

Note 1 à l'article: Il convient que la douille ne soit pas utilisée quand l'écran extérieur enclenchable est enlevé. Il est par conséquent recommandé de positionner la marque d'approbation, lorsqu'il y en a une, de telle façon qu'elle ne soit plus visible lorsque ce type d'écran extérieur est enlevé.

3.8

chemise filetée

pièce cylindrique munie d'un filetage intérieur Edison pour retenir la lampe (le culot) insérée

Note 1 à l'article: Dans quelques constructions, la chemise filetée est fixée de façon permanente ou intégrée dans la chemise extérieure.

Note 2 à l'article: Pour plus de précisions sur certaines définitions, voir également la Figure 17.

3.9

bague d'isolement

pièce intermédiaire cylindrique en matière isolante séparant la chemise filetée métallique et la chemise extérieure métallique

Note 1 à l'article: Pour plus de précisions sur certaines définitions, voir également la Figure 17.

3.10

bague d'abat-jour

pièce cylindrique ayant un filetage interne ou d'autres moyens pour se fixer sur la pièce correspondante du corps de la douille et destinée à monter un abat-jour

Note 1 à l'article: Pour plus de précisions sur certaines définitions, voir également la Figure 17.

3.11

fond

partie d'une douille à serre-fil ou d'une douille à entrée taraudée qui protège les bornes de raccordement

Note 1 à l'article: Pour plus de précisions sur certaines définitions, voir également la Figure 17.

3.12

isolation principale

isolation des parties actives destinée à assurer la protection principale contre les chocs électriques

Note 1 à l'article: L'isolation principale ne comprend pas nécessairement l'isolation exclusivement utilisée à des fins fonctionnelles.

3.13

isolation supplémentaire

isolation indépendante prévue en plus de l'isolation principale en vue d'assurer la protection contre les chocs électriques en cas de défaut de l'isolation principale

3.14

double isolation

isolation comprenant à la fois l'isolation principale et l'isolation supplémentaire

3.15

isolation renforcée

système d'isolation unique des parties sous tension assurant un degré de protection contre les chocs électriques équivalent à une double isolation dans les conditions spécifiées

Note 1 à l'article: L'expression «système d'isolation» ne sous-entend pas que l'isolation se compose d'une pièce homogène. Le système peut comporter plusieurs couches qui ne peuvent pas être soumises aux essais séparément comme isolation principale ou supplémentaire.

3.16

partie active

partie conductrice susceptible de produire un choc électrique

3.17

essai de type

essai ou série d'essais effectués sur un échantillon d'essai de type afin de vérifier la conformité de la conception d'un produit donné aux exigences de la norme concernée

3.18

échantillon d'essai de type

échantillon composé d'un ou de plusieurs spécimens semblables, présenté(s) par le fabricant ou par le vendeur responsable afin de le soumettre aux essais de type

3.19

semi-luminaire

ensemble similaire à une lampe autoballastée mais dans lequel le remplacement de la lampe et/ou de l'amorceur est prévu

3.20

température assignée de fonctionnement

température maximale prévue pour la douille

3.21

température minimale assignée

température la plus basse pour laquelle la douille est conçue (applicable uniquement aux douilles de lampes destinées à être utilisées dans des réfrigérateurs ou congélateurs)

3.22

douille à angle

douille dont la partie arrière (entrée filetée et/ou fond) fait un angle avec l'axe de la chemise filetée

3.23

douille avec dispositif de frein

douille avec un dispositif destiné à prévenir tout dévissage de la lampe dans la douille

Note 1 à l'article: Les lampes sont susceptibles, par exemple, de se dévisser sous l'effet des variations de température ou des vibrations.

3.24

catégorie de tenue aux chocs

chiffre définissant une condition de surtension transitoire

Note 1 à l'article: Les catégories de tenue aux chocs I, II, III et IV sont utilisées.

a) But de la classification des catégories de tenue aux chocs

Les catégories de tenue aux chocs servent à différencier les différents degrés de disponibilité des équipements en ce qui concerne les attentes exigées en matière de continuité de service et de tolérance des risques de défauts.

En sélectionnant les niveaux de tenue aux chocs des équipements, il est possible de réaliser la coordination de l'isolement pour l'installation complète en réduisant le risque de défaut à un niveau acceptable qui servira de base dans la maîtrise de la surtension.

Un chiffre plus élevé désignant la catégorie de tenue aux chocs indique une tenue aux chocs de l'équipement plus élevée, et permet un plus grand choix de méthodes pour la maîtrise de la surtension.

Le concept de catégorie de tenue aux chocs est utilisé pour les équipements directement alimentés par le réseau.

b) Description des catégories de tenue aux chocs

Un équipement de catégorie de tenue aux chocs I est un équipement destiné à être connecté aux installations électriques fixes des bâtiments. Des moyens de protection sont pris à l'extérieur de l'équipement – soit dans l'installation fixe soit entre l'installation fixe et l'équipement – pour limiter les surtensions transitoires à un niveau donné.

Un équipement de catégorie de tenue aux chocs II est un équipement destiné à être connecté aux installations électriques fixes des bâtiments.

Un équipement de catégorie de tenue aux chocs III est un équipement qui constitue une partie des installations électriques fixes et des autres équipements dont le degré de disponibilité attendu est plus élevé.

Un équipement de catégorie de tenue aux chocs IV est destiné à être utilisé à proximité ou dans les installations électriques des bâtiments en amont du tableau de distribution.

3.25

circuit primaire

circuit directement connecté au réseau alternatif

Note 1 à l'article: Il comporte, par exemple, les moyens de connexion au réseau alternatif, les enroulements primaires des transformateurs, moteurs et autres dispositifs en charge.

3.26

circuit secondaire

circuit qui n'a pas de connexion directe avec le circuit primaire en tirant sa puissance d'un transformateur, convertisseur ou système d'isolation équivalent, ou d'un accumulateur

Note 1 à l'article: Exception: les autotransformateurs. Bien qu'ayant une connexion directe avec le circuit primaire, leur partie connectée est également considérée comme un circuit secondaire au sens de la présente définition.

Note 2 à l'article: Les régimes transitoires dans de tels circuits sont amortis par l'enroulement primaire correspondant. Les ballasts inductifs réduisent également la valeur de la tension des régimes transitoires. En conséquence, les composants situés après un circuit primaire ou après un ballast inductif peuvent être adaptés à une catégorie de tenue aux chocs un niveau plus bas, c'est-à-dire une catégorie de tenue aux chocs II.

3.27

adaptateur

composant utilisé pour la connexion électrique et mécanique d'une lampe à une douille

Note 1 à l'article: Cette définition est spécifique à la présente norme. La définition d'un adaptateur est susceptible de varier grandement selon son utilisation. Dans la plupart des cas, un tel composant est utilisé pour adapter les différences de diamètre de filetage entre la douille et la lampe.

3.28

douille protégée à isolation renforcée

douille à incorporer conçue de façon qu'elle satisfasse par elle-même aux exigences des parties à isolation double ou renforcée dans les applications de classe II

3.29

douille à isolation partiellement renforcée

douille à incorporer conçue de façon que certaines parties de la douille nécessitent des dispositions supplémentaires pour satisfaire aux exigences concernant l'isolation double ou renforcée

Note 1 à l'article: Dans certains cas, les dimensions sont susceptibles d'être satisfaites uniquement après montage dans le luminaire.

3.30

tension assignée

valeur déclarée par le fabricant comme étant la tension de service la plus élevée pour laquelle la douille a été prévue

[SOURCE: IEC 60838-1:2016, 3.1, modifié – "travail" a été remplacé par "service"]

3.31

tension de service

tension efficace la plus élevée pouvant être mesurée aux extrémités de tout isolant (les transitoires étant négligées) lorsque la lampe fonctionne dans les conditions normales ou lorsqu'elle est retirée

[SOURCE: IEC 60838-1:2016, 3.2, modifié – "travail" a été remplacé par "service"]

3.32

courant assigné

courant déclaré par le fabricant comme étant le courant le plus élevé pour lequel la douille a été prévue

[SOURCE: IEC 60838-1:2016, 3.3]

3.33

fréquence critique

f_{crit}

fréquence à laquelle la réduction de la tension de claquage d'une distance d'isolement apparaît

Note 1 à l'article: $f_{crit} \approx 0,2/d$ [MHZ] où d (en mm) est la distance d'isolement selon le Tableau 3 (respectivement isolation de base ou supplémentaire et isolation renforcée) sans tenir compte de la fréquence.

[SOURCE: IEC 61347-1:2015, 3.40, modifié – la note a été ajoutée]

3.34

tension d'amorçage

tension de crête appliquée pour amorcer une lampe à décharge

[SOURCE: IEC 61347-1:2015, 3.46]

3.34.1

tension d'impulsion d'amorçage

tension d'amorçage de crête d'une durée totale $\leq 750 \mu s$ (somme de toutes les durées d'impulsion) en moins de 10 ms avec la durée (largeur) de chaque impulsion étant mesurée au niveau de 50 % de la valeur de crête absolue maximale

Note 1 à l'article: Il convient que les formes d'onde d'impulsion d'amorçage, considérées comme une tension d'impulsion d'amorçage, ne contiennent pas de fréquence fondamentale supérieure à 30 kHz ou qu'elles soient généralement fortement amorties (après 20 μs , il convient que le niveau de tension de crête soit inférieur à la moitié de la tension de crête maximale). Pour l'évaluation de la fréquence fondamentale, il convient de consulter l'Annexe E de l'IEC 60664-4:2005.

[SOURCE: IEC 61347-1:2015, 3.46.1]

3.35

tension d'amorçage assignée

valeur crête la plus élevée d'une tension d'impulsion d'amorçage pouvant être supportée par la douille

3.36

tension de service maximale

U_{out}

tension (efficace) de service maximale apparaissant entre les bornes de sortie d'un appareillage ou entre les bornes de sortie et la terre, dans des conditions de fonctionnement normales ou anormales

Note 1 à l'article: Les transitoires et les tensions d'allumage doivent être négligés.

[SOURCE: IEC 61347-1:2015, 3.33, modifié – "d'un appareillage" a été ajouté]

3.37

tension de sortie de crête maximale de service

$\hat{U}_{out}$

tension de service de crête répétitive maximale entre les bornes de sortie d'un appareillage ou entre les bornes de sortie et la terre, lors de conditions de fonctionnement normales ou anormales et avec les surtensions transitoires négligées

[SOURCE: IEC 61347-1:2015, 3.45 modifié – "d'un appareillage " a été ajouté]

3.38

tension de crête équivalente transformée

U_p

tension de crête de sortie transformée, qui est convertie pour la tension de crête la plus défavorable avec sa fréquence associée en une tension d'impulsion d'amorçage

Note 1 à l'article: La valeur de la tension de crête de sortie transformée équivalente déclarée est un paramètre essentiel pour la sélection des composants associés.

Note 2 à l'article: Voir 3.34.1.

Note 3 à l'article: Pour déterminer la tension de crête de sortie transformée équivalente déclarée pour l'isolation principale U_p [principale], la combinaison la plus défavorable de la tension de crête maximale et de la fréquence est à prendre en compte, ce qui signifie la distance dans l'air maximale conformément à l'IEC 61347-1:2015, Tableau 10, pour l'isolation principale.

Note 4 à l'article: Pour déterminer la tension de crête de sortie transformée équivalente déclarée pour l'isolation renforcée U_p [renforcée], la combinaison la plus défavorable de la tension de crête maximale et de la fréquence est à prendre en compte, ce qui signifie la distance dans l'air maximale conformément à l'IEC 61347-1:2015, Tableau 11, pour l'isolation renforcée.

[SOURCE: IEC 61347-1:2015, 3.47]

4 Exigences générales

Les douilles de lampes doivent être conçues et construites de façon qu'en usage normal leur fonctionnement soit sûr et que l'utilisateur ou l'entourage ne puisse pas être mis en danger.

En général, la conformité est vérifiée en exécutant la totalité des essais spécifiés.

De plus, l'enceinte des douilles indépendantes doit satisfaire aux exigences de l'IEC 60598-1, y compris celles relatives à la classification et au marquage.

5 Conditions générales des essais

5.1 Les essais mentionnés dans la présente norme sont des essais de type.

NOTE Les exigences et tolérances autorisées par cette norme se rapportent à l'essai d'un échantillon d'essai de type soumis à cette fin.

La conformité de l'échantillon d'essai de type n'implique pas la conformité de la totalité de la production du fabricant à cette norme de sécurité.

En plus de l'essai de type, la conformité de production est sous la responsabilité du fabricant et peut comprendre des essais individuels (de série) et d'assurance de la qualité.

Pour de plus amples informations sur les essais de conformité en cours de fabrication, voir l'IEC 60061-4.

5.2 Sauf spécification contraire, les essais sont effectués à une température ambiante de $20\text{ °C} \pm 5\text{ °C}$, la douille étant soumise aux essais en état de livraison et installée comme en usage normal.

5.3 L'ensemble des essais et des vérifications est effectué sur un total de

- neuf spécimens pour les douilles sans interrupteur, ou
- 12 spécimens pour les douilles à interrupteur

dans l'ordre des articles ci-après:

- trois spécimens: Articles 2 à 13 (à l'exception des paragraphes 10.1 et 11.2) et Articles 15 à 18;
- trois spécimens: Article 14 (essais des douilles à interrupteur seulement);
- trois spécimens: 10.1, Articles 19 et 20;
- deux spécimens: Article 21 (dont l'un pour l'essai de 21.1 et l'autre pour les essais de 21.3 ou 21.4);
- un spécimen: 21.5 et Article 22.

Pour les essais de douilles avec dispositif de frein, le dispositif de frein doit être enlevé.

Pour les essais des douilles avec dispositif de frein, effectués en conformité avec 13.14, trois spécimens supplémentaires sont exigés avec le dispositif de frein en place.

Pour les essais des bornes sans vis, conformément à 11.2, des spécimens séparés sont en outre nécessaires.

5.4 *En cas de doute, les calibres, les culots d'essai et les mandrins sont vissés dans les spécimens, sauf spécification contraire, en appliquant un des couples de torsion suivants:*

- 0,2 Nm pour les douilles E5;
- 0,2 Nm pour les douilles E10;
- 0,2 Nm pour les douilles E14;
- 0,4 Nm pour les douilles E27;
- 0,8 Nm pour les douilles E40.

5.5 *Pour les douilles E40 dont le courant assigné est de 32 A, les essais doivent être effectués sur la base de ce courant assigné.*

5.6 *Les douilles sont considérées comme répondant à la présente norme si aucun des spécimens soumis à la série complète des essais spécifiés en 5.3 ne présente de défaillance.*

Si un spécimen est refusé à un essai, cet essai et ceux qui l'ont précédé, qui peuvent influencer le résultat de cet essai, sont répétés sur un autre lot de spécimens en nombre égal à celui exigé par 5.3, et qui tous doivent alors satisfaire aux essais répétés et aux suivants. Les douilles sont considérées comme ne répondant pas à la présente norme s'il se produit plus d'une défaillance.

6 Valeurs normalisées

6.1 Les tensions assignées normalisées sont 250 V et 500 V.

Pour les douilles E14 et les douilles E27 à interrupteur, la seule tension assignée admissible est 250 V.

Pour les douilles E5 et E10 destinées au raccordement à l'alimentation de lampes connectées en série, la tension assignée ne doit pas dépasser 25 V pour les douilles E5 et 60 V pour les douilles E10.

NOTE 1 Ces valeurs se réfèrent à la tension entre parties de polarité différente.

Pour les douilles E10 destinées au raccordement de lampes individuelles à l'alimentation, seule la tension assignée de 250 V est admise.

NOTE 2 Ces douilles sont également utilisées pour des cas spéciaux tels que les lampes connectées en série où, en raison du faible nombre de lampes, la tension de 60 V par douille est dépassée.

Hormis l'exception indiquée pour les douilles E5 et E10, la tension assignée ne doit pas être inférieure à 250 V. En outre, une tension assignée de 125 V est admise pour les douilles E40.

La conformité est vérifiée par examen du marquage.

6.2 Les valeurs normalisées du courant assigné sont

- 0,2 A pour les douilles E5;
- 0,5 A pour les douilles E10;
- 2 A pour les douilles E14;
- 2 A pour les douilles E27 à interrupteur;
- 4 A pour les autres douilles E27;
- 16 A pour les douilles E40.

Le courant assigné ne doit pas être inférieur à la valeur normalisée.

La conformité est vérifiée par examen du marquage.

6.3 Les douilles E40 à utiliser dans des installations à 125 V peuvent être prévues, en outre, pour un courant assigné de 32 A.

NOTE Cette valeur nominale assignée couvre toutes les tensions jusqu'à 130 V inclus.

La conformité est vérifiée par examen du marquage.

6.4 La température assignée de fonctionnement des douilles prévues pour fonctionner dans des conditions de températures élevées (douilles à marquage T) ne doit pas être inférieure à 140 °C pour les douilles E14, 170 °C pour les douilles E27 et 230 °C pour les douilles E40.

La conformité est vérifiée par examen du marquage.

NOTE Les températures assignées de fonctionnement des douilles à vis Edison sans marquage T sont indiquées dans l'IEC 60598-1, Tableau 12.1. Elles sont

- 135 °C pour les douilles E14;
- 165 °C pour les douilles E27;
- 225 °C pour les douilles E40.

7 Classification

Les douilles sont classées selon 7.1 à 7.6.

7.1 D'après la matière des parties extérieures:

- douilles en matière isolante;
- douilles métalliques.

NOTE Les douilles qui ont des parties extérieures partiellement en métal et les douilles qui comportent des parties extérieures en matière isolante ayant une surface extérieure conductrice, par exemple une chemise extérieure métallisée, sont considérées comme des douilles métalliques (voir 13.3). Cela ne s'applique pas aux entrées taraudées et aux parties extérieures comme une bague d'abat-jour métallique montée à l'extérieur de la douille en matière isolante, qui ne peuvent pas devenir actives même dans le cas d'un défaut d'isolation. Les douilles métalliques à revêtement isolant sont considérées comme des douilles métalliques (voir 10.5).

Pour contrôler si une surface est conductrice ou non, deux lames métalliques d'une largeur de 1,5 mm, d'une longueur de 25 mm et d'un écartement de 2 mm sont appliquées sur cette surface (à revêtement de peinture d'argent conductrice, par exemple). La résistance d'isolement entre les deux lames est alors mesurée conformément à 15.4. La surface est considérée comme étant conductrice si cette résistance est inférieure à 5 MΩ.

7.2 D'après le degré de protection contre la pénétration d'eau:

- douilles ordinaires;
- douilles protégées contre le ruissellement d'eau vertical.

7.3 D'après le dispositif de fixation:

- douilles à entrée taraudée;
- douilles à serre-fil;
- douilles à embase;
- autres douilles.

NOTE D'autres exemples de douilles sont les douilles munies d'un dispositif de suspension mécanique, par exemple un crochet.

7.4 D'après le type:

- douilles à interrupteur, munies d'un interrupteur intégré pour commander la mise sous tension de la lampe;
- douilles sans interrupteur.

7.5 D'après la protection contre les chocs électriques:

- douilles non protégées;
- douilles protégées;
- douilles indépendantes;
- douilles à isolation partiellement renforcée;
- douilles protégées à isolation renforcée.