

NFPA 121

Standard on Fire Protection for Self-Propelled and Mobile Surface Mining Equipment

2001 Edition



NFPA, 1 Batterymarch Park, PO Box 9101, Quincy, MA 02269-9101
An International Codes and Standards Organization

NFPA License Agreement

This document is copyrighted by the National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, MA 02269-9101 USA.
All rights reserved.

NFPA grants you a license as follows: The right to download an electronic file of this NFPA document for temporary storage on one computer for purposes of viewing and/or printing one copy of the NFPA document for individual use. Neither the electronic file nor the hard copy print may be reproduced in any way. In addition, the electronic file may not be distributed elsewhere over computer networks or otherwise. The hard copy print may only be used personally or distributed to other employees for their internal use within your organization.

IMPORTANT NOTICE ABOUT THIS DOCUMENT

NFPA codes, standards, recommended practices, and guides, of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in its codes and standards.

The NFPA disclaims liability for any personal injury, property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on this document. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making this document available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of this document. Nor does the NFPA list, certify, test or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

See inside back cover for additional important notices and information.

NOTICES

All questions or other communications relating to this document and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA documents during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

Users of this document should be aware that this document may be amended from time to time through the issuance of Tentative Interim Amendments, and that an official NFPA document at any point in time consists of the current edition of the document together with any Tentative Interim Amendments then in effect. In order to determine whether this document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments, consult appropriate NFPA publications such as the *National Fire Codes*® Subscription Service, visit the NFPA website at www.nfpa.org, or contact the NFPA at the address listed above.

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

The NFPA does not take any position with respect to the validity of any patent rights asserted in connection with any items which are mentioned in or are the subject of this document, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on this document. Users of this document are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Users of this document should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of this document, intend to urge action that is not in compliance with applicable laws, and this document may not be construed as doing so.

Licensing Policy

This document is copyrighted by the National Fire Protection Association (NFPA). By making this document available for use and adoption by public authorities and others, the NFPA does not waive any rights in copyright to this document.

1. Adoption by Reference—Public authorities and others are urged to reference this document in laws, ordinances, regulations, administrative orders, or similar instruments. Any deletions, additions, and changes desired by the adopting authority must be noted separately. Those using this method are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. The term "adoption by reference" means the citing of title and publishing information only.

2. Adoption by Transcription—**A.** Public authorities with lawmaking or rule-making powers only, upon written notice to the NFPA (Attention: Secretary, Standards Council), will be granted a royalty-free license to print and republish this document in whole or in part, with changes and additions, if any, noted separately, in laws, ordinances, regulations, administrative orders, or similar instruments having the force of law, provided that: (1) due notice of NFPA's copyright is contained in each law and in each copy thereof; and (2) that such printing and republication is limited to numbers sufficient to satisfy the jurisdiction's lawmaking or rule-making process. **B.** Once this NFPA Code or Standard has been adopted into law, all printings of this document by public authorities with lawmaking or rule-making powers or any other persons desiring to reproduce this document or its contents as adopted by the jurisdiction in whole or in part, in any form, upon written request to NFPA (Attention: Secretary, Standards Council), will be granted a nonexclusive license to print, republish, and vend this document in whole or in part, with changes and additions, if any, noted separately, provided that due notice of NFPA's copyright is contained in each copy. Such license shall be granted only upon agreement to pay NFPA a royalty. This royalty is required to provide funds for the research and development necessary to continue the work of NFPA and its volunteers in continually updating and revising NFPA standards. Under certain circumstances, public authorities with lawmaking or rule-making powers may apply for and may receive a special royalty where the public interest will be served thereby.

3. Scope of License Grant—The terms and conditions set forth above do not extend to the index of this document.

(For further explanation, see the Policy Concerning the Adoption, Printing, and Publication of NFPA Documents, which is available upon request from the NFPA.)

Copyright © 2001 NFPA, All Rights Reserved

NFPA 121

Standard on

Fire Protection for Self-Propelled and Mobile Surface Mining Equipment

2001 Edition

This edition of NFPA 121, *Standard on Fire Protection for Self-Propelled and Mobile Surface Mining Equipment*, was prepared by the Technical Committee on Mining Facilities and acted on by the National Fire Protection Association, Inc., at its November Meeting held November 12–15, 2000, in Orlando, FL. It was issued by the Standards Council on January 13, 2001, with an effective date of February 9, 2001, and supersedes all previous editions.

This edition of NFPA 121 was approved as an American National Standard on February 9, 2001.

Origin and Development of NFPA 121

The Mining Facilities Committee was formed in 1977 to fulfill the need for consensus fire safety for mining. The task of developing the draft of this standard was assigned to the Subcommittee on Surface Mining. It was submitted to the Technical Committee on Mining Facilities for release to the Association and was issued in 1981 as a first edition. The next edition followed in 1986 and included a title change to verify that it includes self-propelled mining equipment. In addition it added a provision for a hazard analysis on each piece of mining equipment. The 1990 edition introduced a variety of minor changes, including the replacement of the term *hazard analysis* with *fire risk assessment* throughout the document. The 1996 edition of the standard was a reconfirmed version of the 1990 edition with editorial corrections and changes to conform to the NFPA *Manual of Style*.

The 2001 edition of the standard clarifies that fire alarm systems must meet the requirements of NFPA 72, *National Fire Alarm Code*®. The definitions also have been updated to conform to the NFPA Glossary of Terms.

Technical Committee on Mining Facilities

Larry J. Moore, *Chair*
FM Global, CO [I]

William R. Bragg, Levitt Safety (Eastern) Ltd, Canada [M]
Rep. Fire Equipment Mfrs. Inst. of Canada
Dennis Duane Brohmer, Ansul Inc./Tyco Int'l, WI [M]
Byron G. Brumbaugh, ASARCO Inc., UT [U]
Matthew J. Bujewski, Marsh USA, Inc., MO [I]
Michael C. Diliberto, Diliberto & Assoc., Inc., CO [SE]
Richard A. Dressler, Bucyrus-Erie Co., WI [M]
Tim Gierer, Alltype Fire Protection Co., MO [IM]
Rep. Nat'l Assn. of Fire Equipment Distributors Inc.
Howard R. Healey, Marsh USA Inc., IL [I]
Will B. Jamison, Consulting Engr, PA [SE]

Thomas Kaylor, Chubb Group of Insurance Cos., KY [I]
Vincent A. Lupo, DBA: Firemaster (Master Protection Corp.), CO [IM]
James W. McCollum, Caterpillar Inc., IL [M]
Donald G. McConnell, Cyprus Amax Coal Co., IL [U]
Barry A. Stewart, Science Applications Int'l Corp. (SAIC), NV [SE]
Bruce Watzman, Nat'l Mining Assn., DC [U]
Robert A. Wessel, Gypsum Assn., DC [M]

Alternates

J. J. Kenny, Marsh USA, Inc., Canada [I]
(Alt. to M. J. Bujewski)

David A. Pelton, Ansul Inc./Tyco Int'l, IL [M]
(Alt. to D. D. Brohmer)

Richard P. Bielen, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on safeguarding life and property against fire, explosion, and related hazards associated with underground and surface coal and metal and nonmetal mining facilities and equipment.

Contents

Chapter 1 Introduction	121- 4	Chapter 3 Referenced Publications	121- 7
1.1 Scope	121- 4	Appendix A Explanatory Material	121- 7
1.2 Purpose	121- 4	Appendix B Fire Risk Assessment	121- 8
1.3 Definitions	121- 4	Appendix C Suggested References	121-11
Chapter 2 Fire Protection	121- 5	Appendix D Referenced Publications	121-12
2.1 Fire Protection.....	121- 5	Index	121-13
2.2 Fire Risk Assessment	121- 5		
2.3 Risk Reduction.....	121- 5		
2.4 Fire Detection and Suppression Equipment.....	121- 6		

NFPA 121

Standard on

Fire Protection for Self-Propelled
and Mobile Surface Mining Equipment

2001 Edition

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Appendix A.

Changes other than editorial are indicated by a vertical rule in the margin of the pages on which they appear. These lines are included as an aid to the user in identifying changes from the previous edition.

A reference in parentheses () following a section or paragraph indicates material that has been extracted from another NFPA document. The complete title and edition of the document the material is extracted from is found in Chapter 3. Editorial changes to extracted material consist of revising references to an appropriate division in this document or the inclusion of the document number with the division number when the reference is to the original document. Requests for interpretations or revisions of extracted text shall be sent to the appropriate technical committee.

Information on referenced publications can be found in Chapter 3 and Appendix D.

Chapter 1 Introduction

1.1* Scope. This standard covers minimum requirements for safeguarding life and property against fire and related hazards associated with self-propelled and mobile surface mining equipment.

1.2 Purpose. This standard is for the use of those charged with mine fire prevention and protection and with the responsibility for purchasing, designing, installing, testing, inspecting, approving, listing, operating, or maintaining both mine fire protection equipment and self-propelled and mobile surface mining equipment.

1.2.1 At times it will be necessary for those charged with purchasing, testing, approving, and maintaining fire protection equipment for self-propelled and surface mining equipment to consult an experienced fire protection specialist.

1.2.2 Because of the uniqueness of surface mining, provisions in this standard can differ from commonly accepted fire protection standards and guides for other types of occupancies.

1.2.3 Nothing in this standard is intended to prevent the use of systems, methods, or devices of equivalent or superior quality, strength, fire resistance, effectiveness, durability, and safety over those prescribed by this standard, providing technical documentation is submitted to the authority having jurisdiction to demonstrate equivalency and the system, method, or device is approved for the intended purpose.

1.2.4 The provisions of this standard are considered necessary to provide a reasonable degree of protection from the hazards addressed in this standard. They reflect situations and the state of the art at the time the standard was issued.

Unless otherwise noted, the provisions of this standard shall not apply to facilities, equipment, structures, or installations that existed or were approved for construction or installation prior to the effective date of the standard. Where noted, the provisions of this standard shall be retroactive.

In those cases where the authority having jurisdiction determines that the existing situation involves a distinct hazard, the authority having jurisdiction shall be permitted to apply retroactively any portions of this standard that he or she deems appropriate.

1.3 Definitions. The definitions used in this standard are in accordance with general mining industry usage or dictionary definitions.

1.3.1* Approved. Acceptable to the authority having jurisdiction.

1.3.2* Authority Having Jurisdiction. The organization, office, or individual responsible for approving equipment, materials, an installation, or a procedure.

1.3.3 Combustible. Capable of undergoing combustion.

1.3.4 Combustion. A chemical process of oxidation that occurs at a rate fast enough to produce heat and usually light in the form of either a glow or flame.

1.3.5 Emergency Egress. An egress from a compartment or work station in emergencies when the normal egress is unusable.

1.3.6 Equipment Operator. The authorized person who starts, controls, or stops mining equipment.

1.3.7 Fire Risk Assessment. The evaluation of the relative danger of the start and spread of fire; the generation of smoke, gases, or toxic fumes; and the possibility of explosion or other occurrence endangering the lives and safety of personnel or causing significant damage to property.

1.3.8 Fixed Suppression System. A total flooding or local application system that consists of a fixed supply of extinguishing agent permanently connected to fixed piping with fixed nozzles that are arranged to discharge an extinguishing agent into an enclosure (total flooding) or directly onto a fire (local application), or a combination of both.

1.3.9 Flash Point. The minimum temperature of a liquid at which sufficient vapor is given off to form an ignitable mixture with the air, near the surface of the liquid or within the vessel used, as determined by the appropriate test procedure and apparatus specified in NFPA 30, *Flammable and Combustible Liquids Code*, 1.7.4. (30:1.7.2.2)

1.3.10 Labeled. Equipment or materials to which has been attached a label, symbol, or other identifying mark of an organization that is acceptable to the authority having jurisdiction and concerned with product evaluation, that maintains periodic inspection of production of labeled equipment or materials, and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

1.3.11 Liquid.

1.3.11.1 Combustible Liquid. Any liquid that has a closed-cup flash point at or above 100°F (37.8°C), as determined by the test procedures and apparatus set forth in NFPA 30, *Flammable and Combustible Liquids Code*, 1.7.4. Combustible liquids are classified as Class II or Class III as follows: (a) *Class II Liquid* — any liquid that has a flash point at or above 100°F (37.8°C) and below 140°F (60°C); (b) *Class IIIA* — any liquid that has a flash point at or above 140°F (60°C), but below 200°F (93°C); (c) *Class IIIB* — any liquid that has a flash point at or above 200°F (93°C). (30:1.7.3.1)

1.3.11.2 Flammable Liquid. Any liquid that has a closed-cup flash point below 100°F (37.8°C), as determined by the test procedures and apparatus set forth in NFPA 30, *Flammable and Combustible Liquids Code*, 1.7.4. Flammable liquids are classified as Class I as follows: (a) *Class I Liquid* — any liquid that has a closed-cup flash point below 100°F (37.8°C) and a Reid vapor pressure not exceeding 40 psia (2068.6 mm Hg) at 100°F (37.8°C), as determined by ASTM D 323, *Standard Method of Test for Vapor Pressure of Petroleum Products (Reid Method)*. Class I liquids are further classified as follows: (1) *Class IA liquids* — those liquids that have flash points below 73°F (22.8°C) and boiling points below 100°F (37.8°C); (2) *Class IB liquids* — those liquids that have flash points below 73°F (22.8°C) and boiling points at or above 100°F (37.8°C); (3) *Class IC liquids* — those liquids that have flash points at or above 73°F (22.8°C), but below 100°F (37.8°C). (30:1.7.3.2)

1.3.12* Listed. Equipment, materials, or services included in a list published by an organization that is acceptable to the authority having jurisdiction and concerned with evaluation of products or services, that maintains periodic inspection of production of listed equipment or materials or periodic evaluation of services, and whose listing states that either the equipment, material, or service meets appropriate designated standards or has been tested and found suitable for a specified purpose.

1.3.13 Mine Operator. Any owner, lessee, or other person who operates, controls, or supervises a mine.

1.3.14 Mobile. Any equipment in use without its own motive power train and normally moved by self-propelled equipment.

1.3.15 Noncombustible. Not capable of supporting combustion.

1.3.16 Normal Operation. The regular performance of those functions for which a machine or accessory is designed.

1.3.17 Portable Extinguisher. Extinguishers of the hand-held or wheeled type that are capable of being carried or moved about; or transportable systems consisting of a hose reel or rack, hose, and discharge nozzle assembly connected to a supply of suppressant.

1.3.18 Self-Propelled Equipment. Any unit that contains a motive power train as an integral part of the unit and is not rail mounted.

1.3.19 Shall. Indicates a mandatory requirement.

1.3.20 Should. Indicates a recommendation or that which is advised but not required.

Chapter 2 Fire Protection

2.1 Fire Protection. Fire protection for the purposes of this standard shall be defined in the broad sense to include fire prevention, fire detection, and fire suppression. The following sections shall address these three aspects of fire protection within the context of a fire risk assessment.

2.2* Fire Risk Assessment.

2.2.1 A fire risk assessment shall be performed on all self-propelled and mobile surface mining equipment.

2.2.1.1 This assessment shall include evaluation of the potential for the start and spread of fire, generation of smoke, gases, or toxic fumes, and explosion that can endanger the lives and safety of personnel or cause damage to property.

2.2.1.2 A separate fire risk assessment for each piece of mining equipment shall be conducted when variations in design, use, condition, and environment could change the fire potential.

2.2.2* The assessment shall include an evaluation of the following:

- (1) Methods for minimizing or eliminating existing hazardous conditions
- (2) Use of detection and early fire warning devices
- (3) Normal and emergency means of egress from a workplace
- (4) Presence of barriers or enclosures to prevent or contain the spread of fire
- (5) Availability of fire-fighting personnel and existing fire-suppression equipment
- (6) Any other devices or procedures necessary to protect life and property
- (7) Use of fire-suppression systems and equipment

2.3* Risk Reduction. Risk reduction practices shall follow the principles of minimizing ignition sources and reducing exposure of combustible materials to ignition sources.

2.3.1 Housekeeping.

2.3.1.1 Spills, leaks, excess lubricants, and combustible materials such as oil-soaked wastes, rubbish, and accumulations of environmental debris shall not be allowed to accumulate in quantities that could create a fire hazard.

2.3.1.2 Approved metal receptacles shall be provided where oil-soaked wastes or rubbish are not immediately removed to a safe place for disposal.

2.3.1.3 The storage and handling of flammable or combustible liquids on or within equipment shall be in accordance with Section 4.5 of NFPA 30, *Flammable and Combustible Liquids Code*.

2.3.1.4 Access to fire protection equipment on mining equipment shall be kept clear of obstructions.

2.3.2 Welding and Cutting.

2.3.2.1 Gas and electric welding or cutting procedures shall be in accordance with NFPA 51B, *Standard for Fire Prevention During Welding, Cutting, and Other Hot Work*.

2.3.2.2 Cutters, welders, and their supervisors shall be trained in the operation of equipment.

2.3.2.3 Cutting and welding equipment shall be maintained in operating condition with all necessary safeguards in place and functioning.

2.3.2.4 Compressed gases used for cutting and welding on or within the equipment shall be stored in accordance with Chapter 2 of NFPA 51, *Standard for the Design and Installation of Oxygen-Fuel Gas Systems for Welding, Cutting, and Allied Processes*.

2.3.2.5 Fully charged and operable fire extinguishers, specifically designed for the class of fire to be expected, shall be available at the work area. Where extinguishant hoselines are available, they shall be connected and ready for service.

2.3.2.6 Combustibles posing a fire hazard shall be relocated or protected with a fire-retardant cover or fire-retardant barrier. Openings or cracks in walls, partitions, floor decks, or ducts shall be covered tightly to prevent the passage of sparks to adjacent areas.

2.3.2.7 Where welding on a metal wall, partition, ceiling, or roof, precautions shall be taken to prevent ignition of combustibles on

the other side due to conduction or radiation. Such combustibles shall be relocated, or a fire watch shall be provided on the opposite side from the work.

2.3.2.8 Where a fire watch is required, it shall be maintained for a minimum of 30 minutes after completion of cutting or welding operations to detect and extinguish smoldering combustibles.

2.3.2.9 The fire watch shall have fire extinguishing equipment readily available and be trained in its use.

2.3.2.10 Fire watchers shall be familiar with the facilities and the procedures for sounding an alarm in the event of a fire.

2.3.2.11 Welding or cutting on equipment or within enclosed areas of equipment shall not be performed in the presence of atmospheres containing flammable mixtures of gases, vapors, or liquids with air, or combustible mixtures of dust in suspension with air.

2.3.2.12* Welding or cutting shall not be performed on or within containers or tanks located on equipment, that have contained combustible or flammable materials, until such containers or tanks have been thoroughly purged and cleaned or inerted.

2.3.2.13 Welding or cutting on equipment shall not be performed within 50 ft (15.7 m), measured horizontally, of explosives, blasting agents, or mine fuel storage areas.

2.3.3 Inspection and Maintenance. Hydraulic, coolant, lubrication and fuel lines, electrical wiring, and fire prevention devices shall be inspected and maintained in accordance with manufacturer's recommendations.

2.3.4 Training. Personnel shall be instructed in the emergency procedures to be followed during a fire.

2.4 Fire Detection and Suppression Equipment.

2.4.1 Portable Fire Extinguishers.

2.4.1.1 All self-propelled surface mining equipment, including but not limited to bulldozers, front-end loaders, haulage trucks, cranes, graders, scrapers, draglines, drills, shovels, and mobile diesel and electrical equipment shall be equipped with at least one listed portable multipurpose (ABC) dry chemical extinguisher.

2.4.1.2 Fire extinguishant applied by hand-portable extinguishers to hazards involving energized electrical equipment shall be nonconductive.

2.4.1.3 Portable extinguishers shall be maintained in a charged and operable condition and shall be kept in their designated places at all times.

2.4.1.4 Extinguishers shall be located conspicuously and shall be accessible.

Exception: In areas where obstruction to visual observation cannot be completely avoided, visible markings shall be provided to indicate the location.

2.4.1.5 Extinguishers installed under conditions where they can be subject to physical damage shall be guarded to protect against damage.

2.4.1.6* A fire risk assessment shall determine the size, number, placement, rating, and nominal capacity of extinguishers required, commensurate with equipment size, configuration and hazards posed, and whether mobile equipment requires portable extinguishers.

2.4.1.7 Portable extinguishers installed on small units of self-propelled and mobile mining equipment including but not limited to miniature loaders, individual personnel transports, and small mobile generators shall have a minimum rating of 2A-10B, C and a minimum nominal capacity of 5 lb (2.27 kg) of extinguishing agent.

2.4.1.8 The installation of an automatic or manually operated fire suppression system shall not eliminate the portable fire extinguisher requirement.

2.4.1.9 Portable fire extinguishers shall be inspected, maintained, and recharged as specified in NFPA 10, *Standard for Portable Fire Extinguishers*, Chapter 4, "Inspection, Maintenance, and Recharging," and the following:

- (1) Portable fire extinguishers shall be inspected visually at least monthly.
- (2) The visual inspection shall ensure the following:
 - a. The extinguisher is in its designated place.
 - b. The tamper seals are intact.
 - c. The extinguisher gauge is in the operable range (if extinguisher is stored-pressure type).
 - d. There is no obvious physical damage or condition that will prevent proper operation.
- (3) Extinguishers found to be defective or deficient by visual inspection shall be replaced.
- (4) Extinguishers shall be subjected to a maintenance examination at least once every year.
- (5) Maintenance procedures shall include a thorough examination of the extinguishers, including mechanical parts, extinguishing agent, and expellant.
- (6) Any troubles or impairments shall be corrected by competent personnel.
- (7) All extinguishers shall be recharged after use in accordance with the manufacturer's recommendations.
- (8) Each extinguisher shall have a durable tag or label securely attached on which the date and initials of the person performing the maintenance services shall be recorded. The same record tag or label can indicate if recharging was also performed.

2.4.1.10 Portable extinguishers shall be tested hydrostatically at intervals not exceeding those specified in NFPA 10, *Standard for Portable Fire Extinguishers*, Chapter 5, "Hydrostatic Testing."

2.4.2 Fire Detection.

2.4.2.1 Fire detectors shall be permitted to be used to initiate audible or visual warning, automatic actuation of a fire suppression system, or equipment shutdown.

2.4.2.2* Fire detectors shall be tested and listed for the application.

2.4.2.3 Compartment sizes and contours, airflow patterns, obstructions, and other characteristics of the protected area shall determine the placement, type, sensitivity, durability and, where applicable, the number of detectors.

2.4.2.4 All fire detection systems and applicable equipment shall be tested after installation in accordance with NFPA 72, *National Fire Alarm Code*®, and fire suppression systems standards. It shall not be necessary for testing to require the discharge of any associated fire suppression system.

2.4.2.5 At least every 12 months, all fire detection systems including alarms, shutdowns, and other associated equipment shall be thoroughly examined and checked for proper opera-

tion by competent personnel in accordance with the manufacturer's recommendations. Any equipment found deficient shall be repaired or replaced and the system retested for proper operation.

2.4.2.6 Between the regular maintenance examinations or tests, the detection system shall be inspected visually by competent personnel, in accordance with an approved schedule necessitated by conditions as determined by the mine operator.

2.4.3 Fixed Suppression Systems.

2.4.3.1* A fire risk assessment shall determine whether self-propelled and mobile equipment shall require a fixed fire suppression system.

2.4.3.2 Mining equipment requiring a fire suppression system shall be protected by a system of sufficient size to suppress potential fires in the protected areas and shall comply with the following.

(a) The fire suppression system shall be approved for the purpose. Where installed, the equipment shall be located or guarded so as to be protected against physical damage.

(b) Fire suppression systems shall be either automatically or manually actuated. Automatically actuated systems shall also have a manual actuator capable of being activated from the operator's compartment or other location.

(c) Depending upon the size of the equipment, additional ground-level manual actuators could be needed to provide quick access for manual activation of the system.

(d) Agent distribution hose or pipe shall be secured and protected against damage, including abrasion and corrosion.

(e) Discharge nozzles shall be protected against entrance of environmental debris, including moisture, dust, dirt, or insects, by blow-off caps or other similar devices or materials. The nozzle cover shall open or blow off upon discharge of the system.

Exception: Paragraphs (b), (c), and (e) shall not apply to suppression systems using automatic sprinklers.

(f) The automatic fire-suppression system shall be installed so that system actuation causes shutdown of the protected equipment.

2.4.3.3 A standby source of power shall be provided where electrical power is the only means of fire suppression system actuation.

2.4.3.4 All fire suppression equipment and systems shall be tested after installation in accordance with the manufacturer's or designer's recommendations. Testing shall not require the discharge of suppressant unless there is no other satisfactory manner in which the reliability and integrity of the system can be verified.

2.4.3.5 An installation-and-maintenance or owner's manual that describes system operation and maintenance requirements shall be provided for all fire suppression equipment.

2.4.3.6 In accordance with manufacturer's or designer's recommended inspection and maintenance procedures and schedules, but not to exceed every 12 months, all fire suppression systems including alarms, shutdowns, and other associated equipment shall be thoroughly examined and checked for proper operation by competent personnel. Any equipment found deficient shall be repaired or replaced and the system retested for proper operation. Between the regular maintenance examinations or tests, the system shall be inspected visually by competent personnel, in accordance with the manufacturer's or

designer's recommended schedule. Testing shall be in accordance with the appropriate NFPA standard.

2.4.3.7 Fire suppression systems shall be maintained in operating condition at all times. Use, impairment, and restoration of the system shall be reported promptly to the mine operator.

2.4.3.8 All persons who can be expected to inspect, test, maintain, or operate a fire suppression system shall be trained to perform their intended tasks.

2.4.3.9 Where inadvertent discharge of the fire suppression system during servicing could result in injury to personnel, provisions shall be made to safeguard against accidental actuation of the system.

2.4.4 Training. All self-propelled and mobile equipment operators, supervisors, and maintenance personnel shall be trained in the proper use of fire suppression equipment.

Chapter 3 Referenced Publications

3.1 The following documents or portions thereof are referenced within this standard as mandatory requirements and shall be considered part of the requirements of this standard. The edition indicated for each referenced mandatory document is the current edition as of the date of the NFPA issuance of this standard. Some of these mandatory documents might also be referenced in this standard for specific informational purposes and, therefore, are also listed in Appendix D.

3.1.1 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

NFPA 10, *Standard for Portable Fire Extinguishers*, 1998 edition.

NFPA 30, *Flammable and Combustible Liquids Code*, 2000 edition.

NFPA 51, *Standard for the Design and Installation of Oxygen-Fuel Gas Systems for Welding, Cutting, and Allied Processes*, 1997 edition.

NFPA 51B, *Standard for Fire Prevention During Welding, Cutting, and Other Hot Work*, 1999 edition.

NFPA 72, *National Fire Alarm Code*®, 1999 edition.

3.1.2 ASTM Publication. American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959.

ASTM D 323, *Standard Method of Test for Vapor Pressure of Petroleum Products (Reid Method)*, 1999.

Appendix A Explanatory Material

Appendix A is not a part of the requirements of this NFPA document but is included for informational purposes only. This appendix contains explanatory material, numbered to correspond with the applicable text paragraphs.

A.1.1 Fires adversely affect all types of self-propelled and mobile surface mining equipment including, but not limited to, trucks, front-end loaders, crawlers, drills, shovels, and draglines. Most fires occur on or near engine exhaust systems, high speed drive lines, malfunctioning high pressure-high temperature hydraulic systems, or faulty electrical components.

Total elimination of fire hazards is impossible since sources of ignition and fuel for fires are inherent in the basic equipment design. The fire problem is further complicated by the collection of environmental debris. Therefore, efforts to reduce fire losses must be aimed at fire prevention and fire suppression.

To improve fire protection and prevention on surface mining equipment, some manufacturers of mining equipment have placed emphasis on the reduction of the fire potential of specific items in the original design of their equipment. Such items include turbochargers, exhaust manifolds and exhaust pipe shielding and insulation, location of combustible and flammable liquid reservoirs, and hydraulic and fuel line routing.

Most surface mining equipment is required to have at least one hand-portable extinguisher mounted in a readily accessible location. Extinguishers are most effective where used by trained operators. However, considering the size and configuration of machines found at a mine, fires can be difficult or impossible to fight with a hand-held extinguisher. For this reason, fire suppression systems have been developed to aid in suppressing those fires that are hard to access and thereby to reduce "off-road" equipment fire losses.

The key to operator protection is early detection of fires to provide a warning to the operator, fuel shut-off to minimize fuel for the fire, and fire suppression during its earliest stages. Specialized systems to perform these functions can be required to protect the operator and the machines. To be totally effective, however, system operation must be fully understood by owners and operators, and provisions must be made for periodic inspection and maintenance.

Fire suppression systems, including hand-portable extinguishers, offer the mining industry a cost-effective tool by which personnel and investments in mining equipment can be protected.

A.1.3.1 Approved. The National Fire Protection Association does not approve, inspect, or certify any installations, procedures, equipment, or materials; nor does it approve or evaluate testing laboratories. In determining the acceptability of installations, procedures, equipment, or materials, the authority having jurisdiction may base acceptance on compliance with NFPA or other appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure, or use. The authority having jurisdiction may also refer to the listings or labeling practices of an organization that is concerned with product evaluations and is thus in a position to determine compliance with appropriate standards for the current production of listed items.

A.1.3.2 Authority Having Jurisdiction. The phrase "authority having jurisdiction" is used in NFPA documents in a broad manner, since jurisdictions and approval agencies vary, as do their responsibilities. Where public safety is primary, the authority having jurisdiction may be a federal, state, local, or other regional department or individual such as a fire chief; fire marshal; chief of a fire prevention bureau, labor department, or health department; building official; electrical inspector; or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the authority having jurisdiction. In many circumstances, the property owner or his or her designated agent assumes the role of the authority having jurisdiction; at government installations, the commanding officer or departmental official may be the authority having jurisdiction.

A.1.3.12 Listed. The means for identifying listed equipment may vary for each organization concerned with product evaluation; some organizations do not recognize equipment as listed unless it is also labeled. The authority having jurisdiction

should utilize the system employed by the listing organization to identify a listed product.

A.2.2 See Appendix B.

A.2.2.2 For additional information, see Appendix B.

A.2.3 See Appendix B.

A.2.3.2.12 For additional information, see NFPA 326, *Standard for the Safeguarding of Tanks and Containers for Entry, Cleaning, or Repair*.

A.2.4.1.6 For additional information, see Appendix B.

A.2.4.2.2 See Appendix B.

A.2.4.3.1 See Appendix B for suggested procedure.

Appendix B Fire Risk Assessment

This appendix is not a part of the requirements of this NFPA document but is included for informational purposes only.

B.1 Fire Risk Assessment. A fire risk assessment consists of the following four phases:

- (1) Identify the potential for fire and explosion.
- (2) Assess the consequences of fire and explosion.
- (3) Determine the need for fire protection.
- (4) Select appropriate option(s).

The following fire risk assessment outline is a suggested procedure to identify the elements in the items defined above. Figure B.1 provides a diagram of the process.

Additional guidance in performing fire risk assessments is provided in several of the reference publications listed in Appendix C.


B.1.1 Identify the Potential for Fire and Explosion.

(a) Ignition Sources.

- (1) *High Temperature.* High temperatures are usually found in the vicinity of a vehicle engine, exhaust system, pumps, turbochargers, batteries, wiring, switches, electrical motors, generators, and friction sources such as bearings, brakes, and gears.
- (2) *Electrical.* Electrical ignition sources include switch gear, motor control centers, circuit breakers, motors and generators, transformers, battery boxes, substations, cable reels, trays, and splices and collector rings.
- (3) *Welding and Cutting.*
- (4) *Other.* Smoking materials, chemical reactions, and spontaneous ignition sources are examples of other sources.

(b) Fuel Sources.

- (1) *Class A.* These materials include combustible debris, wood, rags, electrical insulation, coal dust, upholstery, hoses, tires, and seats.
- (2) *Class B.* This group includes flammable and combustible liquid materials such as gasoline, diesel fuel, liquefied petroleum gas (propane), hydraulic fluids, some coolant combinations, grease, and oil.
- (3) *Class D.* Some new machines have magnesium transmission components that cannot be extinguished with conventional fire suppression agents.

FIGURE B.1 Fire risk assessment chart.

(c) Probability of the Coexistence of Fuel and Ignition Sources.

(1) Proximity of Fuel to Ignition Sources.

- a. *Machine Design.* An assessment should be made of existing areas where lubrication, hydraulic oil, or fuel lines are in proximity to an engine surface or other heat-emitting equipment component. Other areas include equipment articulation points, parking brakes, engine pan area, and battery compartments. Areas not to be overlooked on larger equipment include roller path/collector ring areas, electrical switch gear, and transformer compartments. Existing thermal shields, hose routing, electrical harnesses, and their support can influence the potential for fire.
- b. In identifying risk areas note that a combustible liquid can spray or drip onto a hot surface remote from the rupture or leak point. Likewise, spatter from a battery or an electrical switch short can carry heat to another area of the machine.

c. Many similarities of equipment design and operation exist among the manufacturers. However, within each of the equipment categories there are variations in configurations that could directly influence the fire potential.

- (2) *Fire Incident Experience.* Previous fire experience on similar machines should be considered in the fire risk assessment. Past experience can indicate that special hazards exist, such as hydraulic hose that frequently comes loose at a specific connection on the equipment, equipment that has an adverse fire history, or other component failures that increase fire potential.

(3) Quality of Maintenance.

a. *Type and Quality of Replacement Parts.* Replacement parts should be at least equal in performance to original parts. Examples are hoses, bearings, fittings, and electrical equipment.

b. *Frequency.* Maintenance should be performed in accordance with recommendations and schedules supplied by the equipment manufacturer.

- (4) *Housekeeping.* The presence of accumulations of combustible materials such as oil-soaked waste, fuel spillage, excess lubricant, and coal dust represent potential fire hazards.

B.1.2 Assess the Consequences of Fire and Explosion.

(a) Personnel Exposure.

- (1) *Number and Location.* Determine the number of persons involved and their location during routine and maintenance operations.
- (2) *Risk Exposure.* Determine the exposure to potential fire and explosion risks for each person, and whether the fire and smoke could impair safe egress from their work locations.

(b) Economic Risks.

- (1) *Property Damage.* Consider the cost of repairs, replacement, cleanup, and damage to the work site.
- (2) *Business Interruption.* Items to consider are production loss, personnel overtime, interruption of customer deliveries, and replacement equipment rental.

B.1.3 Determine the Need for Fire Protection.

(a) **Mandatory Requirements.** Certain fire prevention and fire suppression requirements are mandated by company policy, insurance companies, and government agencies.

(b) **Identified Needs.** Additional fire precautions beyond those that are mandated might prove to be necessary, after the fire risk assessment.

(c) **Evaluate.** If the fire risk assessment has disclosed unacceptable personnel risks, economic risks, or both, appropriate fire protection options shall be determined. If the risks are found acceptable, no further action is required.

B.1.4 Select Appropriate Option(s).

(a) Risk Reduction.

- (1) *Machine Design.* Evaluate equipment to determine whether the risk from the start or the spread of a fire, or the risk to personnel from a fire can be reduced. Examples concerning how to reduce the start or spread of a fire include physical barriers between fuel sources and ignition sources, thermal shields over hot surfaces, hose and wiring harness routing, support, and protection, and power shutoffs. Examples for reducing the threat of fire to personnel include emergency egress provisions and relocating or shielding potential fire hazards.

- (2) *Operating Programs and Procedures.* Mine operators, through implementation of policies and procedures, can reduce the threat of fire and explosion. Examples include effective equipment maintenance programs, adequate house-keeping procedures, proper employee training, and development of emergency plans and strategies that deal with fire and explosion hazards. Such emergency plans can include use of company fire brigades and other available equipment such as fire trucks and water wagons, and the response of local fire departments.
- (3) *Evaluate.* Determine whether risk reduction reduces risks to acceptable levels. If risks are within acceptable levels no further action is required. If unacceptable risks still exist, then action is required either to further reduce hazards or to install fire detection/suppression equipment or a combination of both.

(b) Fire Detection and Suppression Equipment.

NOTE: A more detailed discussion of fire suppression and detection equipment can be found in the references in Appendix C and NFPA 10, *Standard for Portable Fire Extinguishers*.

- (1) *Identify Available Alternatives.*
 - a. *Portable Protection.* Options include hand-portable extinguishers, hose reels and lines, wheeled extinguishers, and skid-mounted extinguishers.
To handle difficult fires, larger capacity extinguishers that provide more agent, greater range, and longer discharge time are recommended for agent selection [see B.1.5(a)].
 - b. *Detection.* Fire detection devices can be used to provide early warning of fires, actuate a fire suppression system, shut down equipment, and operate other systems such as door closers and exhaust fans. [For a discussion of detector and control options, selection, and placement, see B.1.5(c) and B.1.5(d).]
 - c. *Fixed Fire Suppression Systems.* Fixed system protection can be accomplished by local application, total flooding, or a combination of both, or automatic sprinklers. [For agent selection, see B.1.5(a). For fixed fire suppression system options, see B.1.5(b).]
- (2) *Compare Capability with Need.* Mandatory requirements and identified needs should be matched with the most cost effective approach to fire detection, fire suppression, or both.
- (3) *Select Equipment.* The selection of all equipment used for detection and suppression of fires in mining equipment should be based upon consideration of the environment where the equipment will function and should be tested. Testing should include provisions for determining the adequacy and durability of the equipment, and the manufacturer should demonstrate that such tests have been conducted.
- (4) *Evaluate.* Determine whether risk reduction results in compliance with mandatory requirements, or reduces risks to acceptable levels, or both. If risks are within acceptable levels, no further action is required. If unacceptable risks still exist, then action is required either to reduce hazards further or to install fire detection/suppression equipment or a combination of both.

B.1.5 Fire Protection Agents and Equipment.

(a) **Fire Suppression Agents.** The following extinguishants are commonly used in the mining industry:

- (1) *Class A.* Dry chemicals (ABC) with ammonium phosphate as the basic ingredient.
 - a. Foams: protein, fluoroprotein, aqueous film forming, medium and high expansion
 - b. Water
 - c. Clean agents
 - d. Halons
- (2) *Class B.* Dry chemicals (BC) with sodium bicarbonate, ammonium phosphate, potassium bicarbonate, urea-based potassium bicarbonate, or potassium chloride as the basic composition.
 - a. Foams: protein, fluoroprotein, aqueous film forming foam, medium and high expansion
 - b. Carbon dioxide
 - c. Halons
 - d. Water
 - e. Clean agents
- (3) *Class C.* Dry chemicals (ABC or BC) with sodium bicarbonate, ammonium phosphate, potassium bicarbonate, urea-based potassium bicarbonate, or potassium chloride as the basic composition.
 - a. Carbon dioxide
 - b. Halons
 - c. Water
 - d. Clean agents
- (4) *Class D.* Dry powder agents composed of sodium chloride or graphite with other particulate material added. Inert materials such as dry sand, foundry flux, and so on.

(b) Method of Application.

- (1) *Fixed Systems.* The design and layout of fixed fire suppression systems should be based upon the method of application of the fire suppressant to the area to be protected. Methods of delivery include the following:
 - a. Local application consisting of a supply of suppressant permanently connected to a distribution system arranged to discharge onto a defined area or space
 - b. Total flooding consisting of a supply of suppressant permanently connected to a distribution system arranged to discharge into an enclosed space
 - c. A combination of a. and b. above
 - d. Automatic sprinklers consisting of a supply of suppressant (normally water) permanently connected to a distribution system to discharge the suppressant

(c) Detector Options.

- (1) Automatic fire detection devices are covered by NFPA 72, *National Fire Alarm Code*. One fire detection device that is commonly used in self-propelled and mobile mining equipment but is not covered in NFPA 72 is fusible plastic tube. It comprises a sensing element consisting of a plastic tube pressurized with inert gas. Heat from the fire causes the tube to burst, releasing the gas pressure and activating a mechanical pneumatic actuator.
- (2) *Fire Detector Placement.* Consideration should be given to the physical configuration of the area to be protected when selecting and locating detectors. A detector's response time is dependent upon its type and proximity to a fire. For spacing, see NFPA 72, *National Fire Alarm Code*.

Other factors to be considered in fire detector placement are ambient temperature, climatic conditions, shock and vibration, air contamination, ventilation flows, and maintenance requirements.

(d) Control Options.

- (1) Depending on mining equipment configuration, use, ground speed capability, degree of hazard enclosure, operating personnel locations, and other factors, consideration may be required of system control options such as the following:
 - a. Discharge time delay
 - b. Discharge abort switch
 - c. Audible and visual alarms
 - d. Pre-discharge alarm
 - e. Detection circuit supervision

B.2 Electrical Ignition Hazards. Self-propelled and mobile surface mining equipment powered by electrical energy are normally supplied through portable electrical power cables carrying high-voltage, three-phase, ac power. Existing regulations require that the electrical system be designed to protect personnel by limiting the voltage rise of the machine frame, in the event of a ground fault, to a maximum of 100 volts. Protection on such electrical systems includes the following:

- (1) Normal overcurrent protection
- (2) Ground-fault current limitation (normally to about 15 amperes)
- (3) Ground-fault overcurrent tripping (usually at about 7 amperes to 10 amperes)
- (4) Monitoring of continuity of the ground conductor in the trailing cable and instantaneous tripping if continuity is lost

Electrical systems having these protective features are singularly free of fires, as fault current is low and faults are cleared rapidly.

When equipment contains one or more transformers designed and installed to reduce the high voltage supplied through the portable cable to a lower utilization voltage, no requirements for ground-fault current limitation or tripping on ground-fault interruptors are necessary. All equipment on the machine is effectively frame grounded, and there is no risk to personnel due to frame voltage rise.

Alternatively, a ground detection system can be used on an ungrounded utilization voltage system, provided the first ground, which would cause an alarm, is found and repaired promptly. Use of a time delay to allow an orderly and safe shutdown of a machine followed by automatic removal of power from the grounded circuit is recommended.

Appendix C Suggested References

This appendix is not a part of the requirements of this NFPA document but is included for informational purposes only.

C.1 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

NFPA 10, *Standard for Portable Fire Extinguishers*, 1998 edition.

NFPA 11, *Standard for Low-Expansion Foam*, 1998 edition.

NFPA 11A, *Standard for Medium- and High-Expansion Foam Systems*, 1999 edition.

NFPA 12, *Standard on Carbon Dioxide Extinguishing Systems*, 2000 edition.

NFPA 12A, *Standard on Halon 1301 Fire Extinguishing Systems*, 1997 edition.

NFPA 13, *Standard for the Installation of Sprinkler Systems*, 1999 edition.

NFPA 14, *Standard for the Installation of Standpipe, Private Hydrant, and Hose Systems*, 2000 edition.

NFPA 15, *Standard for Water Spray Fixed Systems for Fire Protection*, 1996 edition.

NFPA 17, *Standard for Dry Chemical Extinguishing Systems*, 1998 edition.

NFPA 20, *Standard for the Installation of Stationary Pumps for Fire Protection*, 1999 edition.

NFPA 22, *Standard for Water Tanks for Private Fire Protection*, 1998 edition.

NFPA 51B, *Standard for Fire Prevention During Welding, Cutting, and Other Hot Work*, 1999 edition.

NFPA 69, *Standard on Explosion Prevention Systems*, 1997 edition.

NFPA 70, *National Electrical Code*®, 1999 edition.

NFPA 72, *National Fire Alarm Code*®, 1999 edition.

NFPA 230, *Standard for the Fire Protection of Storage*, 1999 edition.

NFPA 326, *Standard for the Safeguarding of Tanks and Containers for Entry, Cleaning, or Repair*, 1999 edition.

NFPA 385, *Standard for Tank Vehicles for Flammable and Combustible Liquids*, 2000 edition.

NFPA 1962, *Standard for the Care, Use, and Service Testing of Fire Hose Including Couplings and Nozzles*, 1998 edition.

NFPA 1963, *Standard for Fire Hose Connections*, 1998 edition.

NFPA 2001, *Standard on Clean Agent Fire Extinguishing Systems*, 2000 edition.

Fire Protection Guide to Hazardous Materials, 11th Edition, NFPA, 1997.

Fire Protection Handbook, 17th Edition, NFPA, 1991.

C.2 Other Publications.

C.2.1 ANSI Publications. American National Standards Institute Inc., 11 West 42nd Street, 13th floor, New York, NY 10036.

ANSI A92.2, *Vehicle-Mounted Elevating and Rotating Aerial Devices*, 1979.

ANSI A92.3, *Elevating Work Platforms, Manually Propelled*, 1980.

ANSI B30.5, *Mobil and Locomotive Cranes*, 1994.

ANSI 505, *Powered Industrial Trucks (NFPA 505-1981)*, 1992.

ANSI 583, *Battery Powered Trucks (UL 583-1977)*, 1991.

C.2.2 ASTM Publication. American Society of Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959.

ASTM E 136, *Test Method for Behavior of Materials in a Vertical Tube Furnace at 750°C*, 1994.

C.2.3 IEEE Publication. Institute of Electrical and Electronics Engineers, Inc., 445 Hoes Lane, P.O. Box 1331, Piscataway, NJ 08855-1331.

IEEE Standard 446, *Recommended Practice for Emergency and Standby Power Systems for Industrial and Commercial Applications*, 1987.

C.2.4 SAE Publications. Society of Automotive Engineers, 400 Commonwealth Drive, Warrendale, PA 15096.

SAE J53, *Minimum Performance Criteria for Emergency Steering of Wheeled Earthmoving Construction Machines, Recommended Practice*, 1984.

SAE J185, *Access Systems for Off-Road Machines, Recommended Practice*, 1988.

SAE J833A USA, *Male and Female Physical Dimensions for Construction and Industrial Equipment*, 1980.

SAE J925, *Minimum Access Dimensions for Construction and Industrial Equipment*, 1993.