

NFPA 1403

Standard on Live Fire Training Evolutions

1997 Edition



National Fire Protection Association, 1 Batterymarch Park, PO Box 9101, Quincy, MA 02269-9101
An International Codes and Standards Organization

Copyright ©
National Fire Protection Association, Inc.
One Batterymarch Park
Quincy, Massachusetts 02269

IMPORTANT NOTICE ABOUT THIS DOCUMENT

NFPA codes, standards, recommended practices, and guides, of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in its codes and standards.

The NFPA disclaims liability for any personal injury, property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on this document. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making this document available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of this document. Nor does the NFPA list, certify, test or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

NOTICES

All questions or other communications relating to this document and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA documents during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

Users of this document should be aware that this document may be amended from time to time through the issuance of Tentative Interim Amendments, and that an official NFPA document at any point in time consists of the current edition of the document together with any Tentative Interim Amendments then in effect. In order to determine whether this document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments, consult appropriate NFPA publications such as the *National Fire Codes*[®] Subscription Service, visit the NFPA website at www.nfpa.org, or contact the NFPA at the address listed above.

A statement, written or oral, that is not processed in accordance with Section 5 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

The NFPA does not take any position with respect to the validity of any patent rights asserted in connection with any items which are mentioned in or are the subject of this document, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on this document. Users of this document are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Users of this document should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of this document, intend to urge action that is not in compliance with applicable laws, and this document may not be construed as doing so.

Licensing Policy

This document is copyrighted by the National Fire Protection Association (NFPA). By making this document available for use and adoption by public authorities and others, the NFPA does not waive any rights in copyright to this document.

1. Adoption by Reference—Public authorities and others are urged to reference this document in laws, ordinances, regulations, administrative orders, or similar instruments. Any deletions, additions, and changes desired by the adopting authority must be noted separately. Those using this method are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. The term "adoption by reference" means the citing of title and publishing information only.

2. Adoption by Transcription—**A.** Public authorities with lawmaking or rule-making powers only, upon written notice to the NFPA (Attention: Secretary, Standards Council), will be granted a royalty-free license to print and republish this document in whole or in part, with changes and additions, if any, noted separately, in laws, ordinances, regulations, administrative orders, or similar instruments having the force of law, provided that: (1) due notice of NFPA's copyright is contained in each law and in each copy thereof; and (2) that such printing and republication is limited to numbers sufficient to satisfy the jurisdiction's lawmaking or rule-making process. **B.** Once this NFPA Code or Standard has been adopted into law, all printings of this document by public authorities with lawmaking or rule-making powers or any other persons desiring to reproduce this document or its contents as adopted by the jurisdiction in whole or in part, in any form, upon written request to NFPA (Attention: Secretary, Standards Council), will be granted a nonexclusive license to print, republish, and vend this document in whole or in part, with changes and additions, if any, noted separately, provided that due notice of NFPA's copyright is contained in each copy. Such license shall be granted only upon agreement to pay NFPA a royalty. This royalty is required to provide funds for the research and development necessary to continue the work of NFPA and its volunteers in continually updating and revising NFPA standards. Under certain circumstances, public authorities with lawmaking or rule-making powers may apply for and may receive a special royalty where the public interest will be served thereby.

3. Scope of License Grant—The terms and conditions set forth above do not extend to the index of this document.

(For further explanation, see the Policy Concerning the Adoption, Printing, and Publication of NFPA Documents, which is available upon request from the NFPA.)

Copyright © 1997 NFPA, All Rights Reserved

NFPA 1403
Standard on
Live Fire Training Evolutions
1997 Edition

This edition of NFPA 1403, *Standard on Live Fire Training Evolutions*, was prepared by the Technical Committee on Fire Service Training and acted on by the National Fire Protection Association, Inc., at its Fall Meeting held November 18–20, 1996, in Nashville, TN. It was issued by the Standards Council on January 17, 1997, with an effective date of February 7, 1997, and supersedes all previous editions.

Changes other than editorial are indicated by a vertical rule in the margin of the pages on which they appear. These lines are included as an aid to the user in identifying changes from the previous edition.

This edition of NFPA 1403 was approved as an American National Standard on February 7, 1997.

Origin and Development of NFPA 1403

The ongoing training of fire fighters is the cornerstone of good fire protection in today's world. However, the benefits derived from live fire training can be negated by the injuries and deaths suffered by fire fighters under unsafe and poorly supervised training conditions. Following a tragic training accident in 1982, which resulted in the deaths of two fire fighters, the Committee on Fire Service Training was urged to address the issue of live fire training evolutions in structures. The committee proceeded to develop NFPA 1403 in order to provide recognized safe practices for conducting such training evolutions. The document was well received following its adoption and served as the basis for live fire training evolutions throughout the United States. The document was updated by the committee in 1991.

In this new 1997 edition, the Committee on Fire Service Training has combined NFPA 1406, *Outside Live Fire Training Evolutions*, and NFPA 1403, *Live Fire Training Evolutions in Structures*, into one document.

Technical Committee on Fire Service Training

John W. Hoglund, *Chair*
University of Maryland, MD [E]

William E. Peterson, *Vice Chair*
Plano Fire Dept., TX [E]
Rep. Fire Marshals Assn. of North America

Roger W. Bassett, R. W. Bassett & Assoc., IL [SE]
Edward W. Bent, Sacramento, CA [SE]
Michael L. Calhoun, North Carolina Dept. of Insurance, NC [E]
Gene P. Carlson, Oklahoma State University, OK [M]
Rep. Int'l Fire Service Training Assn.
W. Rolland Connelly, Jr., Burlington, NJ [SE]
John Lee Cook, Jr., Loudon County Fire Rescue, VA [U]
Rep. NFPA Fire Service Section
Jack L. Cottet, Utica Nat'l Insurance Co., NY [I]
Nicholas J. Cricenti, Jr., SFC Engr Partnership, NH [SE]
Robert F. Debrody, Symtron Systems, NJ [M]
Vincent K. Elmore, Palm Beach Fire Dept., FL [E]
David C. Grupp, Kemper Nat'l Insurance Cos., IL [I]
P. Gerald Haag, Syntex (USA) Inc., CA [SE]

T. Randy Hess, Glatfelter Insurance Group (VFIS), PA [I]
James G. Kellam, Jr., Virginia Beach Fire Dept., VA [U]
Rep. The Alliance for Fire and Emergency Mgmt.
Robert A. Lincoln, Jr., Nassau County Fire Service Academy, NY [U]
John B. Lockwood, Bowie, MD [SE]
John M. Loverin, Lawrence Livermore Nat'l Laboratory, CA [RT]
George E. Luther, Connecticut State Fire Admin, CT [E]
Charles L. Page, Texas A & M University System, TX [U]
Thomas C. Quillin, Tallahassee Fire Dept., FL [U]
James B. Straseske, Illinois Fire Service Inst., IL [U]
Phil Welch, Gaston College, NC [U]
James E. Wilson, Boardman Fire Dept., OH [E]

Alternates

Robert F. Burger, Emergency Response Mgmt. Systems, NM [SE] (Alt. to E. W. Bent)
Carl Goodson, Fire Protection Publications, OK [M] (Alt. to G. P. Carlson)

Kent W. Koelz, Palm Beach Fire/Rescue, FL [E] (Alt. to V. K. Elmore)
Steven J. Williamson, AAI Corp/Symtron Systems, NJ [M] (Alt. to R. F. Debrody)

L. Charles Smeby, Jr., NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the front of the book.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on all fire service training techniques, operations, and procedures to develop maximum efficiency and proper utilization of available personnel. Such activities may include training guides for fire prevention, fire suppression, and other missions for which the fire service has responsibility.

Contents

<p>Chapter 1 Introduction 1403- 4</p> <p>1-1 Scope 1403- 4</p> <p>1-2 Purpose 1403- 4</p> <p>1-3 General 1403- 4</p> <p>1-4 Definitions 1403- 4</p> <p>Chapter 2 Acquired Structures 1403- 4</p> <p>2-1 Student Prerequisites 1403- 4</p> <p>2-2 Structures and Facilities 1403- 5</p> <p>2-3 Fuel Materials 1403- 6</p> <p>2-4 Safety 1403- 6</p> <p>2-5 Instructors 1403- 7</p> <p>Chapter 3 Gas-Fired Training</p> <p style="padding-left: 20px;">Center Buildings 1403- 8</p> <p>3-1 Student Prerequisites 1403- 8</p> <p>3-2 Structures and Facilities 1403- 8</p> <p>3-3 Fuel Materials 1403- 9</p> <p>3-4 Safety 1403- 9</p> <p>3-5 Instructors 1403-10</p> <p>Chapter 4 Non-Gas-Fired Training</p> <p style="padding-left: 20px;">Center Buildings 1403-10</p> <p>4-1 Student Prerequisites 1403-10</p> <p>4-2 Structures and Facilities 1403-10</p> <p>4-3 Fuel Materials 1403-11</p> <p>4-4 Safety 1403-12</p> <p>4-5 Instructors 1403-13</p>	<p>Chapter 5 Exterior Props 1403-13</p> <p>5-1 Student Prerequisites 1403-13</p> <p>5-2 Structures and Facilities 1403-13</p> <p>5-3 Fuel Materials 1403-14</p> <p>5-4 Safety 1403-15</p> <p>5-5 Instructors 1403-16</p> <p>Chapter 6 Exterior Class B Fires 1403-16</p> <p>6-1 Student Prerequisites 1403-16</p> <p>6-2 Facilities 1403-16</p> <p>6-3 Fuel Materials 1403-17</p> <p>6-4 Safety 1403-18</p> <p>6-5 Instructors 1403-18</p> <p>Chapter 7 Reports and Records 1403-19</p> <p>7-1 General 1403-19</p> <p>Chapter 8 Referenced Publications 1403-19</p> <p>Appendix A Explanatory Material 1403-19</p> <p>Appendix B Live Fire Evolution Sample Checklist 1403-25</p> <p>Appendix C Responsibilities of Personnel 1403-26</p> <p>Appendix D Referenced Publications 1403-26</p> <p>Index 1403-27</p>
---	---

NFPA 1403

Standard on

Live Fire Training Evolutions

1997 Edition

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Appendix A.

Information on referenced publications can be found in Chapter 8 and Appendix D

Chapter 1 Introduction

1-1 Scope. This standard applies to the establishment of procedures for training of fire suppression personnel engaged in fire-fighting operations under live fire conditions. It is a basic system that can be adapted to local conditions to serve as a standard mechanism for live fire training. Procedures for live fire training evolutions, such as those involving aircraft, marine structures or vessels, or ground cover or wildland fires, are not covered in this standard.

1-2 Purpose. This standard applies to the training of fire fighters under live fire conditions and focuses on training for coordinated interior and exterior fire suppression operations while maintaining a minimum exposure to risk for the participants. Live fire training evolutions conducted in accordance with this standard shall be managed by means of a documented incident management system in accordance with NFPA 1561, *Standard on Fire Department Incident Management System*. The hierarchy of authority shall be made clear to all participants so that both expected and unforeseen situations are managed with the most efficiency possible and so that reasonable margins of safety are provided.

1-3* General. Interior live fire training in a training center burn building or in a suitable acquired building awaiting demolition is an excellent means of training fire fighters. While this type of training provides high levels of authenticity, it also carries with it most of the hazards of interior fire fighting at an actual emergency. Interior live fire training evolutions shall be planned with great care and supervised closely by instructional personnel. The information contained in this standard is designed to ensure adequate levels of safety while allowing the local organization some flexibility to utilize independent judgment based on local situations and the level of training to be accomplished. Likewise, exterior live fire training is also a valuable training experience, but, as with interior training, there is an inherent danger to the participants and, in the case of flammable liquids and other hazardous materials, the potential for environmental damage.

1-4 Definitions. Unless expressly stated elsewhere, the following terms shall, for the purposes of this standard, have the meanings indicated below.

Acquired Building. A structure acquired by the authority having jurisdiction from a property owner for the purpose of conducting live fire training evolutions.

Acquired Prop. A piece of equipment such as an automobile that was not designed for burning but is used for live fire evolutions.

Authority Having Jurisdiction.* The organization, office, or individual responsible for approving equipment, an installation, or a procedure.

Demonstration. The act of showing a skill.

Evolution. A set of prescribed actions that results in an effective fireground activity.

Instructor. An individual deemed qualified by the authority having jurisdiction to deliver fire fighter training; who has the training and experience to supervise students during live fire training evolutions; and is deemed at least equivalent to an Instructor I as defined in NFPA 1041, *Standard for Fire Service Instructor Professional Qualifications*.

Instructor-in-Charge. An individual qualified as an instructor and designated by the authority having jurisdiction to be in charge of the live fire training evolution.

Live Fire. Any unconfined open flame or device that can propagate fire to the building or other combustible materials.

Participant. Any student, instructor, safety officer, visitor, or other person who is involved in the live fire training evolution within the operations area.

Safety Officer. An individual qualified by the authority having jurisdiction to maintain a safe working environment at all live fire training evolutions.

Shall. Indicates a mandatory requirement.

Should. Indicates a recommendation or that which is advised but not required.

Student. Any person who is present at the live fire training evolution for the purpose of receiving training.

Training Center Burn Building. A structure specifically designed for conducting live fire training evolutions on a repetitive basis. It does not include a structure that is used primarily for training in the use of breathing apparatus where only smoke conditions are created, without a live fire, and the trainee is not subjected to risk of the effects of fire other than the smoke produced.

Chapter 2 Acquired Structures

2-1 Student Prerequisites.

2-1.1* In order to ensure safe operations during a live fire training exercise involving acquired structures, all participating students shall have achieved a minimum level of basic training.

2-1.2 Prior to being permitted to participate in live fire training evolutions, the student shall have received training to meet the performance objectives for Fire Fighter I of the following sections of NFPA 1001, *Standard for Fire Fighter Professional Qualifications*:

Section 3-3	Safety
Section 3-5	Fire Behavior
Section 3-6	Portable Extinguishers
Section 3-7	Personal Protective Equipment
Section 3-11	Ladders
Section 3-12	Fire Hose, Appliances and Streams
Section 3-16	Overhaul
Section 3-19	Water Supply

2-1.3* Students participating in a live fire training evolution who have received the required minimum basic training from other than the authority having jurisdiction shall not be permitted to participate in any live fire training evolution without presenting prior written evidence of having successfully completed the prescribed minimum training to the levels specified in 2-1.2.

2-2 Structures and Facilities.

2-2.1* Strict safety practices shall be applied to all structures selected for live fire training evolutions. These practices vary greatly in the degree of application where comparing burn building structures to acquired structures. By nature, burn buildings have been designed specifically for the purpose of repeated live fire training evolutions and include safeguards that become unacceptably hazardous only through misuse or improper maintenance. Acquired structures, on the other hand, were never designed or intended for burn applications and can lack even the fundamental elements of fire resistance due to their disrepair.

2-2.2 Any building that is considered for a structural fire training exercise shall be prepared properly for the live fire training evolution. Preparation can include application for proper permits and permissions relinquishing the acquired building after the live fire training evolution is completed. The permits required for the exercise, including permits for air quality, water runoff, water usage, burning, and traffic shall be researched thoroughly.

2-2.3* Ownership of the acquired building shall be determined prior to acceptance by the authority having jurisdiction. Evidence of clear title shall be required for all structures acquired for live fire training evolutions.

2-2.4* Written permission shall be secured from the owner of the structure in order for the fire department to conduct live fire training evolutions within the acquired building. A clear description of the anticipated condition of the acquired building at the completion of the evolution(s) shall be put in writing and shall be acknowledged by the owner of the structure.

2-2.5* Proof of insurance cancellation or a signed statement of nonexistence of insurance shall be provided by the owner of the structure prior to acceptance of the acquired building by the authority having jurisdiction.

2-2.6 All appropriate and required permits to conduct live fire training evolutions shall be obtained.

2-2.7 The permits specified in this chapter shall be provided to outside, contract, or other separate training agencies by the authority having jurisdiction upon the request of those agencies.

2-2.8 In preparation for live fire training, an inspection of the structure shall be made to determine that the floors, walls, stairs, and other structural components are capable of withstanding the weight of contents, participants, and accumulated water.

2-2.9* Removal or neutralization of all hazardous storage and conditions within the structure shall be accomplished. Closed containers and highly combustible materials shall be removed. Oil tanks and similar closed vessels that cannot easily be removed shall be vented sufficiently to eliminate an explosion or overpressure rupture, and any hazardous or combustible atmosphere within the tank or other vessel shall be rendered inert. Hazards potentially dangerous to participants, such as floor openings, missing stair treads and rails, and other such hazards, shall be repaired or made inaccessible.

2-2.10* In order to secure optimum personal safety from unforeseen environmental hazards for all participants, a careful examination of the building or structure shall be con-

ducted to determine that the following items have been addressed, if applicable to the specific evolution:

- (a) Floors, railings, and stairs shall be made safe.
- (b) Special attention shall be given to potential chimney hazards.
- (c) All walls and ceilings shall be intact or patched.
- (d) Debris creating or contributing to unsafe conditions shall be removed.
- (e) Low-density combustible fiberboard and unconventional interior finishes shall be removed.
- (f) Extraordinary weight above the training area shall be removed, or the area below it shall be rendered inaccessible.
- (g) An adequate ventilation opening(s) shall be made in the roof.
- (h) Utilities shall be disconnected.
- (i) Consideration shall be given to potential hazards of toxic weeds, insect hives, and vermin.
- (j) All forms of asbestos deemed hazardous to personnel shall be removed by an approved asbestos removal contractor.

2-2.11 Roof ventilation openings that are normally closed but can be opened in the event of emergency shall be permitted to be utilized. These can consist of precut panels or hinged covers.

2-2.12 Buildings that cannot be made safe as required by this chapter shall not be utilized for interior live fire training evolutions.

2-2.13 Adjacent buildings or property that might become involved shall be protected properly or removed.

2-2.14 Utility services adjacent to the live burn site shall be removed or protected.

2-2.15 Trees, brush, and surrounding vegetation that create a hazard to participants shall be removed. Combustible materials, other than those intended for the live fire training evolution, shall be removed or stored in a protected area to preclude accidental ignition.

2-2.16 Property adjacent to the training site that could be affected by the smoke from the live fire training evolution, such as railroads, airports, or heliports; and nursing homes, hospitals, or other similar facilities shall be identified, and the persons in charge shall be informed of the date and time of the evolution.

2-2.17 Streets or highways in the vicinity of the training site shall be surveyed for potential effects from live fire training evolutions. Appropriate safeguards shall be taken to eliminate any possible hazard to motorists. Such safeguards can include street closings, traffic rerouting, signs, and police traffic control.

2-2.18 Pedestrian traffic in the vicinity of the training site shall be kept clear of the operations area of the live burn. Fire lines shall be established for this purpose.

2-2.19 Awareness of weather conditions, wind velocity, and wind direction shall be maintained. In all cases, a final check shall be made for possible changes in weather conditions immediately before actual ignition.

2-2.20 The water supply for any individual live fire training evolution shall be assessed carefully based on the extent of the evolutions to be performed. Consideration shall be given to

the proper control and extinguishment of the fire and the provision of necessary backup lines to protect personnel.

2-2.21 The minimum water supply and delivery for live fire training evolutions shall meet the criteria identified in NFPA 1231, *Standard on Water Supplies for Suburban and Rural Fire Fighting*.

2-2.22 A minimum reserve of additional water in the amount of 50 percent of the fire flow demand in 2-2.21 shall be available to handle exposure protection or unforeseen situations.

2-2.23* Separate sources shall be utilized for the supply of attack lines and backup lines in order to preclude the loss of both water supply sources at the same time.

Exception: A single source shall be sufficient at a training center facility where the water system has been engineered to provide adequate volume for the evolutions conducted and a backup power source or backup pumps, or both, are in place to ensure an uninterrupted supply in the event of a power failure or malfunction.

2-2.24 Adequate areas for the staging, operating, and parking of fire apparatus that are used in the live fire training evolution shall be designated.

2-2.25 An area for parking fire apparatus and vehicles that are not a part of the evolution shall be designated so as not to interfere with fireground operations. Consideration shall be given to locating this area in order to facilitate prompt response of apparatus in the event of an emergency.

2-2.26 Where required or necessary, parking areas for police vehicles or for the press shall be designated.

2-2.27 A parking area for an ambulance or an emergency medical services vehicle shall be designated. Consideration shall be given to locating this area to facilitate prompt response in the event of a personal injury to participants in the evolution.

2-2.28 Consideration shall be given to the designation and layout of ingress/egress routes in order to ensure their availability in the event of an emergency.

2-2.29 Prior to conducting actual live fire training evolutions, a preburn briefing session shall be conducted for all participants. All facets of each evolution to be conducted shall be discussed, and assignments shall be made for all crews participating in the training session. The location of simulated victims shall not be required to be disclosed, provided that the possibility of victims is discussed during the briefing.

2-2.30 A preburn plan shall be prepared and shall be utilized during the preburn briefing sessions. All features of the training areas and structure shall be indicated on the plan.

2-2.31 Prior to conducting any live fire training, all participants shall have a knowledge of and familiarity with the layout of the building in order to facilitate any necessary evacuation of the building. Prior to conducting any live fire training in the structure, all participants in the evolution shall be required to conduct a walk-through of the structure.

2-2.32 All spectators shall be restricted to an area outside the operations area perimeter established by the safety officer.

2-2.33 Appropriate control measures such as ropes, signs, and fire line markings shall be posted to indicate the perimeter of the operations area.

2-2.34 Visitors who are allowed to observe operations and who are allowed within the operations area perimeter shall be escorted at all times and shall be equipped with and shall properly wear complete protective clothing in accordance with 2-4.17 through 2-4.22.

2-2.35 All possible sources of ignition, other than those that are under the direct supervision of the person responsible for the start of the training fire, shall be removed from the operations area.

2-3 Fuel Materials.

2-3.1 The fuels that are utilized in live fire training evolutions shall have known burning characteristics that are as controllable as possible. Unidentified materials, such as debris found in or around the structure that could burn in unanticipated ways, react violently, or create environmental or health hazards, shall not be permitted to be used.

2-3.2* Fuel materials shall be used only in the amounts necessary to create the desired fire size. Pressure-treated wood, rubber, and plastic, and straw or hay treated with pesticides or harmful chemicals shall not be permitted to be used. The fuel load shall be limited to avoid conditions that could cause an uncontrolled flashover or backdraft.

2-3.3 The use of flammable or combustible liquids, as defined in NFPA 30, *Flammable and Combustible Liquids Code*, shall not be permitted for use in live fire training evolutions in acquired structures.

2-3.4* The instructor-in-charge shall assess the selected fire room environment for factors that can affect the growth, development, and spread of fire.

2-3.5* The instructor-in-charge, as a minimum, shall document fuel loading including furnishings; wall and floor coverings and ceiling materials; type of construction of the structure including type of roof and combustible void spaces; and dimensions of the room.

2-3.6* The training exercise shall be stopped immediately when the instructor-in-charge determines through ongoing assessment that the combustible nature of the environment represents a potential hazard. The exercise shall continue only when the appropriate actions have been taken to reduce the hazard.

2-4 Safety.

2-4.1 A safety officer shall be appointed for all live fire training evolutions.

2-4.2* The safety officer shall have the authority, regardless of rank, to intervene and control any aspect of the operations when, in his or her judgment, a potential or actual danger, accident, or unsafe condition exists.

2-4.3 The responsibilities of the safety officer shall include, but shall not be limited to the following:

- (a) The prevention of unsafe acts
- (b) The elimination of unsafe conditions

2-4.4 The safety officer shall provide for the safety of all persons on the scene including students, instructors, visitors, and spectators.

2-4.5 The safety officer shall not be assigned other duties that interfere with safety responsibilities.

2-4.6 Sufficient backup lines shall be provided to ensure adequate protection for personnel on training attack lines.

2-4.7* The instructor-in-charge of the live fire training evolutions shall determine, prior to each specific evolution, the number of training attack lines and backup lines that are necessary. Each hoseline shall be capable of delivering a minimum of 95 gpm (360 Lpm). The instructor-in-charge then shall:

- (a) Assign one instructor to each functional crew, which shall not exceed five students
- (b) Assign one instructor to each backup line
- (c) Assign sufficient additional personnel to backup lines to provide mobility
- (d) Assign one additional instructor for each additional functional assignment

2-4.8* Additional safety personnel, as deemed necessary by the safety officer, shall be located strategically within the structure to react to any unplanned or threatening situation or condition.

2-4.9 A method of fireground communications shall be established to enable coordination among the incident commander, the interior and exterior sectors, the safety officer, and external requests for assistance.

2-4.10* A building evacuation plan shall be established and an evacuation signal shall be demonstrated to all participants in an interior live fire training evolution.

2-4.11 Emergency medical services shall be available on site to handle injuries. Written reports shall be filled out and submitted on all injuries and on all medical aid rendered.

2-4.12 A thorough search of the structure shall be conducted to ensure that no unauthorized persons, animals, or objects are in the building immediately prior to ignition.

2-4.13 No person(s) shall play the role of a victim inside the building.

2-4.14 Only one fire at a time shall be permitted within an acquired structure.

2-4.15 Fires shall not be located in any designated exit paths.

2-4.16 The training session shall be curtailed, postponed, or canceled, as necessary, to reduce the risk of injury or illness caused by extreme weather conditions.

2-4.17 Each participant shall be equipped with full protective clothing and self-contained breathing apparatus (SCBA). All participants shall be inspected by the safety officer prior to entry into a live fire training evolution to ensure that the protective clothing and SCBA are being worn properly and are in serviceable condition.

2-4.18 Protective coats, trousers, hoods, footwear, helmets, and gloves shall meet the requirements of NFPA 1971, *Standard on Protective Ensemble for Structural Fire Fighting*.

2-4.19 Self-contained breathing apparatus (SCBA) shall meet the requirements of NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus for Fire Fighters*.

2-4.20* Where station or work uniforms are worn by any participant, the station or work uniform shall meet the requirements of NFPA 1975, *Standard on Station/Work Uniforms for Fire Fighters*.

2-4.21 Personal alarm devices shall meet the requirements of NFPA 1982, *Standard on Personal Alert Safety Systems (PASS) for Fire Fighters*.

2-4.22 All students, instructors, safety personnel, and other personnel shall wear properly all protective clothing and equipment specified in this chapter whenever they are involved in any evolution or fire suppression operation during the live fire training evolution.

2-4.23* All students, instructors, safety personnel, and other personnel participating in any evolution or operation of fire suppression during the live fire training evolution shall breathe from a SCBA air supply whenever operating under one or more of the following conditions:

- (a) In an atmosphere that is oxygen deficient or contaminated by products of combustion, or both
- (b) In an atmosphere that is suspected of being oxygen deficient or contaminated by products of combustion, or both
- (c) In any atmosphere that can become oxygen deficient or contaminated, or both
- (d) Below ground level

2-4.24 One person shall be designated as the "ignition officer" to control the materials being burned. The ignition officer shall not be a student.

2-4.25 The ignition officer shall wear full protective clothing, including self-contained breathing apparatus (SCBA), as required in 2-4.17 through 2-4.22, when performing this function. A charged hoseline shall accompany the ignition officer when igniting any fire.

2-4.26* The decision to ignite the training fire shall be made by the instructor-in-charge in coordination with the safety officer. The fire shall be ignited by the ignition officer in the presence of and under the direct supervision of the safety officer.

2-5 Instructors.

2-5.1 All instructors shall be deemed qualified to deliver fire fighter training by the authority having jurisdiction.

2-5.2* The participating student-to-instructor ratio shall not be greater than 5 to 1.

2-5.3 Other factors such as extreme temperatures, large groups, and classes of long duration shall be taken into consideration, and additional instructors shall be designated as deemed necessary to ensure proper levels of safety.

2-5.4 The instructor-in-charge shall be responsible for full compliance with this standard.

2-5.5 Prior to the ignition of any fire, instructors shall ensure that all protective clothing and equipment specified in this chapter are being worn properly.

2-5.6 Instructors shall take a head count when entering and exiting the building during an actual attack evolution conducted in accordance with this standard. Instructors shall monitor and supervise all assigned students closely during the live fire training evolution.

2-5.7* The instructor-in-charge shall consider the circumstances of each training session and make suitable provisions for the rest and rehabilitation of members operating at the scene. These considerations shall include medical evaluation

and treatment, food and fluid replenishment, and relief from climate conditions, in accordance with the circumstances of the training session.

Chapter 3 Gas-Fired Training Center Buildings

3-1 Student Prerequisites.

3-1.1* In order to ensure safe operations during a live fire training exercise involving gas-fired training center buildings, all participating students shall have achieved a minimum level of basic training.

3-1.2 Prior to being permitted to participate in live fire training evolutions, the student shall have received training to meet the performance objectives for Fire Fighter I of the following sections of NFPA 1001, *Standard for Fire Fighter Professional Qualifications*:

Section 3-3	Safety
Section 3-5	Fire Behavior
Section 3-6	Portable Extinguishers
Section 3-7	Personal Protective Equipment
Section 3-11	Ladders
Section 3-12	Fire Hose, Appliances and Streams
Section 3-16	Overhaul
Section 3-19	Water Supply

3-1.3* Students participating in a live fire training evolution who have received the required minimum basic training from other than the authority having jurisdiction shall not be permitted to participate in any live fire training evolution without presenting prior written evidence of having successfully completed the prescribed minimum training to the levels specified in 3-1.2.

3-2 Structures and Facilities.

3-2.1 Strict safety practices shall be applied to all structures selected for live fire training evolutions. These practices vary greatly in the degree of application where comparing burn building structures to acquired structures. By nature, burn buildings have been designed specifically for the purpose of repeated live fire training evolutions and include safeguards that become unacceptably hazardous only through misuse or improper maintenance.

3-2.2* Training center burn buildings shall be inspected visually for damage prior to live fire training evolutions. Damage shall be documented. The structural integrity of the building shall be evaluated and documented periodically, but at least annually. Where the burn building damage is severe enough to affect the safety of the students, training shall not be permitted.

3-2.3 All doors, windows and window shutters, roof scuttles and automatic ventilators, mechanical equipment, lighting, manual or automatic sprinklers, and standpipes necessary for the live fire training evolution shall be checked and operated, where appropriate, prior to any live fire training evolution to ensure they operate correctly.

3-2.4* All safety devices, such as thermometers, oxygen and toxic and combustible gas monitors, evacuation alarms, and emergency shutdown switches, shall be checked prior to any live fire training evolutions to ensure they operate correctly.

3-2.5* For burn buildings that contain gas-fueled training systems, the instructors shall run the system prior to exposing stu-

dents to live flames in order to ensure the correct operation of devices such as the gas valves, flame safeguard units, agent sensors, combustion fans, and ventilation fans.

3-2.6 Training center burn buildings shall be left in a safe condition upon completion of live fire training evolutions. Debris hindering the access or egress of fire fighters shall be removed prior to the beginning of the next training exercises.

3-2.7 Pedestrian traffic in the vicinity of the training site shall be kept clear of the operations area of the live burn. Fire lines shall be established for this purpose.

3-2.8 Awareness of weather conditions, wind velocity, and wind direction shall be maintained. In all cases, a final check shall be made for possible changes in weather conditions immediately before actual ignition.

3-2.9 The water supply for any individual live fire training evolution shall be assessed carefully based on the extent of the evolutions to be performed. Consideration shall be given to the proper control and extinguishment of the fire and the provision of necessary backup lines to protect personnel.

3-2.10 The minimum water supply and delivery for the live fire training evolutions shall meet the criteria identified in NFPA 1231, *Standard on Water Supplies for Suburban and Rural Fire Fighting*.

3-2.11 A minimum reserve of additional water in the amount of 50 percent of the fire flow demand in 3-2.10 shall be available to handle exposure protection or unforeseen situations.

3-2.12* Separate sources shall be utilized for the supply of attack lines and backup lines in order to preclude the loss of both water supply sources at the same time.

Exception: A single source shall be sufficient at a training center facility where the water system has been engineered to provide adequate volume for the evolutions conducted and a backup power source or backup pumps, or both, are in place to ensure an uninterrupted supply in the event of a power failure or malfunction.

3-2.13 Adequate areas for the staging, operating, and parking of fire apparatus that are used in the live fire training evolution shall be designated.

3-2.14 An area for parking fire apparatus and vehicles that are not a part of the evolution shall be designated so as not to interfere with fireground operations. Consideration shall be given to locating this area to facilitate prompt response of apparatus in the event of an emergency.

3-2.15 Where required or necessary, parking areas for police vehicles or for the press shall be designated.

3-2.16 A parking area for an ambulance or an emergency medical services vehicle shall be designated. Consideration shall be given to locating this area to facilitate prompt response in the event of a personal injury to participants in the evolution.

3-2.17 Consideration shall be given to the designation and layout of ingress/egress routes in order to ensure their availability in the event of an emergency.

3-2.18 Prior to conducting actual live fire training evolutions, a preburn briefing session shall be conducted for all participants. All facets of each evolution to be conducted shall be discussed, and assignments shall be made for all crews participating in the training session. The location of simulated

victims shall not be required to be disclosed, provided that the possibility of victims is discussed during the preburn briefing.

3-2.19 A preburn plan shall be prepared and shall be utilized during the preburn briefing sessions. All features of the training areas and structure shall be indicated on the plan.

3-2.20 Prior to conducting any live fire training, all participants shall have a knowledge of and familiarity with the layout of the building in order to facilitate any necessary evacuation of the building. Prior to conducting any live fire training in the structure, all participants in the evolution shall be required to conduct a walk-through of the structure.

3-2.21 All spectators shall be restricted to an area outside the operations area perimeter established by the safety officer.

3-2.22 Appropriate control measures such as ropes, signs, and fire line markings shall be posted to indicate the perimeter of the operations area.

3-2.23 Visitors who are allowed to observe operations and who are allowed within the operations area perimeter shall be escorted at all times and shall be equipped with and shall properly wear complete protective clothing in accordance with 3-4.17 through 3-4.22.

3-2.24 All possible sources of ignition, other than those that are under the direct supervision of the person responsible for the start of the training fire, shall be removed from the operations area.

3-2.25 There shall be ample room provided around all props such that there is space for all attack lines as well as backup lines to operate freely.

3-3 Fuel Materials.

3-3.1 The fuels that are utilized in live fire training evolutions shall have known burning characteristics that are as controllable as possible. Unidentified materials, such as debris found in or around the structure that could burn in unanticipated ways, react violently, or create environmental or health hazards, shall not be permitted to be used.

3-3.2* The use of flammable gas, such as propane and natural gas, shall be permitted only in burn buildings specifically designed for their use, as defined in NFPA 1402, *Guide to Building Fire Service Training Centers*. Liquefied versions of these gases shall not be permitted inside the burn building.

3-3.3* The instructor-in-charge shall assess the selected fire room environment for factors that can affect the growth, development, and spread of fire.

3-3.4* The training exercise shall be stopped immediately when the instructor-in-charge determines through ongoing assessment that the combustible nature of the environment represents a potential hazard. The exercise shall continue only when the appropriate actions have been taken to reduce the hazard.

3-4 Safety.

3-4.1 A safety officer shall be appointed for all live fire training evolutions.

3-4.2* The safety officer shall have the authority, regardless of rank, to intervene and control any aspect of the operations when, in his or her judgment, a potential or actual danger, accident, or unsafe condition exists.

3-4.3 The responsibilities of the safety officer shall include, but shall not be limited to the following:

- (a) The prevention of unsafe acts
- (b) The elimination of unsafe conditions

3-4.4 The safety officer shall provide for the safety of all persons on the scene including students, instructors, visitors, and spectators.

3-4.5 The safety officer shall not be assigned other duties that interfere with safety responsibilities.

3-4.6 The safety officer shall be knowledgeable in the operation and location of safety features available within the burn building, such as emergency shutoff switches, gas shutoff valves, and evacuation alarms.

3-4.7 Sufficient backup lines shall be provided to ensure adequate protection for personnel on training attack lines.

3-4.8* The instructor-in-charge of the live fire training evolutions shall determine, prior to each specific evolution, the number of training attack lines and backup lines that are necessary. Each hoseline shall be capable of delivering a minimum of 95 gpm (360 Lpm). The instructor-in-charge then shall assign the following:

- (a) One instructor to each functional crew, which shall not exceed five students
- (b) One instructor to each backup line
- (c) Sufficient additional personnel to backup lines to provide mobility
- (d) One additional instructor for each additional functional assignment

3-4.9* Additional safety personnel, as deemed necessary by the safety officer, shall be located strategically within the structure to react to any unplanned or threatening situation or condition.

3-4.10 A method of fireground communications shall be established to enable coordination among the incident commander, the interior and exterior sectors, the safety officer, and external requests for assistance.

3-4.11* A building evacuation plan shall be established and an evacuation signal shall be demonstrated to all participants in an interior live fire training evolution.

3-4.12 Emergency medical services shall be available on site to handle injuries. Written reports shall be filled out and submitted on all injuries and on all medical aid rendered.

3-4.13 A thorough search of the structure shall be conducted to ensure that no unauthorized persons, animals, or objects are in the building immediately prior to ignition.

3-4.14 No person(s) shall play the role of a victim inside the building.

3-4.15 Fires shall not be located in any designated exit paths.

3-4.16 The training session shall be curtailed, postponed, or canceled, as necessary, to reduce the risk of injury or illness caused by extreme weather conditions.

3-4.17 Each participant shall be equipped with full protective clothing and self-contained breathing apparatus (SCBA). All participants shall be inspected by the safety officer prior to entry into a live fire training evolution to ensure that the pro-

ective clothing and SCBA are being worn properly and are in serviceable condition.

3-4.18 Protective coats, trousers, hoods, footwear, helmets, and gloves shall meet the requirements of NFPA 1971, *Standard on Protective Ensemble for Structural Fire Fighting*.

3-4.19 Self-contained breathing apparatus (SCBA) shall meet the requirements of NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus for Fire Fighters*.

3-4.20* Where station or work uniforms are worn by any participant, the station or work uniform shall meet the requirements of NFPA 1975, *Standard on Station/Work Uniforms for Fire Fighters*.

3-4.21 Personal alarm devices shall meet the requirements of NFPA 1982, *Standard on Personal Alert Safety Systems (PASS) for Fire Fighters*.

3-4.22 All students, instructors, safety personnel, and other personnel shall wear properly all protective clothing and equipment specified in this chapter whenever they are involved in any evolution or fire suppression operation during the live fire training evolution.

3-4.23* All students, instructors, safety personnel, and other personnel participating in any evolution or operation of fire suppression during the live fire training evolution shall breathe from a SCBA air supply whenever operating under one or more of the following conditions:

(a) In an atmosphere that is oxygen deficient or contaminated by products of combustion, or both

(b) In an atmosphere that is suspected of being oxygen deficient or contaminated by products of combustion, or both

(c) In any atmosphere that can become oxygen deficient or contaminated, or both

(d) Below ground level

3-4.24* The decision to ignite a training fire shall be made by the instructor-in-charge in coordination with the safety officer. Fires shall not be ignited without an instructor visually confirming that the flame area is clear of personnel.

3-4.25 Flammable gas fires shall not be ignited manually.

3-5 Instructors.

3-5.1 All instructors shall be deemed qualified to deliver fire fighter training by the authority having jurisdiction.

3-5.2* The participating student-to-instructor ratio shall not be greater than 5 to 1.

3-5.3 Other factors such as extreme temperatures, large groups, and classes of long duration shall be taken into consideration, and additional instructors shall be designated as deemed necessary to ensure proper levels of safety.

3-5.4 The instructor-in-charge shall be responsible for full compliance with this standard.

3-5.5 Prior to the ignition of any fire, instructors shall ensure that all protective clothing and equipment specified in this chapter are being worn properly.

3-5.6 Instructors shall take a head count when entering and exiting the building during an actual attack evolution conducted in accordance with this standard. Instructors shall

monitor and supervise all assigned students closely during the live fire training evolution.

3-5.7* The instructor-in-charge shall consider the circumstances of each training session and make suitable provisions for the rest and rehabilitation of members operating at the scene. These considerations shall include medical evaluation and treatment, food and fluid replenishment, and relief from climate conditions, in accordance with the circumstances of the training session.

3-5.8 Instructors responsible for conducting live fire training evolutions with a gas-fueled training system shall be trained properly in the complete operation of the system. The training of instructors shall be performed by an individual authorized by the system manufacturer.

3-5.9 Where concurrent, multiple live fire training evolutions are being conducted in a specifically designed burn building, the identity of the instructor-in-charge of the evolutions shall be clear to all participants. It shall be this instructor's responsibility to coordinate overall burn building fireground activities to ensure proper levels of safety.

Chapter 4 Non-Gas-Fired Training Center Buildings

4-1 Student Prerequisites.

4-1.1* In order to ensure safe operations during a live fire training exercise involving non-gas-fired training center buildings, all participating students shall have achieved a minimum level of basic training.

4-1.2 Prior to being permitted to participate in live fire training evolutions, the student shall have received training to meet the performance objectives for Fire Fighter I of the following sections of NFPA 1001, *Standard for Fire Fighter Professional Qualifications*:

Section 3-3	Safety
Section 3-5	Fire Behavior
Section 3-6	Portable Extinguishers
Section 3-7	Personal Protective Equipment
Section 3-11	Ladders
Section 3-12	Fire Hose, Appliances and Streams
Section 3-16	Overhaul
Section 3-19	Water Supply

4-1.3* Students participating in a live fire training evolution who have received the required minimum basic training from other than the authority having jurisdiction shall not be permitted to participate in any live fire training evolution without presenting prior written evidence of having successfully completed the prescribed minimum training to the levels specified in 4-1.2.

4-2 Structures and Facilities.

4-2.1 Strict safety practices shall be applied to all structures selected for live fire training evolutions. These practices vary greatly in the degree of application where comparing burn building structures to acquired structures. By nature, burn buildings have been designed specifically for the purpose of repeated live fire training evolutions and include safeguards that become unacceptably hazardous only through misuse or improper maintenance.

4-2.2* Training center burn buildings shall be inspected visually for damage prior to live fire training evolutions. Damage

shall be documented. The structural integrity of the building shall be evaluated and documented periodically, but at least annually. Where the burn building damage is severe enough to affect the safety of the students, training shall not be permitted.

4-2.3 All doors, windows and window shutters, roof scuttles and automatic ventilators, mechanical equipment, lighting, manual or automatic sprinklers, and standpipes necessary for the live fire training evolution shall be checked and operated, where appropriate, prior to any live fire training evolution to ensure they operate correctly.

4-2.4* All safety devices, such as thermometers, oxygen and toxic and combustible gas monitors, evacuation alarms, and emergency shutdown switches, shall be checked prior to any live fire training evolutions to ensure they operate correctly.

4-2.5 Training center burn buildings shall be left in a safe condition upon completion of live fire training evolutions. Debris hindering the access or egress of fire fighters shall be removed prior to the beginning of the next training exercises.

4-2.6 In preparation for live fire training, an inspection of the structure shall be made to determine that the floors, walls, stairs, and other structural components are capable of withstanding the weight of contents, participants, and accumulated water.

4-2.7 Property adjacent to the training site that could be affected by the smoke from the live fire training evolution, such as railroads, airports, or heliports; and nursing homes, hospitals, or other similar facilities shall be identified, and the persons in charge shall be informed of the date and time of the evolution.

4-2.8 Streets or highways in the vicinity of the training site shall be surveyed for potential effects from live fire training evolutions. Appropriate safeguards shall be taken to eliminate any possible hazard to motorists. Such safeguards can include street closings, traffic rerouting, signs, and police traffic control.

4-2.9 Pedestrian traffic in the vicinity of the training site shall be kept clear of the operations area of the live burn. Fire lines shall be established for this purpose.

4-2.10 Awareness of weather conditions, wind velocity, and wind direction shall be maintained. In all cases, a final check shall be made for possible changes in weather conditions immediately before actual ignition.

4-2.11 The water supply for any individual live fire training evolution shall be assessed carefully based on the extent of the evolutions to be performed. Consideration shall be given to the proper control and extinguishment of the fire and the provision of necessary backup lines to protect personnel.

4-2.12 The minimum water supply and delivery for live fire training evolutions shall meet the criteria identified in NFPA 1231, *Standard on Water Supplies for Suburban and Rural Fire Fighting*.

4-2.13 A minimum reserve of additional water in the amount of 50 percent of the fire flow demand in 4-2.12 shall be available to handle exposure protection or unforeseen situations.

4-2.14* Separate sources shall be utilized for the supply of attack lines and backup lines in order to preclude the loss of both water supply sources at the same time.

Exception: A single source shall be sufficient at a training center facility where the water system has been engineered to provide adequate volume for the evolutions conducted and a backup power source or backup pumps, or both, are in place to ensure an uninterrupted supply in the event of a power failure or malfunction.

4-2.15 Adequate areas for the staging, operating, and parking of fire apparatus that are used in the live fire training evolution shall be designated.

4-2.16 An area for parking fire apparatus and vehicles that are not a part of the evolution shall be designated so as not to interfere with fireground operations. Consideration shall be given to locating this area in order to facilitate prompt response of apparatus in the event of an emergency.

4-2.17 Where required or necessary, parking areas for police vehicles or for the press shall be designated.

4-2.18 A parking area for an ambulance or an emergency medical services vehicle shall be designated. Consideration shall be given to locating this area to facilitate prompt response in the event of a personal injury to participants in the evolution.

4-2.19 Consideration shall be given to the designation and layout of ingress/egress routes in order to ensure their availability in the event of an emergency.

4-2.20 Prior to conducting actual live fire training evolutions, a preburn briefing session shall be conducted for all participants. All facets of each evolution to be conducted shall be discussed, and assignments shall be made for all crews participating in the training session. The location of simulated victims shall not be required to be disclosed, provided that the possibility of victims is discussed during the preburn briefing.

4-2.21 A preburn plan shall be prepared and shall be utilized during the preburn briefing sessions. All features of the training areas and structure shall be indicated on the plan.

4-2.22 Prior to conducting any live fire training, all participants shall have a knowledge of and familiarity with the layout of the building in order to facilitate any necessary evacuation of the building. Prior to conducting any live fire training in the structure, all participants in the evolution shall be required to conduct a walk-through of the structure.

4-2.23 All spectators shall be restricted to an area outside the operations area perimeter established by the safety officer.

4-2.24 Appropriate control measures such as ropes, signs, and fire line markings shall be posted to indicate the perimeter of the operations area.

4-2.25 Visitors who are allowed to observe operations and who are allowed within the operations area perimeter shall be escorted at all times and shall be equipped with and shall properly wear complete protective clothing in accordance with 4-4.17 through 4-4.22.

4-2.26 All possible sources of ignition, other than those that are under the direct supervision of the person responsible for the start of the training fire, shall be removed from the operations area.

4-3 Fuel Materials.

4-3.1 The fuels that are utilized in live fire training evolutions shall have known burning characteristics that are as controllable as possible. Unidentified materials, such as debris found in

or around the structure that could burn in unanticipated ways, react violently, or create environmental or health hazards, shall not be permitted to be used.

4-3.2* Fuel materials shall be used only in the amounts necessary to create the desired fire size. Pressure-treated wood, rubber, and plastic, and straw or hay treated with pesticides or harmful chemicals shall not be permitted to be used. The fuel load shall be limited to avoid conditions that could cause an uncontrolled flashover or backdraft.

4-3.3* The use of flammable or combustible liquids, as defined in NFPA 30, *Flammable and Combustible Liquids Code*, shall not be permitted for use in live fire training evolutions in structures.

Exception: Limited quantities of combustible liquid with a flash point above 100°F (38°C) shall be permitted to be used in a training center burn building that has been specifically engineered to accommodate this fuel.

4-3.4* The instructor-in-charge shall assess the selected fire room environment for factors that can affect the growth, development, and spread of the fire.

4-3.5* The instructor-in-charge, as a minimum, shall document fuel loading including furnishings; wall and floor coverings, and ceiling materials; type of construction of the structure including type of roof and combustible void spaces; and dimensions of room.

4-3.6* The training exercise shall be stopped immediately when the instructor-in-charge determines through ongoing assessment that the combustible nature of the environment represents a potential hazard. The exercise shall continue only when the appropriate actions have been taken to reduce the hazard.

4-4 Safety.

4-4.1 A safety officer shall be appointed for all live fire training evolutions.

4-4.2* The safety officer shall have the authority, regardless of rank, to intervene and control any aspect of the operations when, in his or her judgment, a potential or actual danger, accident, or unsafe condition exists.

4-4.3 The responsibilities of the safety officer shall include, but shall not be limited to the following:

- (a) The prevention of unsafe acts
- (b) The elimination of unsafe conditions

4-4.4 The safety officer shall provide for the safety of all persons on the scene including students, instructors, visitors, and spectators.

4-4.5 The safety officer shall not be assigned other duties that interfere with safety responsibilities.

4-4.6 The safety officer shall be knowledgeable in the operation and location of safety features available within the burn building, such as emergency shutoff switches, gas shutoff valves, and evacuation alarms.

4-4.7 Sufficient backup lines shall be provided to ensure adequate protection for personnel on training attack lines.

4-4.8* The instructor-in-charge of the live fire training evolutions shall determine, prior to each specific evolution, the number of training attack lines and backup lines that are necessary. Each hose line shall be capable of delivering a mini-

mum of 95 gpm (360 Lpm). The instructor-in-charge then shall assign the following:

- (a) One instructor to each functional crew, which shall not exceed five students
- (b) One instructor to each backup line
- (c) Sufficient additional personnel to backup lines to provide mobility
- (d) One additional instructor for each additional functional assignment

4-4.9* Additional safety personnel, as deemed necessary by the safety officer, shall be located strategically within the structure to react to any unplanned or threatening situation or condition.

4-4.10 A method of fireground communications shall be established to enable coordination among the incident commander, the interior and exterior sectors, the safety officer, and external requests for assistance.

4-4.11* A building evacuation plan shall be established and an evacuation signal shall be demonstrated to all participants in an interior live fire training evolution.

4-4.12 Emergency medical services shall be available on site to handle injuries. Written reports shall be filled out and submitted on all injuries and on all medical aid rendered.

4-4.13 A thorough search of the structure shall be conducted to ensure that no unauthorized persons, animals, or objects are in the building immediately prior to ignition.

4-4.14 No person(s) shall play the role of a victim inside the building.

4-4.15 Fires shall not be located in any designated exit paths.

4-4.16 The training session shall be curtailed, postponed, or canceled, as necessary, to reduce the risk of injury or illness caused by extreme weather conditions.

4-4.17 Each participant shall be equipped with full protective clothing and self-contained breathing apparatus (SCBA). All participants shall be inspected by the safety officer prior to entry into a live fire training evolution to ensure that the protective clothing and SCBA are being worn properly and are in serviceable condition.

4-4.18 Protective coats, trousers, hoods, footwear, helmets, and gloves shall meet the requirements of NFPA 1971, *Standard on Protective Ensemble for Structural Fire Fighting*.

4-4.19 Self-contained breathing apparatus (SCBA) shall meet the requirements of NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus for Fire Fighters*.

4-4.20* Where station or work uniforms are worn by any participant, the station or work uniform shall meet the requirements of NFPA 1975, *Standard on Station/Work Uniforms for Fire Fighters*.

4-4.21 Personal alarm devices shall meet the requirements of NFPA 1982, *Standard on Personal Alert Safety Systems (PASS) for Fire Fighters*.

4-4.22 All students, instructors, safety personnel, and other personnel shall wear properly all protective clothing and equipment specified in this chapter whenever they are involved in any evolution or fire suppression operation during the live fire training evolution.

4-4.23* All students, instructors, safety personnel, and other personnel participating in any evolution or operation of fire suppression during the live fire training evolution shall breathe from a SCBA air supply whenever operating under one or more of the following conditions:

- (a) In an atmosphere that is oxygen deficient or contaminated by products of combustion, or both
- (b) In an atmosphere that is suspected of being oxygen deficient or contaminated by products of combustion, or both
- (c) In any atmosphere that can become oxygen deficient or contaminated, or both
- (d) Below ground level

4-4.24 One person shall be designated as the “ignition officer” to control the materials being burned. The ignition officer shall not be a student.

4-4.25 The ignition officer shall wear full protective clothing, including self-contained breathing apparatus (SCBA), as required in 4-4.17 through 4-4.22, when performing this function. A charged hoseline shall accompany the ignition officer when igniting any fire.

4-4.26* The decision to ignite the training fire shall be made by the instructor-in-charge in coordination with the safety officer. The fire shall be ignited by the ignition officer in the presence of and under the direct supervision of the safety officer.

4-5 Instructors.

4-5.1 All instructors shall be deemed qualified to deliver fire fighter training by the authority having jurisdiction.

4-5.2* The participating student-to-instructor ratio shall not be greater than 5 to 1.

4-5.3 Other factors such as extreme temperatures, large groups, and classes of long-duration shall be taken into consideration, and additional instructors shall be designated as deemed necessary to ensure proper levels of safety.

4-5.4 The instructor-in-charge shall be responsible for full compliance with this standard.

4-5.5 Prior to the ignition of any fire, instructors shall ensure that all protective clothing and equipment specified in this chapter are being worn properly.

4-5.6 Instructors shall take a head count when entering and exiting the building during an actual attack evolution conducted in accordance with this standard. Instructors shall monitor and supervise all assigned students closely during the live fire training evolution.

4-5.7* The instructor-in-charge shall consider the circumstances of each training session and make suitable provisions for the rest and rehabilitation of members operating at the scene. These considerations shall include medical evaluation and treatment, food and fluid replenishment, and relief from climate conditions, in accordance with the circumstances of the training session.

4-5.8 Where concurrent, multiple live fire training evolutions are being conducted in a specifically designed burn building, the identity of the instructor in charge of the evolutions shall be clear to all participants. It shall be this instructor's responsibility to coordinate overall burn building fireground activities to ensure proper levels of safety.

Chapter 5 Exterior Props

5-1 Student Prerequisites.

5-1.1* In order to ensure safe operations during a live fire training exercise involving exterior props, all participating students shall have achieved a minimum level of basic training.

5-1.2 Prior to being permitted to participate in live fire training evolutions, the student shall have received training to meet the performance objectives for Fire Fighter I of the following sections of NFPA 1001, *Standard for Fire Fighter Professional Qualifications*:

Section 3-3	Safety
Section 3-5	Fire Behavior
Section 3-6	Portable Extinguishers
Section 3-7	Personal Protective Equipment
Section 3-11	Ladders
Section 3-12	Fire Hose, Appliances and Streams
Section 3-19	Water Supply

5-1.3* Students participating in a live fire training evolution who have received the required minimum basic training from other than the authority having jurisdiction shall not be permitted to participate in any live fire training evolution without presenting prior written evidence of having successfully completed the prescribed minimum training to the levels specified in 5-1.2.

5-2 Structures and Facilities.

5-2.1* Strict safety practices shall be applied to all exterior props selected for live fire training evolutions.

5-2.2 For outside training, care shall be taken to select areas that limit the hazards to both personal safety and the environment. The training site shall be flat and open without obstructions that can interfere with fire-fighting operations.

5-2.3 Where using live training fires outside, the ground cover shall be such that it does not contribute to the fire. The ground cover shall be impervious and of such topography that the runoff from live fire does not enter municipal, private, or public waters or other sensitive areas.

5-2.4 Exterior props shall be inspected visually for damage prior to live fire training evolutions. Damage shall be documented. The structural integrity of the props shall be evaluated and documented periodically, but at least annually.

5-2.5 All safety devices, such as thermometers, oxygen and toxic and combustible gas monitors, evacuation alarms, and emergency shutdown switches, shall be checked prior to any live fire training evolutions to ensure they operate correctly.

5-2.6 Exterior props shall be left in a safe condition upon completion of live fire training evolutions. Debris hindering the access of fire fighters shall be removed prior to the beginning of the next training exercise.

5-2.7 All appropriate and required permits to conduct live fire training evolutions shall be obtained.

5-2.8 The permits specified in this chapter shall be provided to outside, contract, or other separate training agencies by the authority having jurisdiction upon the request of those agencies.

5-2.9 Adjacent buildings or property that might become involved shall be protected properly or removed.

5-2.10 Utility services adjacent to the live burn site shall be removed or protected.

5-2.11 Trees, brush, and surrounding vegetation that create a hazard to participants shall be removed. Combustible materials, other than those intended for the live fire training evolution, shall be removed or stored in a protected area to preclude accidental ignition.

5-2.12 Property adjacent to the training site that could be affected by the smoke from the live fire training evolution, such as railroads, airports, or heliports; and nursing homes, hospitals, or other similar facilities shall be identified, and the persons in charge shall be informed of the date and time of the evolution.

5-2.13 Streets or highways in the vicinity of the training site shall be surveyed for potential effects from live fire training evolutions. Appropriate safeguards shall be taken to eliminate any possible hazard to motorists. Such safeguards can include street closings, traffic rerouting, signs, and police traffic control.

5-2.14 Pedestrian traffic in the vicinity of the training site shall be kept clear of the operations area of the live burn. Fire lines shall be established for this purpose.

5-2.15 Awareness of weather conditions, wind velocity, and wind direction shall be maintained. In all cases, a final check shall be made for possible changes in weather conditions immediately before actual ignition.

5-2.16 The water supply for any individual live fire training evolution shall be assessed carefully based on the extent of the evolution to be performed. Consideration shall be given to the proper control and extinguishment of the fire and the provision of necessary backup lines to protect personnel.

5-2.17 The minimum water supply and delivery for the live fire training evolutions shall meet the criteria identified in NFPA 1231, *Standard on Water Supplies for Suburban and Rural Fire Fighting*.

5-2.18 A minimum reserve of additional water in the amount of 50 percent of the fire flow demand in 5-2.17 shall be available to handle exposure protection or unforeseen situations.

5-2.19* Separate sources shall be utilized for the supply of attack lines and backup lines in order to preclude the loss of both water supply sources at the same time.

Exception: A single source shall be sufficient at a training center facility where the water system has been engineered to provide adequate volume for the evolutions conducted and a backup power source or backup pumps, or both, are in place to ensure an uninterrupted supply in the event of a power failure or malfunction.

5-2.20 Adequate areas for the staging, operating, and parking of fire apparatus that are used in the live fire training evolution shall be designated.

5-2.21 An area for parking fire apparatus and vehicles that are not a part of the evolution shall be designated so as not to interfere with fireground operations. Consideration shall be given to locating this area in order to facilitate prompt response of apparatus in the event of an emergency.

5-2.22 Where required or necessary, parking areas for police vehicles or for the press shall be designated.

5-2.23 A parking area for an ambulance or an emergency medical services vehicle shall be designated. Consideration

shall be given to locating this area to facilitate prompt response in the event of a personal injury to participants in the evolution.

5-2.24 Consideration shall be given to the designation and layout of ingress/egress routes in order to ensure their availability in the event of an emergency.

5-2.25 Prior to conducting actual live fire training evolutions, a preburn briefing session shall be conducted for all participants. All facets of each evolution to be conducted shall be discussed, and assignments shall be made for all crews participating in the training session. The location of simulated victims shall not be required to be disclosed, provided that the possibility of victims is discussed in the preburn briefing.

5-2.26 A preburn plan shall be prepared and shall be utilized during the preburn briefing sessions. All features of the training areas and structure shall be indicated on the plan.

5-2.27 Prior to conducting any live fire training, all participants shall have a knowledge of and familiarity with the props or props being used for the evolution.

5-2.28 All spectators shall be restricted to an area outside the operations area perimeter established by the safety officer.

5-2.29 Appropriate control measures such as ropes, signs, and fire line markings shall be posted to indicate the perimeter of the operations area.

5-2.30 Visitors who are allowed to observe operations and who are allowed within the operations area perimeter shall be escorted at all times and shall be equipped with and shall properly wear complete protective clothing in accordance with 5-4.15 through 5-4.20.

5-2.31 All possible sources of ignition, other than those that are under the direct supervision of the person responsible for the start of the training fire, shall be removed from the operations area.

5-2.32 There shall be ample room provided around all props so that there is space for all attack lines as well as backup lines to operate freely.

5-3 Fuel Materials.

5-3.1 The fuels that are utilized in live fire training evolutions shall have known burning characteristics that are as controllable as possible. Unidentified materials, such as debris found in or around the site that could burn in unanticipated ways, react violently, or create environmental or health hazards, shall not be permitted to be used.

5-3.2* Fuel materials shall be used only in the amounts necessary to create the desired fire size. Pressure-treated wood, rubber, and plastic, and straw or hay treated with pesticides or harmful chemicals shall not be permitted to be used.

5-3.3* The instructor-in-charge shall assess the selected fire room environment for factors that can affect the growth, development, and spread of the fire.

5-3.4* The training exercise shall be stopped immediately when the instructor-in-charge determines through ongoing assessment that the combustible nature of the environment represents a potential hazard. The exercise shall continue only when the appropriate actions have been taken to reduce the hazard.

5-3.5 Props used for outside live fire training shall be designed specifically for the evolution to be performed.

5-3.6* All props that use pressure to move fuel to the fire shall be equipped with remote fuel shutoffs. The remote fuel shutoff shall be within site of the prop, and the entire field of attack for the prop, but shall be outside of the safety perimeter. During the entire time the prop is in use, the remote shutoff shall be continuously attended by safety personnel trained in its operation.

5-3.7 Liquefied petroleum gas props shall be equipped with all safety features as described in NFPA 58, *Standard for the Storage and Handling of Liquefied Petroleum Gases*, and NFPA 59, *Standard for the Storage and Handling of Liquefied Petroleum Gases at Utility Gas Plants*. Where the evolution involves the failure of a safety feature, the failed part shall be located downstream from the properly functioning safety feature.

5-3.8 Measures shall be taken where using flammable or combustible liquids to prevent runoff from contaminating the surrounding area. There shall be oil separators for cleaning the runoff water.

5-3.9* Vehicles used as props for live fire training shall have all fluid reservoirs, tanks, shock absorbers, drive shafts, and other gas-filled closed containers removed, vented, or drained prior to any ignition.

5-3.10 For flammable metal fires, there shall be a sufficient quantity of the proper extinguishing agent available so that all attack crews have an adequate supply as well as a 150 percent reserve for the use of the backup crews.

5-4 Safety.

5-4.1 A safety officer shall be appointed for all live fire training evolutions.

5-4.2* The safety officer shall have the authority, regardless of rank, to intervene and control any aspect of the operations when, in his or her judgment, a potential or actual danger, accident, or unsafe condition exists.

5-4.3 The responsibilities of the safety officer shall include, but shall not be limited to the following:

- (a) The prevention of unsafe acts
- (b) The elimination of unsafe conditions

5-4.4 The safety officer shall provide for the safety of all persons on the scene including students, instructors, visitors, and spectators.

5-4.5 The safety officer shall not be assigned other duties that interfere with safety responsibilities.

5-4.6 Sufficient backup lines shall be provided to ensure adequate protection for personnel on training attack lines.

5-4.7* The instructor-in-charge of the live fire training evolutions shall determine, prior to each specific evolution, the number of training attack lines and backup lines that are necessary. Each hoseline shall be capable of delivering a minimum of 95 gpm (360 Lpm). The instructor-in-charge then shall assign the following:

- (a) One instructor to each functional crew, which shall not exceed five students
- (b) One instructor to each backup line
- (c) Sufficient additional personnel to backup lines to provide mobility

(d) One additional instructor for each additional functional assignment

(e) One safety person to each manually activated safety station

5-4.8* Additional safety personnel, as deemed necessary by the safety officer, shall be located strategically within the area to react to any unplanned or threatening situation or condition.

5-4.9 A method of fireground communications shall be established to enable coordination among the incident commander, the interior and exterior sectors, the safety officer, and external requests for assistance.

5-4.10 Emergency medical services shall be available on site to handle injuries. Written reports shall be filled out and submitted on all injuries and on all medical aid rendered.

5-4.11 One person shall be designated to control the materials being burned and to ignite the training fire in the presence of and under the direct supervision of a safety officer. This person shall not be a student and shall wear full protective clothing including self-contained breathing apparatus (SCBA) as required in 5-4.15 through 5-4.20 of this standard. The decision to ignite the training fire shall be made by the instructor in charge, in coordination with the safety officer.

5-4.12 No person(s) shall play the role of a victim inside the building.

5-4.13 Fires shall not be located in any designated exit paths.

5-4.14 The training session shall be curtailed, postponed, or canceled, as necessary, to reduce the risk of injury or illness caused by extreme weather conditions.

5-4.15 Each participant shall be equipped with full protective clothing and self-contained breathing apparatus (SCBA). All participants shall be inspected by the safety officer prior to entry into a live fire training evolution to ensure that the protective clothing and SCBA are being worn properly and are in serviceable condition.

5-4.16 Protective coats, trousers, hoods, footwear, helmets, and gloves shall meet the requirements of NFPA 1971, *Standard on Protective Ensemble for Structural Fire Fighting*.

Exception: For outside fires, those persons who do not engage in or are not exposed to the hazards of structural fire fighting shall be permitted to use helmets that meet federal OSHA requirements.

5-4.17 Self-contained breathing apparatus (SCBA) shall meet the requirements of NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus for Fire Fighters*.

5-4.18* Where station or work uniforms are worn by any participant, the station or work uniform shall meet the requirements of NFPA 1975, *Standard on Station/Work Uniforms for Fire Fighters*.

5-4.19 Personal alarm devices shall meet the requirements of NFPA 1982, *Standard on Personal Alert Safety Systems (PASS) for Fire Fighters*.

5-4.20 All students, instructors, safety personnel, and other personnel shall wear properly all protective clothing and equipment specified in this chapter whenever they are involved in any evolution or fire suppression operation during the live fire training evolution.

5-4.21* All students, instructors, safety personnel, and other personnel participating in any evolution or operation of fire suppression during the live fire training evolution shall breathe from a SCBA air supply whenever operating under one or more of the following conditions:

- (a) In an atmosphere that is oxygen deficient or contaminated by products of combustion, or both
- (b) In an atmosphere that is suspected of being oxygen deficient or contaminated by products of combustion, or both
- (c) In any atmosphere that can become oxygen deficient or contaminated, or both
- (d) Below ground level

5-5 Instructors.

5-5.1 All instructors shall be deemed qualified to deliver fire fighter training by the authority having jurisdiction.

5-5.2* The participating student-to-instructor ratio shall not be greater than 5 to 1.

5-5.3 Other factors such as extreme temperatures, large groups, and classes of long duration shall be taken into consideration, and additional instructors shall be designated as deemed necessary to ensure proper levels of safety.

5-5.4 The instructor-in-charge shall be responsible for full compliance with this standard.

5-5.5 Prior to the ignition of any fire, instructors shall ensure that all protective clothing and equipment specified in this chapter are being worn properly.

5-5.6 Instructors shall take a head count when entering and exiting the area during an actual attack evolution conducted in accordance with this standard. Instructors shall monitor and supervise all assigned students closely during the live fire training evolution.

5-5.7* The instructor-in-charge shall consider the circumstances of each training session and make suitable provisions for the rest and rehabilitation of members operating at the scene. These considerations shall include medical evaluation and treatment, food and fluid replenishment, and relief from climate conditions, in accordance with the circumstances of the training session.

5-5.8 Instructors responsible for conducting live fire training evolutions with a gas-fueled training system shall be trained properly in the complete operation of the system. The training of instructors shall be performed by an individual authorized by the system manufacturer.

Chapter 6 Exterior Class B Fires

6-1 Student Prerequisites.

6-1.1* In order to ensure safe operations during a live fire training exercise involving exterior Class B fires, all participating students shall have achieved a minimum level of basic training.

6-1.2 Prior to being permitted to participate in live fire training evolutions, the student shall have received training to meet the performance objectives for Fire Fighter I of the following sections of NFPA 1001, *Standard for Fire Fighter Professional Qualifications*:

Section 3-3	Safety
Section 3-5	Fire Behavior
Section 3-6	Portable Extinguishers
Section 3-7	Personal Protective Equipment
Section 3-12	Fire Hose, Appliances and Streams
Section 3-19	Water Supply

6-1.3* Students participating in a live fire training evolution who have received the required minimum basic training from other than the authority having jurisdiction shall not be permitted to participate in any live fire training evolution without presenting prior written evidence of having successfully completed the prescribed minimum training to the levels specified in 6-1.2.

6-2 Facilities.

6-2.1* Strict safety practices shall be applied to all props and areas selected for live fire training evolutions.

6-2.2 For outside training, care shall be taken to select areas that limit the hazards to both personal safety and the environment. The training site shall be flat and open without obstructions that can interfere with fire-fighting operations.

6-2.3 Where using live training fires outside, the ground cover shall be such that it does not contribute to the fire. The ground cover shall be impervious and of such topography that the runoff from live fire does not enter municipal, private, or public waters or other sensitive areas.

6-2.4 The burn area shall be inspected visually for damage prior to live fire training evolutions. Damage shall be documented.

6-2.5 All safety devices, such as thermometers, oxygen and toxic and combustible gas monitors, evacuation alarms, and emergency shutdown switches, shall be checked prior to any live fire training evolutions to ensure they operate correctly.

6-2.6 Props shall be left in a safe condition upon completion of live fire training evolutions. Debris hindering the access of fire fighters shall be removed prior to the beginning of the next training exercise.

6-2.7 All appropriate and required permits to conduct live fire training evolutions shall be obtained.

6-2.8 The permits specified in this chapter shall be provided to outside, contract, or other separate training agencies by the authority having jurisdiction upon the request of those agencies.

6-2.9 Adjacent buildings or property that might become involved shall be protected properly or removed.

6-2.10 Utility services adjacent to the live burn site shall be removed or protected.

6-2.11 Trees, brush, and surrounding vegetation that create a hazard to participants shall be removed. Combustible materials, other than those intended for the live fire training evolution, shall be removed or stored in a protected area to preclude accidental ignition.

6-2.12 Property adjacent to the training site that could be affected by the smoke from the live fire training evolution, such as railroads, airports, or heliports; and nursing homes, hospitals, or other similar facilities shall be identified, and the persons in charge shall be informed of the date and time of the evolution.

6-2.13 Streets or highways in the vicinity of the training site shall be surveyed for potential effects from live fire training evolutions. Appropriate safeguards shall be taken to eliminate any possible hazard to motorists. Such safeguards can include street closings, traffic rerouting, signs, and police traffic control.

6-2.14 Pedestrian traffic in the vicinity of the training site shall be kept clear of the operations area of the live burn. Fire lines shall be established for this purpose.

6-2.15 Awareness of weather conditions, wind velocity, and wind direction shall be maintained. In all cases, a final check shall be made for possible changes in weather conditions immediately before actual ignition.

6-2.16 The water supply for any individual live fire training evolution shall be assessed carefully based on the extent of the evolution to be performed. Consideration shall be given to the proper control and extinguishment of the fire and the provision of necessary backup lines to protect personnel.

6-2.17 The minimum water supply and delivery for the live fire training evolutions shall meet the criteria identified in NFPA 1231, *Standard on Water Supplies for Suburban and Rural Fire Fighting*.

6-2.18 A minimum reserve of additional water in the amount of 50 percent of the fire flow demand in 6-2.17 shall be available to handle exposure protection or unforeseen situations.

6-2.19* Separate sources shall be utilized for the supply of attack lines and backup lines in order to preclude the loss of both water supply sources at the same time.

Exception: A single source shall be sufficient at a training center facility where the water system has been engineered to provide adequate volume for the evolutions conducted and a backup power source or backup pumps, or both, are in place to ensure an uninterrupted supply in the event of a power failure or malfunction.

6-2.20 Adequate areas for the staging, operating, and parking of fire apparatus that are used in the live fire training evolution shall be designated.

6-2.21 An area for parking fire apparatus and vehicles that are not a part of the evolution shall be designated so as not to interfere with fireground operations. Consideration shall be given to locating this area in order to facilitate prompt response of apparatus in the event of an emergency.

6-2.22 Where required or necessary, parking areas for police vehicles or for the press shall be designated.

6-2.23 A parking area for an ambulance or an emergency medical services vehicle shall be designated. Consideration shall be given to locating this area to facilitate prompt response in the event of a personal injury to participants in the evolution.

6-2.24 Consideration shall be given to the designation and layout of ingress/egress routes in order to ensure their availability in the event of an emergency.

6-2.25 Prior to conducting actual live fire training evolutions, a preburn briefing session shall be conducted for all participants. All facets of each evolution to be conducted shall be discussed, and assignments shall be made for all crews participating in the training session. The location of simulated victims shall not be required to be disclosed, provided that the possibility of victims is discussed in the preburn briefing.

6-2.26 A preburn plan shall be prepared and shall be utilized during the preburn briefing sessions. All features of the training areas shall be indicated on the plan.

6-2.27 Prior to conducting any live fire training, all participants shall have a knowledge of and familiarity with the props or props being used for the evolution.

6-2.28 All spectators shall be restricted to an area outside the operations area perimeter established by the safety officer.

6-2.29 Appropriate control measures such as ropes, signs, and fire line markings shall be posted to indicate the perimeter of the operations area.

6-2.30 Visitors who are allowed to observe operations and who are allowed within the operations area perimeter shall be escorted at all times and shall be equipped with and shall properly wear complete protective clothing in accordance with 6-4.15 through 6-4.20.

6-2.31 All possible sources of ignition, other than those that are under the direct supervision of the person responsible for the start of the training fire, shall be removed from the operations area.

6-2.32 There shall be ample room provided around all props so that there is space for all attack lines as well as backup lines to operate freely.

6-3 Fuel Materials.

6-3.1 The fuels that are utilized in live exterior Class B fire training evolutions shall have known burning characteristics that are as controllable as possible. Unidentified materials found in or around the structure that could burn in unanticipated ways, react violently, or create environmental or health hazards, shall not be permitted to be used.

6-3.2* Fuel materials shall be used only in the amounts necessary to create the desired fire size.

6-3.3* The instructor-in-charge shall assess the selected fire environment for factors that can affect the growth, development, and spread of the fire.

6-3.4* The instructor-in-charge, as a minimum, shall document fuel loading.

6-3.5* The training exercise shall be stopped immediately when the instructor-in-charge determines through ongoing assessment that the combustible nature of the environment represents a potential hazard. The exercise shall continue only when the appropriate actions have been taken to reduce the hazard.

6-3.6 Props used for outside live fire training shall be designed specifically for the evolution to be performed.

6-3.7* All props that use pressure to move fuel to the fire shall be equipped with remote fuel shutoffs. The remote fuel shutoff shall be within site of the prop, and the entire field of attack for the prop, but shall be outside of the safety perimeter. During the entire time the prop is in use, the remote shutoff shall be continuously attended by safety personnel trained in its operation.

6-3.8 Liquefied petroleum gas props shall be equipped with all safety features as described in NFPA 58, *Standard for the Storage and Handling of Liquefied Petroleum Gases*, and NFPA 59, *Standard for the Storage and Handling of Liquefied Petroleum Gases at Utility Gas Plants*. Where the evolution involves the failure of

a safety feature, the failed part shall be located downstream from the properly functioning safety feature.

6-3.9 Measures shall be taken where using flammable or combustible liquids to prevent runoff from contaminating the surrounding area. There shall be oil separators for cleaning the runoff water.

6-4 Safety.

6-4.1 A safety officer shall be appointed for all live fire training evolutions.

6-4.2* The safety officer shall have the authority, regardless of rank, to intervene and control any aspect of the operations when, in his or her judgment, a potential or actual danger, accident, or unsafe condition exists.

6-4.3 The responsibilities of the safety officer shall include, but shall not be limited to the following:

- (a) The prevention of unsafe acts
- (b) The elimination of unsafe conditions

6-4.4 The safety officer shall provide for the safety of all persons on the scene including students, instructors, visitors, and spectators.

6-4.5 The safety officer shall not be assigned other duties that interfere with safety responsibilities.

6-4.6 The safety officer shall be knowledgeable in the operation and location of safety features available, such as emergency shutoff switches, gas shutoff valves, and evacuation alarms.

6-4.7 Sufficient backup lines shall be provided to ensure adequate protection for personnel on training attack lines.

6-4.8* The instructor-in-charge of the live fire training evolutions shall determine, prior to each specific evolution, the number of training attack lines and backup lines that are necessary. Each hoseline shall be capable of delivering a minimum of 95 gpm (360 Lpm). The instructor-in-charge then shall assign the following:

- (a) One instructor to each functional crew, which shall not exceed five students
- (b) One instructor to each backup line
- (c) Sufficient additional personnel to backup lines to provide mobility
- (d) One additional instructor for each additional functional assignment
- (e) One safety person to each manually activated safety station

6-4.9 A method of fireground communications shall be established to enable coordination among the incident commander, the interior and exterior sectors, the safety officer, and external requests for assistance.

6-4.10 Emergency medical services shall be available on site to handle injuries. Written reports shall be filled out and submitted on all injuries and on all medical aid rendered.

6-4.11 One person shall be designated to control the materials being burned and to ignite the training fire in the presence of and under the direct supervision of a safety officer. This person shall not be a student and shall wear full protective clothing including self-contained breathing apparatus (SCBA) as required in 6-4.15 through 6-4.20 of this standard.

The decision to ignite the training fire shall be made by the instructor in charge, in coordination with the safety officer.

6-4.12 No person(s) shall play the role of a victim inside the building.

6-4.13 Fires shall not be located in any designated exit paths.

6-4.14 The training session shall be curtailed, postponed, or canceled, as necessary, to reduce the risk of injury or illness caused by extreme weather conditions.

6-4.15 Each participant shall be equipped with full protective clothing and self-contained breathing apparatus (SCBA). All participants shall be inspected by the safety officer prior to entry into a live fire training evolution to ensure that the protective clothing and SCBA are being worn properly and are in serviceable condition.

6-4.16* Protective coats, trousers, hoods, footwear, helmets, and gloves shall meet the requirements of NFPA 1971, *Standard on Protective Ensemble for Structural Fire Fighting*.

Exception: For outside fires, those persons who do not engage in or are not exposed to the hazards of structural fire fighting shall be permitted to use helmets that meet federal OSHA requirements.

6-4.17 Self-contained breathing apparatus (SCBA) shall meet the requirements of NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus for Fire Fighters*.

6-4.18* Where station or work uniforms are worn by any participant, the station or work uniform shall meet the requirements of NFPA 1975, *Standard on Station/Work Uniforms for Fire Fighters*.

6-4.19 Personal alarm devices shall meet the requirements of NFPA 1982, *Standard on Personal Alert Safety Systems (PASS) for Fire Fighters*.

6-4.20 All students, instructors, safety personnel, and other personnel shall wear properly all protective clothing and equipment specified in this chapter whenever they are involved in any evolution or fire suppression operation during the live fire training evolution.

6-4.21* All students, instructors, safety personnel, and other personnel participating in any evolution or operation of fire suppression during the live fire training evolution shall breathe from a SCBA air supply whenever operating under one or more of the following conditions:

- (a) In an atmosphere that is oxygen deficient or contaminated by products of combustion, or both
- (b) In an atmosphere that is suspected of being oxygen deficient or contaminated by products of combustion, or both
- (c) In any atmosphere that can become oxygen deficient or contaminated, or both
- (d) Below ground level

6-5 Instructors.

6-5.1 All instructors shall be deemed qualified to deliver fire fighter training by the authority having jurisdiction.

6-5.2* The participating student-to-instructor ratio shall not be greater than 5 to 1.

6-5.3 Other factors such as extreme temperatures, large groups, and classes of long duration shall be taken into consid-

eration, and additional instructors shall be designated as deemed necessary to ensure proper levels of safety.

6-5.4 The instructor-in-charge shall be responsible for full compliance with this standard.

6-5.5 Prior to the ignition of any fire, instructors shall ensure that all protective clothing and equipment specified in this chapter are being worn properly.

6-5.6* The instructor-in-charge shall consider the circumstances of each training session and make suitable provisions for the rest and rehabilitation of members operating at the scene. These considerations shall include medical evaluation and treatment, food and fluid replenishment, and relief from climate conditions, in accordance with the circumstances of the training session.

6-5.7 Instructors responsible for conducting live fire training evolutions with a gas-fueled training system shall be trained properly in the complete operation of the system. The training of instructors shall be performed by an individual authorized by the system manufacturer.

Chapter 7 Reports and Records

7-1 General.

7-1.1 The following records and reports shall be maintained on all live fire training evolutions in accordance with the requirements of this standard:

- (a) An accounting of the activities conducted
- (b) A listing of instructors present and their assignments
- (c) A listing of all other participants
- (d) Documentation of unusual conditions encountered
- (e) Any injuries incurred and treatment rendered
- (f) Any changes or deterioration of the structure
- (g) Documentation of the condition of the premises and adjacent area at the conclusion of the training exercise

7-1.2* For acquired buildings, records pertaining to the structure shall be completed.

7-1.3 Upon completion of the training session, an acquired building shall be formally turned over to the control of the property owner. A standard form indicating the transfer of authority for the building shall be completed.

7-1.4 A post-training critique session, complete with documentation, shall be conducted to evaluate student performance and to reinforce the training that was covered.

Chapter 8 Referenced Publications

8-1 The following documents or portions thereof are referenced within this standard as mandatory requirements and shall be considered part of the requirements of this standard. The edition indicated for each referenced mandatory document is the current edition as of the date of the NFPA issuance of this standard. Some of these mandatory documents might also be referenced in this standard for specific informational purposes and, therefore, are also listed in Appendix D.

8-1.1 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

NFPA 30, *Flammable and Combustible Liquids Code*, 1996 edition.

NFPA 58, *Standard for the Storage and Handling of Liquefied Petroleum Gases*, 1995 edition.

NFPA 59, *Standard for the Storage and Handling of Liquefied Petroleum Gases at Utility Gas Plants*, 1995 edition.

NFPA 1001, *Standard for Fire Fighter Professional Qualifications*, 1992 edition.

NFPA 1041, *Standard for Fire Service Instructor Professional Qualifications*, 1996 edition.

NFPA 1231, *Standard on Water Supplies for Suburban and Rural Fire Fighting*, 1993 edition.

NFPA 1402, *Guide to Building Fire Service Training Centers*, 1997 edition.

NFPA 1561, *Standard on Fire Department Incident Management System*, 1995 edition.

NFPA 1971, *Standard on Protective Ensemble for Structural Fire Fighting*, 1997 edition.

NFPA 1975, *Standard on Station/Work Uniforms for Fire Fighters*, 1994 edition.

NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus for Fire Fighters*, 1992 edition.

NFPA 1982, *Standard on Personal Alert Safety Systems (PASS) for Fire Fighters*, 1993 edition.

Appendix A Explanatory Material

This appendix is not a part of the requirements of this NFPA document but is included for informational purposes only.

A-1-3 Drills conducted to familiarize fire fighters with the proper use of self-contained breathing apparatus in a smoke environment should not be conducted under live fire conditions.

A-1-4 Authority Having Jurisdiction. The phrase “authority having jurisdiction” is used in NFPA documents in a broad manner, since jurisdictions and approval agencies vary, as do their responsibilities. Where public safety is primary, the authority having jurisdiction may be a federal, state, local, or other regional department or individual such as a fire chief; fire marshal; chief of a fire prevention bureau, labor department, or health department; building official; electrical inspector; or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the authority having jurisdiction. In many circumstances, the property owner or his or her designated agent assumes the role of the authority having jurisdiction; at government installations, the commanding officer or departmental official may be the authority having jurisdiction.

A-2-1.1 The actual structural fire attack evolution is normally conducted for one of the two following purposes:

- (a) As the final phase of basic training
- (b) As an ongoing means of maintaining and improving acquired skills

In both instances, the live fire training evolution is a means by which a fire fighter can collectively display many combinations of earlier acquired skills and develop an appreciation of the necessary safety aspects of structural fire fighting.

A-2-1.3 The type of written documentation required can vary, depending upon the instructor's familiarity with the student participants' level of training from outside agencies. All stu-

dent participants from outside agencies should be allowed to participate only as official representatives of an established organization. Prior documentation should be required in order to facilitate planning of the training session.

A-2-2.1 Where training facility burn buildings are available, they should be used instead of acquired structures.

A-2-2.3 Information pertaining to building ownership should be reviewed by the legal counsel of the authority having jurisdiction prior to accepting the structure.

A-2-2.4 Information regarding the written permission of the building owner should be reviewed by the legal counsel of the authority having jurisdiction prior to accepting the structure.

A-2-2.5 Information regarding cancellation of insurance by the building owner should be reviewed by the legal counsel of the authority having jurisdiction prior to accepting the structure.

A-2-2.9 Care should be exercised in the neutralization of hazards posed by closed tanks and vessels. The vessel or its contents can pose a hazard that should be eliminated. Appropriate references should be consulted or assistance should be obtained based on the specific circumstances encountered. The area within the tank should be filled with dry sand as a preferred means of rendering the internal atmosphere inert. Under no circumstances should water or other liquids be utilized as a means of inerting a tank or other closed vessel.

A-2-2.10 Low-density combustible fiberboard has been implicated as a major factor in the following rapidly spreading fires that resulted in fatalities:

- (a) Our Lady of the Angels School (Chicago, IL, 1958)
- (b) Hartford Hospital (Hartford, CT, 1961)
- (c) Opemiska Social Club (Chapais, Quebec, 1980)
- (d) Boulder Fire Department training fire (Boulder, CO, 1982)

Unconventional interior finishes include burlap, carpeting, and artificial turf.

The collapse of overhead structural members can result from the combined effect of the weight of both live and dead overhead loads as well as the loss of structural integrity caused by fire. Linoleum is a potential fuel source, particularly after being preheated by repeated fire exposure and thus can contribute to an unanticipated increase in fire intensity.

A-2-2.23 Reliability should be considered when determining what constitutes valid separate sources. The intent of this paragraph is to prevent the simultaneous loss of both attack lines and backup lines in the event of a pump or water supply failure. Where a public water supply system is used, two pumpers on two different hydrants should be used. Two pumpers drafting from the same pond or river also are appropriate, provided the source contains sufficient usable water. Where tankers or folding tanks, or both, are used, two separate pumpers should be used to supply the attack and backup lines.

A-2-3.2 Acceptable Class A materials include pine excelsior, wooden pallets, straw, hay, and other ordinary combustibles. An excessive fuel load can contribute to conditions that create unusually dangerous fire behavior. This can jeopardize structural stability, egress, and the safety of participants.

A-2-3.4 The instructor-in-charge is concerned with the safety of participants and the assessment of conditions that can lead

to rapid, uncontrolled burning, commonly referred to as "flashover." Flashover can trap, injure, and kill fire fighters. Conditions known to be variables affecting the attainment of flashover are as follows:

- (a) The heat release characteristics of materials used as primary fuels
- (b) The preheating of combustibles
- (c) The combustibility of wall and ceiling materials
- (d) The room geometry (e.g., ceiling height, openings to rooms)

In addition, the arrangement of the initial materials to be ignited, particularly the proximity to walls and ceilings, and the ventilation openings are important factors to be considered when assessing the potential fire growth.

A-2-3.5 Plotting the expected avenues of firespread and the time factors for expected buildup of the fire provides an extra degree of safety for the participants of the exercise. Voids can result in sudden and unexpected vertical spread of the fire and trap participants by cutting off exit routes, or can result in unexpected weakening of the structural members, leading to collapse. To compensate for this potential hazard, the instructor-in-charge should prescribe primary and secondary exit paths for participants in the exercises.

A-2-3.6 Incidents of injuries and deaths during live fire training exercises indicate that fire growth dynamics were not considered or were inaccurately assessed prior to the beginning of the exercises. Fire growth is typically linear until the flame height reaches the ceiling; thereafter, rapid acceleration can be expected. It might be necessary to remove combustible wall and ceiling materials, reduce the amount of furnishings, or take other similar measures to reduce rapid fire growth. Careful consideration should be given to the presence of combustible void spaces, and steps should be taken to ensure that the fire is not able to gain unexpected growth in such areas.

A-2-4.2 Severe weather presents the potential for health and safety hazards to all persons attending and participating in an exercise. Extreme heat can cause heat exhaustion or heat stroke, and extreme cold can cause frostbite, hypothermia, or slippery surfaces. An impending severe storm can bring lightning or high winds. Such situations warrant the careful consideration of limiting activity, waiting for a storm to pass, or postponing the exercise.

A-2-4.7 A minimum flow rate of 95 gpm (360 Lpm) is necessary in order to provide adequate quantities of water to cover the planned evolution plus a reserve for unanticipated emergencies. The appropriate quantity and exact flow rates that are needed for fire control and extinguishment should be calculated in advance, and certain factors such as equipment, manpower, fire area, and topography should be taken into consideration. Knowledge of the hoseline sizes, types of nozzles, type of fire stream to be utilized, and principles of fire attack and deployment aid in determining the exact flow rates that are necessary.

A-2-4.8 The additional safety personnel can be necessary to watch for signs of fire in voids, concealed spaces, and exit paths, or combinations thereof, at acquired structures. Where fire is discovered in any of these areas, the operation should cease as a training exercise and should be treated as a working structure fire.

A-2-4.10 Participants involved in the live fire training evolutions should be instructed to report to a predetermined loca-

tion for a roll call if evacuation of the building is signaled. Instructors should immediately report any personnel not accounted for to the instructor-in-charge. Examples of an evacuation signal that could be used include a whistle, apparatus air horn, or high-low electronic siren.

A-2-4.20 Clothing worn under protective clothing can degrade and cause injury to the wearer, even without damaging the protective clothing. All wearers of protective clothing should be aware of the dangers of clothing made from certain all-synthetic materials that can melt and adhere to and burn the wearer even while wearing protective clothing that meets NFPA standards. Any clothing, such as shirts, pants, underwear, and sweatshirts, worn under protective clothing should meet the requirements of NFPA 1975, *Standard on Station/Work Uniforms for Fire Fighters*, whenever possible, or clothing should be selected, at a minimum, for the fabric's ability to resist ignition. Fire retardant fabrics and all-natural fibers should be considered.

A-2-4.23 No person should be allowed to breathe smoke, toxic vapors or fumes, products of combustion, or other contaminated atmospheres or be exposed to an oxygen-deficient atmosphere.

A-2-4.26 The gas-fueled training systems that are available can provide the instructors with the ability to ignite the fires from a remote control room. Igniting a fire in this manner can present a safety risk to unsuspecting personnel within the burn building. It is important for the instructor located in the control room to keep in constant communication with the instructor present within the burn building. This communication is critical when initiating a fire and throughout the training exercise.

A-2-5.2 It is important that the participating student-to-instructor ratio be monitored so it does not exceed the span of control necessary to provide proper supervision of trainees.

A-2-5.7 The two most serious heat-related illnesses are heat exhaustion and heat stroke. According to the NIOSH document, *Occupational Exposure to Hot Environments, Revised Criteria*, symptoms of heat exhaustion include fatigue, nausea, headache, dizziness, pallor, weakness, and thirst. Factors that predispose a person to heat exhaustion include sustained exertion in the heat, failure to replace the water lost in sweat, and lack of acclimatization. Heat exhaustion responds readily to prompt treatments such as moving to a cooler environment, resting in a recumbent position, and taking fluids by mouth.

Heat stroke is the more serious of the heat-related illnesses and is considered a medical emergency. Symptoms of heat stroke include hot, red, dry skin, a rectal temperature of 104°F (40°C) or above, confusion, possible convulsions or loss of consciousness, or any combination of these symptoms. Factors that predispose a person to heat stroke include sustained exertion in the heat by unacclimatized workers, lack of physical fitness, obesity, recent alcohol intake, dehydration, individual susceptibility, and chronic cardiovascular disease. Heat stroke should be treated immediately. Treatments to reduce body temperature rapidly include immersing in chilled water, rinsing with alcohol, wrapping in a wet sheet, or fanning with cool, dry air, or any combination of these treatments. A physician's care is necessary to treat possible secondary disorders such as shock or kidney failure. While heat exhaustion cases greatly outnumber heat stroke cases, every case of heat exhaustion should be treated as having the potential to develop into heat stroke.

Acclimatization is a physiological adaptation to heat stress that occurs over a short period of time. After acclimatization has occurred, the body sweats more while losing less salt and can maintain a lower core temperature and lower cardiovascular demands. A person becomes acclimatized to a certain work intensity and temperature with repeated exposures to that work load and temperature. Formal acclimatization procedures might not be necessary for all fire fighters; however, training drills should be held outdoors regularly so that seasonal acclimatization can occur. For additional protection against heat stress, fire fighters might want to perform their regular aerobic training activities outdoors, especially during the spring and summer.

The metabolic demands of fire fighting range from 60 percent to 100 percent of maximum aerobic capacity. Tasks such as stair climbing, roof venting, and rescue operations, when performed in full gear, have an energy cost of 85 percent to 100 percent of maximum capacity and lead to near maximum heart rates.

It is clear from these estimates that a high level of cardiovascular fitness is an advantage in performing fire-fighting tasks. The higher level of fitness allows a longer work period and provides a greater reserve in case of an unexpected increase in work demands or in extreme environmental conditions.

There are fire incidents during which even the fittest, most acclimatized fire fighter is exposed to significant heat stress. For this reason, many fire departments have adopted formal procedures for on-scene rehabilitation and have incorporated them into their manuals for standard operating procedures. The general goals of rehabilitation are as follows:

- (a) To provide physical and mental rest, allowing the fire fighter to recuperate from demands of emergency operations and adverse environmental conditions
- (b) To revitalize fire fighters by providing fluid replacement and food as needed
- (c) To provide medical monitoring, including treatment of injuries, to determine if and when fire fighters are able to return to action

NOTE: This material was excerpted from the *NIOSH Health Hazard Evaluation Report*, HETA 90-395-2121, International Association of Fire Fighters (IAFF), Sedgwick County, KS, June 1991.

A-3-1.1 See A-2-1.1.

A-3-1.3 See A-2-1.3.

A-3-2.2 There should be ongoing concern for the progressive damage to burn buildings associated with fire intensity during live fire training evolutions. Excessive fire intensity can result in accelerated destruction of the training center burn building and can increase the risk to personnel to an unacceptable level.

A-3-2.4 Some training center burn buildings might utilize propane-fueled fires in lieu of Class A-fueled fires and still create a realistic fire training experience. Propane-fueled fires produce less smoke and other by-products than ordinary Class A combustibles and, therefore, create less of a negative environmental impact. Such fires also negate the need to clean up large amounts of burned materials at the end of the exercise, since no such materials are used. Such buildings might incorporate emergency shutdown switches and other electronic devices to monitor burn evolutions, which should provide an increased level of safety for fire fighters.

A-3-2.5 Some training center burn buildings utilize gas-fueled fires in lieu of Class A-fueled fires. Gas-fueled fires produce less smoke and other by-products than ordinary Class A combustibles and, therefore, create less of a negative environmental impact. Such fires also negate the need to clean up large amounts of burned materials at the end of the exercise, since no such materials are used. Such buildings incorporate emergency shutdown switches, ventilation systems, and other electronic devices to monitor burn evolutions, which should provide an increased level of safety for fire fighters.

A-3-2.12 See A-2-2.23.

A-3-3.2 Propane and liquefied natural gas remain in the liquid state only when they are stored and distributed under pressure. When either of these gases is released, the difference in the storage and atmospheric pressures can cause the liquid to convert quickly to a gas. During this conversion, liquid propane, for example, can expand 272.7 times its volume. With such a high expansion rate, a leaking liquid propane pipe has the potential to cause the space to reach an explosive level.

A-3-3.3 See A-2-3.4.

A-3-3.4 See A-2-3.6.

A-3-4.2 See A-2-4.2.

A-3-4.8 See A-2-4.7.

A-3-4.9 See A-2-4.8.

A-3-4.11 See A-2-4.10.

A-3-4.20 See A-2-4.20.

A-3-4.23 See A-2-4.23.

A-3-4.24 See A-2-4.26.

A-3-5.2 See A-2-5.2.

A-3-5.7 See A-2-5.7.

A-4-1.1 See A-2-1.1.

A-4-1.3 See A-2-1.3.

A-4-2.2 See A-3-2.2.

A-4-2.4 See A-3-2.4.

A-4-2.14 See A-2-2.23.

A-4-3.2 See A-2-3.2.

A-4-3.3 Where combustible liquids are used in a training center burn building, safety precautions should include, but should not be limited to, the following:

- (a) The fuel is contained in a noncombustible container.
- (b) A qualified person verifies that the rate of heat release does not result in unsafe conditions for the students, instructors, or structure.
- (c) A system is in place to prevent overflow of the container when fire-fighting water is applied.
- (d) A system is in place to prevent splashing of the fuel.
- (e) A method is in place to control unburned vapors.

A-4-3.4 See A-2-3.4.

A-4-3.5 See A-2-3.5.

A-4-3.6 See A-2-3.6.

A-4-4.2 See A-2-4.2.

A-4-4.8 See A-2-4.7.

A-4-4.9 See A-2-4.8.

A-4-4.11 See A-2-4.10.

A-4-4.20 See A-2-4.20.

A-4-4.23 See A-2-4.23.

A-4-4.26 See A-2-4.26.

A-4-5.2 See A-2-5.2.

A-4-5.7 See A-2-5.7.

A-5-1.1 See A-2-1.1.

A-5-1.3 See A-2-1.3.

A-5-2.1 These practices vary greatly, depending on the evolutions performed and the location where performed. Props that are specifically designed for live fire training represent different challenges than props that are acquired for training. Acquired props were never designed to withstand repeated burning and might present unexpected reactions when exposed to fire.

A-5-2.19 See A-2-2.23.

A-5-3.2 A fire should not be larger than is necessary for the evolution. It should be understood that it is not necessary to have large fires to teach many of the basic evolutions and tactics. Where the objective of the training session is to train in the use of master streams or multiple attack lines, larger fires might be necessary. The key element is to maintain a fire that is controllable using the available resources.

A-5-3.3 See A-2-3.4.

A-5-3.4 See A-2-3.6.

A-5-3.6 The safety person at the remote shutoff should have the authority to shut off the fuel supply to the prop when, in the safety person's judgment, the prop has malfunctioned, the fire has gone dangerously out of control, or the extinguishment team is in jeopardy.

A-5-3.9 The list of the items to be removed prior to a vehicle burn evolution should consist of, but should not be limited to, bumper compression cylinders, shock absorbers, fuel tanks, drive shafts, battery, and brake shoes (asbestos). The oil pan, transmission, and differential drain plugs should be removed, and the fluids should be drained and disposed of properly.

A-5-4.2 See A-2-4.2.

A-5-4.7 See A-2-4.7.

A-5-4.8 See A-2-4.8.

A-5-4.18 See A-2-4.20.

A-5-4.21 See A-2-4.23.

A-5-5.2 See A-2-5.2.

A-5-5.7 See A-2-5.7.

A-6-1.1 See A-2-1.1.

A-6-1.3 See A-2-1.3.

A-6-2.1 See A-5-2.1.

A-6-2.19 See A-2-2.23.

A-6-3.2 See A-5-3.2.