

NFPA No.

220

*File: 200 Series
Building Construction*

Standard Types of
BUILDING CONSTRUCTION

May
1955



Price: Twenty-five Cents*

Copyright 1955

**NATIONAL FIRE PROTECTION ASSOCIATION
International**

60 Batterymarch St., Boston 10, Mass.

National Fire Protection Association

International

Executive Office: 60 Batterymarch St., Boston 10, Mass.

The National Fire Protection Association was organized in 1896 to promote the science and improve the methods of fire protection and prevention, to obtain and circulate information on these subjects and to secure the cooperation of its members in establishing proper safeguards against loss of life and property by fire. Its membership includes over a hundred and ninety national and regional societies and associations (list on outside back cover) and more than fifteen thousand individuals, corporations, and organizations. Anyone interested may become a member; membership information is available on request.

This pamphlet is one of a large number of publications on fire safety issued by the Association including periodicals, books, posters and other publications; a complete list is available without charge on request. All NFPA standards adopted by the Association are published in six volumes of the **National Fire Codes** which are re-issued annually and which are available on an annual subscription basis. The standards, prepared by the technical committees of the National Fire Protection Association and adopted in the annual meetings of the Association, are intended to prescribe reasonable measures for minimizing losses of life and property by fire. All interests concerned have opportunity through the Association to participate in the development of the standards and to secure impartial consideration of matters affecting them.

NFPA standards are purely advisory as far as the Association is concerned, but are widely used by law enforcing authorities in addition to their general use as guides to fire safety.

Definitions

The official NFPA definitions of shall, should and approved are:

SHALL is intended to indicate requirements.

SHOULD is intended to indicate recommendations, or that which is advised but not required.

APPROVED refers to approval by the authority having jurisdiction.

Units of measurements used here are U. S. standard. 1 U. S. gallon = 0.83 Imperial gallons = 3.785 liters.

Approved Equipment

The National Fire Protection Association does not "approve" individual items of fire protection equipment, materials or services. The standards are prepared, as far as practicable, in terms of required performance, avoiding specifications of materials, devices or methods so phrased as to preclude obtaining the desired results by other means. The suitability of devices and materials for installation under these standards is indicated by the listings of nationally recognized testing laboratories, whose findings are customarily used as a guide to approval by agencies applying these standards. Underwriters' Laboratories, Inc., Underwriters' Laboratories of Canada and the Factory Mutual Laboratories test devices and materials for use in accordance with the appropriate standards, and publish lists which are available on request.

Standard Types of Building Construction.

NFPA No. 220—1955

The following text on Standard Types of Building Construction is the result of several years consideration of the subject by the Building Construction Committee and is intended to supersede all previous NFPA classifications, which date back to 1901.

In 1952, the Committee submitted a tentative standard which was adopted by the Association at its 1952 Annual Meeting. Revisions of the 1952 standard were adopted by the National Fire Protection Association at the 1954 Annual Meeting, Washington, D. C., May 17–21, 1954.

The present edition adopted by the Association on May 19, 1955, on recommendation of the Committee on Building Construction contains certain changes in the description of the fire resistance rating of structural members under the definition of fire-resistive construction in order to clarify the intent. Other than this, it is unchanged from the 1954 edition.

It is the purpose of this standard to establish definitions of types of building construction as a guide to other NFPA committees and others who may wish to specify structural requirements without detailing specific assemblies of materials.

COMMITTEE ON BUILDING CONSTRUCTION.

R. C. CORSON, *Chairman*,

Factory Mutual Engineering Division, 1151 Boston-Providence Turnpike,
Norwood, Mass.

THEODORE IRVING COE,
American Institute of Architects.

GEN. EDWARD J. MCGREW, Jr.,
New York State Building Code Commission.

NOLAN D. MITCHELL,*
National Bureau of Standards.

W. W. PRITSKY,
National Board of Fire Underwriters.

GORDON ROBERTSON,*
Building Inspector, City of Springfield,
Mass.

EDWIN N. SEARL,
Western Actuarial Bureau.

A. J. STEINER,
Underwriters' Laboratories, Inc.

*Serving in a personal capacity.

STANDARD TYPES OF BUILDING CONSTRUCTION.

NFPA No. 220—1955

Introduction.

This standard outlines standard types of building construction for the guidance of committees operating under the procedure of the National Fire Protection Association.

The fire resistance of building construction varies with the susceptibility to damage by fire of the building materials used, and the degree of fire protection, if any, provided for the structural members. Fire resistance ratings of structural members shall be determined as described in "Standard Method of Fire Test of Building Construction and Materials," a standard prepared by a joint committee of the American Society for Testing Materials, the Associated Factory Mutual Fire Insurance Companies, the National Board of Fire Underwriters, National Bureau of Standards, National Fire Protection Association and Underwriters' Laboratories, Inc., under procedure of the American Standards Association (NFPA No. 251, ASTM No. E119, ASA No. A2.1). The above standard is published as a pamphlet and in National Fire Codes, Vol. III, Building Construction and Equipment, by the National Fire Protection Association, 60 Batterymarch St., Boston 10, Mass., and in the Book of Standards by the American Society for Testing Materials, 1916 Race St., Philadelphia 3, Pa.

In this standard only those factors considered necessary to the classification of building types have been included, so that it will be necessary for the user to consider the influence of location, occupancy, exterior exposure, possibility of mechanical damage to fireproofing, and other features which may impose additional requirements for safeguarding life and property, as commonly covered in detail in building codes. In addition, fire detection and extinguishing facilities, both public and private, available or to be provided, will influence the use of the terms in this standard.

This standard provides the following classifications of building types:

Fire-resistive construction	Ordinary construction
Heavy timber construction	Wood frame construction
Noncombustible construction	

Fire-Resistive Construction.

Definition: That type of construction in which the structural members including walls, partitions, columns, floor and roof constructions are of noncombustible materials with fire resistance ratings not less than those specified in the following table.

The two classifications are identified by the required fire resistance of floors as a matter of convenience.

Fire Resistance Rating of Structural Members in Hours	Classification	
	3-hour	2-hour
Bearing walls or bearing portions of walls, exterior or interior	4	3
Bearing walls and bearing partitions must have adequate stability under fire conditions in addition to the specified fire resistance rating.		
Nonbearing walls or portions of walls, exterior or interior	NC	NC
NC-Noncombustible. Fire resistance may be required in such walls by conditions such as fire exposure, location with respect to lot lines, occupancy or other pertinent conditions.		
Principal supporting members including columns, trusses, girders and beams for one floor or roof only	3	2
Principal supporting members including columns, trusses, girders and beams for more than one floor	4	3
Floor construction members, including beams, slabs and joists not affecting the stability of the building	3	2
Roof construction members, including beams, purlins and slabs, not affecting the stability of the building	2	1½
Interior partitions enclosing stairways and other openings through floors	2	2
One-hour noncombustible partitions may be permitted under certain conditions.		

Heavy Timber Construction.

Definition: That type of construction in which bearing walls or bearing portions of walls are of noncombustible materials having a minimum fire resistance of two hours and stability under fire conditions; nonbearing exterior walls are of noncombustible construction; columns, beams and girders are

of heavy timber, solid or laminated; floor and roof construction are of wood without concealed spaces, except as permitted in paragraph (c) below. Fire resistance may be required for non-bearing exterior walls and fire resistance additional to that specified may be required in bearing walls or bearing portions of walls, by conditions such as occupancy, location with respect to lot lines, fire exposure and other pertinent conditions. (Dimensions given in the following paragraphs are nominal dimensions.)

(a). Columns, if of wood, shall be not less than 8 inches in any dimension. Beams and girders, if of wood, shall be not less than 6 inches in least dimension nor less than 10 inches in depth. Interior structural members, columns, beams, girders or trusses, of materials other than wood and having fire resistance ratings not less than 1 hour, may be substituted for heavy timber members.

(b). Floors shall be constructed of splined or tongued and grooved plank not less than 3 inches in thickness covered with 1 inch flooring, laid cross-wise or diagonally, or of laminated planks not less than 4 inches width, set on edge close together, spiked at intervals of 18 inches and covered with 1 inch flooring.

(c). Timber arches or trusses may be used to support roof loads. The framing members shall be not less than 4 inches by 6 inches, except that spaced members may be composed of two or more pieces not less than 3 inches in thickness when blocked solidly throughout their intervening spaces or when such spaces are tightly closed by a continuous wood cover plate of not less than 2 inches thickness secured to the underside of members. Splice scabs shall be not less than 3 inches thickness.

(d). Roof decks shall be of matched or splined plank not less than 2 inches thickness, or of laminated planks not less than 3 inches width, set on edge close together and laid as required for floors. Beams and girders supporting roof loads only shall be not less than 6 inches in least dimension.

(e). Interior partitions enclosing stairways and other openings through floors shall have not less than 1 hour fire resistance.

Noncombustible Construction.

Definition: That type of construction in which the walls, partitions and structural members are of noncombustible construction not qualifying as Fire Resistive Construction.

"Noncombustible" as applied to a building material or

combination of materials means that which will not ignite and burn when subjected to fire, such as the following: steel, iron, brick, tile, concrete, slate, asbestos, glass or plasters.

Protected Noncombustible Construction. Noncombustible Construction may be designated Protected Noncombustible Construction when bearing walls or bearing portions of walls, exterior or interior, are of noncombustible construction having a minimum fire resistance rating of 2 hours and are stable under fire conditions; roof and floor construction and their supports have 1 hour fire resistance; and stairways and other openings through floor are enclosed with partitions having 1 hour fire resistance.

Ordinary Construction.

Definition: That type of construction in which exterior bearing walls or bearing portions of exterior walls are of noncombustible construction having a minimum fire resistance of two hours and stability under fire conditions; nonbearing exterior walls are of noncombustible construction; and in which the roofs, floors and interior framing are wholly or partly of wood (or other combustible material) of smaller dimensions than required for Heavy Timber Construction. Fire resistance may be required for nonbearing exterior walls, and fire resistance additional to that specified may be required for bearing walls or bearing portions of walls, by conditions such as occupancy, location with respect to lot lines, fire exposure and other pertinent conditions.

Protected Ordinary Construction. **Definition:** Ordinary Construction may be designated Protected Ordinary Construction when roof and floor construction and their supports have 1-hour fire resistance, and stairways and other openings through floors are enclosed with partitions having 1-hour fire resistance.

Wood Frame Construction.

Definition: That type of construction in which exterior walls, bearing walls and partitions, floor and roof constructions and their supports are of wood or other combustible material, when the construction does not qualify as Heavy Timber Construction or Ordinary Construction.

Protected Wood Frame Construction. **Definition:** Wood Frame Construction may be designated Protected Wood Frame Construction when roof and floor construction and their supports have 1-hour fire resistance, and stairways and other openings through floors are enclosed with partitions having 1-hour fire resistance.

POCKET EDITIONS OF NFPA STANDARDS

Standards published in 4 1/4 x 7 1/4 in. size, revised as of May 21, 1955. For complete list of publications write National Fire Protection Assn., 60 Batterymarch St., Boston 10, Mass.

0 Series: Administration

1-L Fire Prevention Bureau Ordinance, 1925	\$.25
8 Fire Casualty Definition, 1953	.25
6M Fire Safety in Industry, '55	.35

10 Series: Extinguishing Appliances

10 First Aid Fire Appliances, 1955	.50
11 Foam Extinguishing Systems, 1954	.50
12 Carbon Dioxide Ext. Systems, 1949	.50
12A Inert Gas for Fire Prevention, 1941	.25
13 Sprinkler Systems, 1955	.50
13A Sprinkler Maintenance, 1953	.25
14 Standpipe and Hose Systems, 1952	.25
15 Water Spray Systems, 1955	.50
18 Wetting Agents, 1955	.35
182M Vaporizing Liquid Extinguishing, '55	.25
19 Motor Fire Apparatus Specifications, 1955	.50
191 Portable Pumping Units, 1954	.25
192 Volunteer Fire Departments, 1952	.50
193 Aerial Ladder Testing, 1955	.35
198 Fire Hose, Care of, 1936	.15

20 Series: Extinguishing Auxiliaries

20 Centrifugal Fire Pumps, 1955	.50
23 Fire Dept. Sprinkler Connections, 1931	.25
24 Outside Protection, 1955	.35
27 Private Fire Brigades, 1955	.35
29C Hydrants for Private Service, 1955	.25

30 Series: Flammable Liquids

30-L Flammable Liquids Ordinance, 1954	.50
30E Self-Service Gasoline Stations, 1950	.05
31 Oil Burning Equipments, 1955	.50
31LA Oil Burning Ordinance, 1927	.25
32 Dry Cleaning Plants, 1954	.35
32S Properties Flammable Liquids, 1954	.75
32SA Flammable Liquid Trade Name Index, '54	1.25
32B Warning Labels Flammable Liquids, 1951	.10
33 Spray Finishing, 1955	.25
34 Dip Tanks, Flammable Liquids, 1952	.25
38S Tank Vehicles, 1955	.15
392 Gasoline Stoves, 1930	.15
393 Gasoline Blow Torches, 1934	.15
395 Farm Storage of Flam. Liquids, 1947	.15

40 Series: Combustible Solids

40 Cellulose Nitrate Motion Picture Film, '53	.50
42 Pyroxylin Plastic in Factories, 1936	.35
44 Combustible Fibres, 1953	.25
47 Retail Lumber Storage, 1951	.15
48 Magnesium Handling Storage, 1954	.25
49 Table of Hazardous Chemicals, 1950	.50
492 Spontaneous Heating, Table, 1949	.25
494-L Model State Fireworks Law, 1949	.25

50 Series: Gases

51 Welding and Cutting, Gas Systems, 1954	.35
52 LPG Piping, Appliances in Bldgs., 1953	.35
54, 54A Gas Piping Appliances in Bldgs., '54	.50
56 Hospital Operating Rooms, 1954	.25
56S Nonflammable Medical Gases, 1951	.25
58 Liquefied Petroleum Gases, 1955	.35
59 LP Gas in Utility Gas Plants, 1954	.35

60 Series: Explosive Dusts

60 Pulverized Fuel Systems (old) 1946	.50
60A Pulverized Coal Systems (new) 1946	.35
61A Starch Factories, 1944	.25
61B Terminal Grain Elevators, 1954	.35
61C Flour and Feed Mills, 1954	.35
62 Sugar and Cocoa, 1952	.25
63 Dust Explosions in Industrial Plants, '48	.25
64 Country Grain Elevators, 1954	.25
651 Aluminum Bronze Powder, 1952	.25
652 Magnesium Powder or Dust, 1952	.25
653 Coal Pneumatic Cleaning Plants, 1952	.25
654 Plastics Industry, 1946	.35
655 Sulphur Dust, 1950	.25
656 Spice Grinding Plants, 1952	.25

657 Confectionery Manufacturing Plants, '52	\$.25
661 Suction-Venting in Grain Elevators, '42	.25
662 Wood Flour Manufacturing, 1946	.25
663 Woodworking Plants, 1952	.25
68 Explosion Venting, 1954	.75

70 Series: Electrical

70 National Electrical Code, 1953	1.00
71 Central Station Signaling Systems, 1955	.35
72 Proprietary Signaling Systems, 1955	.35
73 Municipal Alarm Systems, 1955	.35
74 Alarm Systems for Dwellings, 1950	.05
77 Static Electricity, 1950	.50
78 Lightning Code, 1952	.50

80-90 Series: Construction

80 Protection of Openings, 1941	.50
81 Fur Storage, Cleaning, Fumigating, 1953	.35
82, 82A Incinerators, Rubbish Handling, '55	.35
83 Transit Operations, 1952	.50
86 Ovens and Furnaces, Class A, 1950	.75
87 Piers and Wharves, 1954	.35
88 Garages, 1932	.25
90A Air Conditioning Systems, 1955	.35
90B Warm Air Heating, Residences, 1955	.35
91 Blower and Exhaust Systems, 1949	.25
93 Dehydrators and Driers, 1954	.35

100 Series: Safety to Life

101 Building Exits Code, 1952	1.00
101A Exit Drills and Alarm Systems, 1951	.25
101B Nursing Homes, 1955	.25
101C Interior Finish, 1955	.25
102 Places Outdoor Assembly, 1949	.25

200 Series: Building Construction

220 Std. Types of Building Construction, '55	.25
223 Fire Protective Constr. on the Farm, '53	.35
224 Homes, Camps in Forested Areas, 1953	.35
231 General Storage Standards, 1946	.25
251 Fire Tests Bldg. Materials, 1955	.25
253 Fire Tube Apparatus, Treated Wood, '55	.35
254 Crib Test, Treated Wood, 1955	.35
255 Hazard Test Bldg. Materials, 1955	.25

300 Series: Marine

302 Motor Craft, 1955	.35
303 Boatyards and Marinas, 1952	.25
304L Petroleum Wharves, 1938	.25
306 Gas Hazards on Vessels, 1951	.15
307 Operation of Marine Terminals, 1951	.25
312 Vessels, Construction and Repair, 1951	.15

400 Series: Aviation

402 Aircraft Rescue Procedure, 1954	.35
403 Aircraft Rescue Equipment, 1955	.50
404 Static Electricity, Aircraft, 1954	.15
406 Fire Dept. Handling Crash Fires, 1955	.35
407 Fueling Aircraft, 1955	.50
408 Aircraft Hand Extinguishers, 1955	.25
409 Aircraft Hangars, 1954	.50

500 Series: Ground Transportation

501 Trailer Coaches and Trailer Courts, 1952	.25
505 Industrial Trucks, 1955	.25
512 Truck Fire Protection, 1955	.25

600 Series: Operating Methods

601 The Watchman, 1951	.25
604 Salvaging Operations, 1954	.50

700: Classification, Treatment Materials

701 Flameproofed Textiles, 1951	.35
---------------------------------	-----

800 Series: Radioactive Materials

801 Radioactive Material, Labs., 1955	.50
---------------------------------------	-----

National Fire Codes

Contents 1955 Editions

These six volumes, republished annually to keep up to date, are bound in red cloth, gold stamped. 5½ x 8½ inches, 500 to 800 pages each. \$6.00 per volume, special discounts to NFPA members on subscription basis. Available from National Fire Protection Association, 60 Batterymarch Street, Boston 10, Mass. Many of these same standards are also available in pocket editions.

Vol. I

Flammable Liquids and Gases

- 1L Fire Prev. Bureau Ordinance, 1925
- 3 Definition of Fire Casualty, 1953
- 6M Fire Safety Guide in Industrial Establishments, 1955
- 30L Flammable Liquids Ordinance, 1954
- 30A Tanks in Flooded Regions, 1937
- 30C Rooms, Cabinets and Outside Houses for Flammable Liquids, 1951
- 30D Concrete Fuel Oil Tanks, 1922
- 30E Self Service Gasoline Stations, 1950
- 30F Abandonment or Removal of Underground Tanks, 1951
- 31 Oil Burning Equipments, 1955
- 31LA Oil Burner Ordinance, 1927
- 32 Dry Cleaning Plants, 1954
- 33 Spray Finishing, 1955
- 34 Dip Tanks, 1952
- 35 Lacquer Manufacturing Plants, 1946
- 37 Internal Combustion Engines, 1934
- 37A Coal Gas Producers, 1934
- 51 Welding & Cutting, 1954
- 52 LPG Piping, Appliances Bldgs., 1953
- 53 Gasoline Vapor Gas Machines, Lamps, and Systems, 1932
- 54 Gas Piping Appliances in Bldgs., 1954
- 54A City Gas, 1943
- 55 Emergency Gas Shut-off Valves, 1924
- 56 Hospital Operating Rooms, 1954
- 58 Liquefied Petroleum Gases, 1955
- 59 LPG at Utility Gas Plants, 1954
- 86 Class A Ovens and Furnaces, 1950
- 325 Properties Flammable Liquids, 1954
- 325A Trade Name Index of Flammable Liquids
- 326 Warning Labels Flam. Liquids, 1951
- 392 Gasoline Stoves, 1930
- 393 Gasoline Blow Torches, 1934
- 395 Farm Storage Flam. Liquids, 1947
- 565 Non-Flammable Medical Gases, 1951
- 574 Fumigation of Grain, 1939
- 574L Fumigation Ordinance, 1939

Vol. II

Combustible Solids, Dusts, Chemicals and Explosives

- 40 Cellulose Nitrate Motion Picture Film, 1953
- 42 Pyroxylin Plastic in Factories, 1936
- 43 Pyroxylin Warehouses, Stores, 1940
- 44 Combustible Fibres, 1953
- 47 Lumber Storage, 1951
- 48 Magnesium Storage, Processing, 1954
- 49 Table Hazardous Chemicals, 1950
- 60 Pulverized Fuel Systems, 1946
- 60A Pulverized Coal Systems, 1946

- 61A Starch Factories, 1944
- 61B Terminal Grain Elevators, 1954
- 61C Flour and Feed Mills, 1954
- 62 Sugar and Cocoa, 1952
- 63 Dust Explosions, Industrial Plants, 1948
- 64 Country Grain Elevators, 1954
- 68 Explosion Venting, 1954
- 69 Inerting for Fire and Explosion Prevention, 1941
- 81 Fur Storage, Cleaning, 1953
- 93 Dehydrators and Driers, 1954
- 492 Spontaneous Heating, Table, 1949
- 493 Spontaneous Ignition of Coal, 1936
- 494L Model State Fireworks Law, 1949
- 495L Explosives Ordinance for Cities, 1941
- 651 Aluminum Bronze Powder, 1952
- 652 Magnesium Powder or Dust, 1952
- 653 Coal Pneumatic Cleaning Plants, 1952
- 654 Plastics Industry, 1946
- 655 Sulphur Dust, 1946
- 656 Spice Grinding Plants, 1952
- 657 Confectionery Mfg. Plants, 1952
- 661 Suction-Venting in Elevators, 1942
- 662 Wood Flour Manufacturing, 1946
- 663 Woodworking Plants, 1952
- 801 Radioactive Materials, Laboratories, '55

Vol. III

Building Construction and Equipment

- 80 Protection of Openings, 1941
- 80A Protection Against Exposure Fires, 1925
- 82 Incinerators, 1955
- 82A Rubbish, Handling, 1948
- 88 Garages, 1932
- 90A Air Conditioning Systems, 1955
- 90B Warm Air Heating, Air Conditioning for Residences, 1955
- 91 Blower and Exhaust Systems, 1949
- 92 Waterproofing of Floors, Drainage of Scuppers, 1937
- 101 Building Exits Code, 1952
- 101B Nursing Homes, 1955
- 101C Interior Finish, 1955
- 102 Places of Outdoor Assembly, 1949
- 103 Hotel Fire Safety Law, Guide, 1948
- 201 Structural Defects, 1921
- 202 Roof Openings, Cornices, Gutters, 1917
- 203 Roof Coverings, 1910
- 211 Chimneys and Flues, 1944
- 212 Smokepipes and Stovepipes, 1942
- 213 Spark Arresters, 1936
- 220 Standard Building Types, 1955
- 221 Standard Industrial Buildings, 1928
- 222 Private Residences, 1925
- 223 Farm Fire Protective Const., 1953
- 224 Homes in Forested Areas, 1953

- 231 General Storage, 1946
- 232 Protection of Records, 1946
- 241 Bldg. Construction Operations, 1933
- 242 Construction of Bridges, 1937
- 243 Construction of Tunnels, 1937
- 244 Subway Construction Operations, 1937
- 251 Fire Tests of Bldg. Construction and Materials, 1955
- 252 Tests of Door Assemblies, 1950
- 253 Tests of Treated Wood by Fire Tube Apparatus, 1955
- 254 Tests Treated Wood by Crib Test, 1955
- 255 Test for Fire Hazard of Building Materials, 1955
- 701 Flameproofed Textiles, 1951

Vol. IV Extinguishing Equipment

- 10 First Aid Fire Appliances, 1955
- 11 Foam Extinguishing Systems, 1954
- 12 Carbon Dioxide Ext. Systems, 1949
- 13 Sprinkler Systems, 1955
- 13A Sprinkler Maintenance, 1953
- 14 Standpipe and Hose Systems, 1952
- 15 Water Spray Systems, 1955
- 18 Wetting Agents, 1955
- 19 Motor Fire Apparatus, Specs., 1955
- 20 Centrifugal Fire Pumps, 1955
- 21 Steam Fire Pumps, 1937
- 22 Water Tanks Private Protection, 1950
- 23 Fire Dept. Hose Connections, 1931
- 24 Outside Protection, 1955
- 26 Valves Controlling Water Supplies, '31
- 27 Private Fire Brigades, 1955
- 29A Valve Specifications, 1933
- 29B Indicator Posts, Specifications, 1933
- 29C Hydrant Specifications, 1955
- 182M Vaporizing Liquid Extinguishing, '55
- 191 Portable Pumping Units, 1954
- 192 Volunteer Fire Departments, 1952
- 192A Volunteer Fire Dept. Equipment, '52
- 192B Volunteer Fire Dept. Organization, '42
- 192C Volunteer Fire Dept. Ordinance, 1938
- 192D State Legislation for Volunteer Fire Dept. Organization, 1938
- 193 Aerial Ladder Testing, 1955.
- 194 Hose Couplings
- 198 Care of Fire Hose, 1936
- 291 Uniform Marking of Hydrants, 1935

- 295 Forest Fire Fighting Equipment, 1934
- 296 Water Systems on Farms, 1938
- 297 Fire Equipment, Metal Mines, 1931
- 601 The Watchman, 1951
- 604 Salvaging Operations, 1954

Vol. V Electrical

- 70 National Electrical Code, 1953 Interpretations and Interim Amendments to July 30, 1955
- 71 Central Station Signaling Systems, '55
- 72 Proprietary Signaling Systems, 1955
- 73 Municipal Alarm Systems, 1955
- 74 Alarm Systems for Dwellings, 1950
- 77 Static Electricity, 1950
- 78 Protection Against Lightning, 1952

Vol. VI Transportation

- Government Regulations
- 83 Transit Operations, 1952
- 87 Piers and Wharves, 1954
- 301 Marine Fire Hazards, 1929
- 302 Motor Craft, 1955
- 303 Boatyards and Marinas, 1952
- 304L Petroleum Wharves, 1938
- 305 Gasoline Fueling, Small Craft, 1930
- 306 Vessels, Control of Gas Hazards, 1951
- 307 Operation of Marine Terminals, 1951
- 311 Ship Fire Signal, 1949
- 312 Vessels During Construction, Repair and Lay-up, 1951
- 385 Tank Vehicles for Flam. Liquids, 1955
- 402 Aircraft Rescue Procedure, 1954
- 403 Aircraft Rescue Equipment, 1955
- 404 Static Electricity Aircraft, 1954
- 406 Fire Dept. Handling Crash Fires, 1955
- 407 Fueling Aircraft, 1955
- 408 Aircraft Hand Fire Extinguishers, 1955
- 409 Aircraft Hangars, 1954
- 501 Trailer Coaches and Courts, 1952
- 505 Industrial Trucks, 1955
- 512 Truck Fire Protection, 1955

Typical NFPA BOOKS

(Complete list on request)

NFPA Handbook of Fire Protection. Crosby-Fiske-Forster. The standard handbook of fire protection engineering, including fundamental reference data for experienced men specializing in fire prevention and fire protection. Includes hydraulic data, charts, tables, illustrations of automatic sprinklers, and other fire protection devices, and much other material not elsewhere available. Eleventh edition (1954), 1,656 pages. Price **\$10.50**

NFPA Inspection Manual. A pocket manual for inspectors covering inspection procedure, heating hazards, inspection of protective equipment, and much other valuable information. Cloth bound, 366 pages, 1950. Price **\$3.00**

Industrial Fire Brigades Training Manual. Prepared by the NFPA Committee on Firemen's Training. The text includes information on organizing and training the plant fire brigade, necessary routine for the maintenance of plant fire protection, and general information on fire hazards. 1954. 8½ x 11 in., 160 pgs., 385 illust. Price **\$3.25**